


NOTE \* STARTER PANEL WILL BE LOCATED AT HIGH LEVEL  
\* 10M THERMOSTAT CABLE LENGHT WILL BE PROVIDED AS PER CONTRACT.

WMS	WIREMESH SUPPLY
WME	WIREMESH EXHAUST

Equipment Tag Number.	Qty	Area Served			Supply Air Fan								Cooling Coil								Electrical Data			REMARKS
		Floor	Space	MEW ACTIVITY	FA / UNIT (l/s)	EA / UNIT (l/s)	HRU	SA/Unit (l/s)	RA/Unit (l/s)	ESP (Pa)	Fan Motor Power/Unit (kW)	Speed Control	On Coil		Off Coil		TC (kW)	SC (kW)	CHW Flow (l/s)	Pipe Connection (mm)	Volt	Phase	Hz	
													DB (°C)	WB (°C)	DB (°C)	WB (°C)								
AHU-G-0070	1	GROUND FLOOR	RETAIL	SHOPPING MALL	133	157	HRU-M1-01	1341	1208	250	2.200	Constant	22.2	16.8	13.7	13.2	15.4	13.7	0.410	32	415	3	50	PACKAGE AHU



- NOTES
- DRAWINGS DIMENSIONS ARE TO BE READ NOT TO BE SCALED.
  - ARCHITECTURAL DRAWING MUST BE READ IN CONJUNCTION WITH ALL OTHER SERVICE DRAWINGS AND CONTRACT DOCUMENTS AND IN CASE OF ANY DISCREPANCIES ARISE BETWEEN THESE DRAWINGS AND ANY OF THE DOCUMENTS THEY SHOULD BE IMMEDIATELY REPORTED TO THE ENGINEER BEFORE THE COMMENCEMENT OF ANY WORK ON SITE.
  - ALL THE LEVELS AND DIMENSIONS MUST BE CHECKED AND VERIFIED BY THE MAIN CONTRACTOR BEFORE THE COMMENCEMENT OF ANY ITEM OF WORK ON THE SITE OR THE PREPARATION OF THE SHOP DRAWINGS.
  - THE INVESTOR'S EXTERNAL FACING SHOPFRONT SIGNAGE (IF ANY) MUST STRICTLY COMPLY WITH THE OWNER'S REQUIREMENTS AND DIRECTIONS.
  - NO CHANGES AND/OR PENETRATIONS OF ANY DESCRIPTION WILL BE PERMITTED TO THE OWNER - PROVIDED EXTERNAL GLASS SHOP FRONTS.
  - SUPPLY, STORAGE AND PROTECTION OF EXPANSION JOINT COVERS AND RELATED ACCESSORIES INSIDE ALL INVESTOR SPACES IS BY THE OWNER. INSTALLATION OF THE SAME WILL BE BY THE INVESTOR. SUPPLY AND INSTALLATION OF THE VAPOR BARRIER, FIRE BARRIER & INSULATION DRAPE ASSEMBLY WILL BE BY THE OWNER.
  - THIS DRAWING IS INDICATIVE ONLY ( NOT TO BE USED FOR CONSTRUCTION ) AND IS ACCURATE AS AT THE DATE SHOWN ON THE DRAWING.
  - THIS DRAWING IS SUBJECT TO CHANGE AS PLANNING, DEVELOPMENT AND CONSTRUCTION CONTINUES THROUGH UNTIL OPENING OF THE CENTRE.
  - IT IS THE RESPONSIBILITY OF THE RECIPIENT OF THIS DRAWING TO UPDATE THEMSELVES WITH ANY SUBSEQUENT REVIEWS, UPDATES, ADDITIONS, DELETIONS AND /OR SUBSTITUTIONS.
  - IT IS THE RESPONSIBILITY OF THE INVESTOR TO UNDERTAKE AN ON-SITE MEASURE TO VERIFY ALL DIMENSIONS SHOWN ON THIS DRAWING
  - TAMDEEN REAL ESTATE CO. DOES NOT ACCEPT ANY LIABILITY OF ANY FORM FOR THE RECIPIENT'S USE AND/OR INTERPRETATION OF THIS DRAWING
  - THE ANCHOR BOLT SIZE USED FOR ANY FLOORING SUPPORTING SYSTEM SHOULD NOT EXCEED MORE THAN 8mm DEPTH TO AVOID ANY DAMAGE THAT MAY CAUSED IN THE IMBEDDED PVC CONDUIT.

FOR REVIEW

OWNER

**تمدین TAMDEEN GROUP**

PROJECT TITLE

Al Khiran Outlet Mall

CONSULTANTS

**cracknell SSH**

DESIGN ARCHITECT

**CALLISONRTKL**  
A DESIGN CONSULTANCY OF ARCADIS

ENGINEER OF RECORD

**مطعم ومهندسة دارocha OHA ENGINEERING CONSULTANT**  
P.O. Box 6249 HAWAILLY - CODE NO 30207 - KUWAIT  
PHONE: 22400508 - 22405515 FAX: 22455511  
E-mail oha@darocha.com

MANAGED BY

**تمدین TAMDEEN MALL MANAGEMENT CO. K.S.C.C**  
P.O. BOX: 29060 SAFAT 13151, KUWAIT  
TEL: +965 25362330  
FAX: +965 25362350  
WWW.TAMDEENMALLS.COM

DRAWING TITLE:

**GROUND FLOOR RETAIL-HVAC PLAN**

UNIT NO.	G-128	
USAGE.	RETAIL	
TRADE	SCALE	DATE
HVAC	1:50 @ A1	JULY 2020
DRAWN BY	CHECKED BY	APPROVED BY
--	--	--
DRAWING No.	OF	REV.
AC-01	03 OF 07	00