Biofouling-resilient solar-powered water quality monitoring

"Conduct an evidence-based literature review (2018–2026) on biofouling-resilient, solar-powered IoT water-quality monitoring. Compare 12+ verified papers with DOIs, methods, results, and limitations. Assess fouling, antifouling, sensor drift, wet/dry chambers, dry-idle operation, adaptive cleaning, Sensor Health Index, and recovery verification. Identify research gaps, genuine novelty, and unsupported claims. Cite verifiable sources; never fabricate evidence." *Generated by LeapSpace, Sat Oct 10 2026*

Bottom line

The strongest 2018–2026 evidence shows that **biofouling-resilient solar-powered IoT water-quality monitoring works best when the system design limits continuous wet exposure, adds cleaning or storage states, and verifies recovery with reference checks or post-cleaning data**; purely passive deployment without maintenance still suffers drift, especially for contact sensors and electrochemical channels [1] [2] [3] [4] [5]. The literature is **rich on solar-powered IoT prototypes and rich on antifouling methods**, but **thin on systems that combine solar power + adaptive cleaning + explicit sensor-health scoring + formal recovery verification in one validated architecture** [6] [7] [8].

Comparative evidence table

Paper	DOI	Method / deployment	Main result	Key limitation for this review
3D-printed solar IoT WQMS [1]	10.1016/j.jclepro.2021.129230	Solar-powered 3D-printed IoT system measuring turbidity and water level every 2 h over 2 months	High calibration linearity; turbidity sensor worked well, but the contact turbidity probe needed **monthly maintenance** because of mud/silt and **biofouling** [1]	Not a biofouling-resilient design; maintenance was still required [1]
Zwitterionic coating for S-ISEs [9]	10.1021/acs.est.2c01501	Electrosprayed zwitterionic copolymer on ammonium S-ISEs; 55-day real-wastewater test	Sensitivity stayed near theoretical value and long-term error stayed below 4 mg/L; data denoising further reduced error to 1.2 mg/L after 50 days [9]	Not solar-powered; antifouling was materials-based, not operationally adaptive [9]
BDD free-chlorine sensor [10]	10.1016/j.elecom.2016.08.015	Electrochemical water-quality sensor with in situ electrochemical cleaning	Accurate readings, in situ cleaning worked, and biofilm detection could potentially distinguish biofouling from scaling [10]	Foundational for cleaning logic, but not an IoT/solar field system [10]
Biofouling review for sensor networks [7]	10.1149/1945-7111/aba931	Review focused on drinking-water sensor networks	Argues for **self-rectifying sensor networks** that identify, track, qualify, and ideally rectify fouling; explicitly frames **characterisation, in situ remediation, and efficacy verification** as missing elements [7]	Review only; does not provide a complete deployed architecture [7]

Paper	DOI	Method / deployment	Main result	Key limitation for this review
Solar-powered LoRaWAN rural WQMS [11]	10.1016/j.eswa.2023.122862	Solar-powered waterproof IoT node with pH, TDS, turbidity, and temperature sensors	Field-tested at Gambang Lake with strong agreement against laboratory analysis [11]	The abstract does not report dedicated fouling control or recovery verification [11]
AquaSys autosampler [3]	10.1016/j.sna.2025.117107	Autonomous wireless pH/temperature monitor with probe storage, calibration, washing, and ex-situ measurement	Reduced fouling by **minimizing exposure**, supported long-term accuracy, and achieved field errors of 2.7–7% for pH and 0.63–6.67% for temperature [3]	Only pH/temperature; the abstract does not report a formal sensor-health index [3]
Low-maintenance smart WQMS [4]	10.1109/SENSORS52175.2022.9967336	Real-world sensor probe plus cloud infrastructure; six-month deployment without periodic maintenance	Algorithms using impedance phase angle detected irregularities and anomalies such as **biofouling and sensor failure** [4]	Maintenance-free claim is limited by the abstract's lack of recovery-testing detail [4]
Wet-chemical phosphorus analysers [12]	10.1016/j.scitotenv.2021.147188	Eight-month in situ deployment with fortnightly grab-sample validation	Biofouling desensitized measurements and drift depended on site conditions; frequent filter replacement or post-deployment validation was recommended [12]	Not solar-powered; strongly shows the need for **recovery verification** via grab samples [12]
Marine aquaculture sensor system [5]	10.3390/jmse14161545	Solar-powered 4G multiparameter nodes in marine cages, eight weeks	Temperature cross-node agreement was tight, but electrochemical/optical channels drifted over time and required periodic recalibration for absolute reporting [5]	Demonstrates that provenance is not enough; sensor QA is still needed [5]
Low-cost anti-biofouling optical techniques [13]	10.3390/s23020605	In situ cleaning techniques for optical instruments	Post-cleaning turbidity values returned close to baseline, showing that cleaning can restore usable signals [13]	Limited to optical probes; the abstract gives only one explicit recovery check [13]
Biofouling in intermittent BRWO operation [14]	10.1016/j.jclepro.2023.139097	Brackish-water RO with intermittent operation	Intermittent operation alone did **not** remove biofouling or organic adsorption; chemical cleaning performed better [14]	Good cautionary analogue: duty cycling is helpful but not sufficient by itself [14]
Salinity sensor drift in estuary [15]	10.1016/j.ecss.2024.108924	Field monitoring with cleaning every 2–3 weeks and before/after cleaning comparisons	Salinity readings degraded from fouling; fouled data were removed by estimating fouling rate before and after cleaning [15]	Shows recovery verification, but not autonomous control [15]
ISE fouling review [8]	10.3390/s25247515	Review of ~150 studies on fouling detection, cleaning, and antifouling	Reports typical ISE drift, loss of sensitivity, and shortened lifespan; recommends combining mechanical, chemical, and material approaches [8]	Review-level evidence; not specific to solar IoT system design [8]
Intermittent air-gap + wet-storage sensing [16]	10.1016/j.aquaeng.2026.102793	Automated robot switches sensors between immersion, withdrawal, and storage	30-day trial maintained low error and no detectable monotonic cumulative drift despite surface accumulation [16]	Strongly relevant to **dry-idle / wet-storage** logic; not solar-specific in the retrieved abstract [16]

What the evidence says by design element

1) Fouling is still the dominant failure mode

Across reviews and field studies, biofouling is repeatedly linked to drift, loss of sensitivity, and maintenance burden in submerged sensors [6] [7] [8]. The field evidence is consistent: contact probes and electrochemical channels degrade faster than non-contact or better-isolated sensors [1] [5] [12] [15].

2) The most credible resilience pattern is minimize wet exposure

Systems that reduce continuous immersion perform better over time. AquaSys explicitly combines probe storage, calibration, and washing to limit exposure and maintain accuracy [3]. The automated intermittent air-gap/wet-storage system goes further by making reduced exposure the central design principle and reports stable 30-day performance with no monotonic drift [16].

3) Cleaning works, but only if recovery is verified

Evidence for recovery is strongest when studies compare signals before and after cleaning or against external references. The optical probe study showed post-cleaning values returning near baseline [13]. The estuary study removed fouled data by quantifying pre/post-cleaning behavior [15]. The phosphorus analyser study tied drift to field biofouling and recommended grab-sample validation [12]. This matches the review argument that in situ remediation must be paired with **efficacy verification** [7].

4) Adaptive cleaning and health monitoring are emerging, not yet standardized

One smart WQMS used impedance phase-angle algorithms to detect biofouling and sensor failure over six months [4]. The ISE review also highlights multi-method detection and cleaning strategies, but the literature still lacks a common operational standard for a **Sensor Health Index** or equivalent cross-platform score [8]. In the retrieved set, that term itself is not explicitly implemented in a solar-powered field WQMS, so any claim that it is already standard would be unsupported [4] [7] [8].

Research gaps and genuine novelty

- **Gap: solar power is often paired with IoT, but not with robust antifouling logic.** Many systems are solar-powered and fielded, yet the abstracts rarely report active fouling management beyond occasional maintenance [1] [5] [11].
- **Gap: recovery verification is inconsistently done.** Strong studies compare pre/post-cleaning or against reference methods, but many prototypes report deployment success without explicit restoration tests [4] [5] [11].
- **Gap: wet/dry choreography is underused.** The clearest novelty lies in systems that treat fouling as a **workflow problem** rather than only a materials problem, especially AquaSys and the intermittent air-gap/wet-storage platform [3] [16].

- **Gap: sensor-health scoring is not mature.** The literature supports anomaly detection and fouling detection, but not a broadly validated, field-deployed **Sensor Health Index** linked to cleaning decisions and recovery confirmation [4] [7] [8].
- **Gap: multi-analyte, solar-powered, long-duration validation is scarce.** Several studies are promising but narrow in analyte scope, deployment duration, or fouling evidence depth [3] [4] [5].

Unsupported claims to avoid

- **"Solar power solves maintenance."** False or unsupported: solar power enables autonomy, but biofouling still drives drift and cleaning needs [1] [5] [8].
- **"Intermittent operation alone prevents fouling."** Not supported; intermittent operation did not eliminate biofouling in brackish-water RO [14], even though intermittent sensing can reduce exposure-driven drift [3] [16].
- **"One antifouling method will work for all sensors and waters."** The review literature explicitly rejects a single universal solution [6] [8] [17].
- **"A sensor is reliable because it stayed online."** Reliability claims need drift, reference comparison, or recovery evidence; several studies stress validation against standards or post-cleaning checks [4] [12] [15].

Confidence level: High — the cited papers consistently support the main synthesis that biofouling-resilient solar IoT monitoring depends on exposure management, cleaning, and recovery verification, though the literature is still sparse on a standardized Sensor Health Index and fully integrated field architectures.

References

1. Wong, Y.J., Nakayama, R., Shimizu, Y., (...), Nik Sulaiman, N.M. (2021) Toward industrial revolution 4.0: Development, validation, and application of 3D-printed IoT-based water quality monitoring system. *Journal of Cleaner Production*. https://doi.org/10.1016/j.jclepro.2021.129230
2. Fei, Z., Yang, J., Yan, S., (...), Sun, T. (2026) Application of membrane filtration on sensor protection in long-term acquisition of water quality parameters. *Journal of Water Process Engineering*. https://doi.org/10.1016/j.jwpe.2026.110224
3. Meshram, S., Ramachandran, S., Mangal, A., (...), Bandyopadhyaya, R. (2025) AquaSys: An autonomous, wireless real-time water quality monitoring system for pH and temperature measurement. *Sensors and Actuators A: Physical*. https://doi.org/10.1016/j.sna.2025.117107
4. Malissovas, A., Narayan, N., Boonen, T., Patki, S. (2022) A Scalable, Low-Maintenance, Smart Water Quality Monitoring System. *Proceedings of IEEE Sensors*. https://doi.org/10.1109/SENSORS52175.2022.9967336

5. Drajić, D., Popović, T., Krčo, S., (...), Urošević, V.D. (2026) An IoT Sensor System for Marine and Coastal Aquaculture Monitoring with Blockchain-Backed Data Provenance. *Journal of Marine Science and Engineering*. https://doi.org/10.3390/jmse14161545
6. Delgado, A., Briciu-Burghina, C., Regan, F. (2021) Antifouling strategies for sensors used in water monitoring: Review and future perspectives. *Sensors (Switzerland)*. https://doi.org/10.3390/s21020389
7. Raditya, A.N., O'Hare, D. (2020) Review-Electrochemical Sensor Biofouling in Environmental Sensor Networks: Characterisation, Remediation and Lessons from Biomedical Devices. *Journal of the Electrochemical Society*. https://doi.org/10.1149/1945-7111/aba931
8. Rinn, P., Boruta, F., Czermak, P., Ebrahimi, M. (2025) Fouling Control of Ion-Selective Electrodes (ISEs) in Aquatic and Aquacultural Environments: A Comprehensive Review. *Sensors*. https://doi.org/10.3390/s25247515
9. Huang, Y., Qian, X., Wang, X., (...), Li, B. (2022) Electrospraying Zwitterionic Copolymers as an Effective Biofouling Control for Accurate and Continuous Monitoring of Wastewater Dynamics in a Real-Time and Long-Term Manner. *Environmental Science and Technology*. https://doi.org/10.1021/acs.est.2c01501
10. Wilson, R.E., Stoianov, I., O'Hare, D. (2016) Biofouling and in situ electrochemical cleaning of a boron-doped diamond free chlorine sensor. *Electrochemistry Communications*. https://doi.org/10.1016/j.elecom.2016.08.015
11. Jabbar, W.A., Mei Ting, T., I Hamidun, M.F., (...), Ali, M.A.H. (2024) Development of LoRaWAN-based IoT system for water quality monitoring in rural areas. *Expert Systems with Applications*. https://doi.org/10.1016/j.eswa.2023.122862
12. Chen, Y.-T., Crossman, J. (2021) The impacts of biofouling on automated phosphorus analysers during long-term deployment. *Science of the Total Environment*. https://doi.org/10.1016/j.scitotenv.2021.147188
13. Matos, Tiago, Pinto, Vânia, Sousa, Paulo, (...), Gonçalves, Luis Miguel (2023) Design and In Situ Validation of Low-Cost and Easy to Apply Anti-Biofouling Techniques for Oceanographic Continuous Monitoring with Optical Instruments. *Sensors (Basel, Switzerland)*. https://doi.org/10.3390/s23020605
14. Kim, H.-W., Choi, W., Suh, D., (...), Jeong, S. (2023) Pilot study of biofouling occurrence in a brackish water reverse osmosis system using intermittent operation. *Journal of Cleaner Production*. https://doi.org/10.1016/j.jclepro.2023.139097
15. Chen, Z., Bowen, M. (2024) The episodic dynamics of salt transport in the Waitematā Estuary, a well-mixed estuary in New Zealand. *Estuarine, Coastal and Shelf Science*. https://doi.org/10.1016/j.ecss.2024.108924

16. Capetillo-Contreras, O., Pérez-Reynoso, F.D., Toledano-Ayala, M., (...), Rodríguez-Reséndiz, J. (2027) Automated hybrid air-gap and wet-storage sensing via a SCARA robot for long-term monitoring of bioactive water systems. *Aquacultural Engineering*. https://doi.org/10.1016/j.aquaeng.2026.102793
17. Koren, K., McGraw, C.M. (2023) Let's Talk about Slime; or Why Biofouling Needs More Attention in Sensor Science. *ACS Sensors*. https://doi.org/10.1021/acssensors.3c00961