

**GICEA TEST REPORT**

**C. C. PATEL ENVIRONMENT TESTING LABORATORY**

TEST REPORT ID NO.: 695/PWR/25-26

REPORT DATE: 22/01/2026

- 1) NAME & ADDRESS OF THE CUSTOMER : LAKSHYA INTERNATIONAL SCHOOL, OPP. APPLEWOOD, SHANTIPRA, AHMEDABAD  
2) SAMPLE TYPE & TESTING REQUIRED : CHEMICAL AND MICROBIOLOGICAL TESTING OF PRESCHOOL R.O. WATER  
3) SAMPLE COLLECTED & SUPPLIED BY : CUSTOMER  
4) DATE OF SAMPLE RECEIVED : 19/01/2026  
5) DATE OF SAMPLE TESTING : 19/01/2026  
6) SAMPLE CONDITION ON RECEIPT : SATISFACTORY  
7) CUSTOMER REFERENCE NO. IF ANY : -


| SR. NO. | PARAMETER ANALYSED         | ANALYSIS VALUE | UNITS                     | PERMISSIBLE LIMIT IN ABSENCE OF ALTERNATE SOURCE AS PER IS - 10500, 2012 | REFERENCE TEST METHOD NO. USED                                         |
|---------|----------------------------|----------------|---------------------------|--------------------------------------------------------------------------|------------------------------------------------------------------------|
| 1       | PH AT 25.0 °C              | 7.34           | -                         | 6.5 - 8.5                                                                | APHA 22 <sup>ND</sup> ED. 2012 - 4500 H <sup>+</sup> B                 |
| 2       | CONDUCTIVITY@ 25°C         | 309.00         | µS/CM                     | NS                                                                       | APHA 22 <sup>ND</sup> ED. 2012 - 2510 B                                |
| 3       | COLOUR                     | BDL            | HAZEN UNITS               | 15.00                                                                    | APHA 22 <sup>ND</sup> ED. 2012 - 2120 B                                |
| 4       | ODOUR                      | AGREEABLE      | -                         | AGREEABLE                                                                | APHA 22 <sup>ND</sup> ED. 2012 - 2150 B                                |
| 5       | TURBIDITY                  | BDL            | NTU                       | 5.00                                                                     | APHA 22 <sup>ND</sup> ED. 2012 - 2130-B                                |
| 6       | TOTAL DISSOLVED SOLIDS     | 202.00         | mg/l                      | 2000.00                                                                  | APHA 22 <sup>ND</sup> ED. 2012 - 2540-C                                |
| 7       | TOTAL HARDNESS             | 88.00          | mg/l as CaCO <sub>3</sub> | 600.00                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 2340-C                                |
| 8       | CHLORIDES                  | 56.00          | mg/l                      | 1000.00                                                                  | APHA 22 <sup>ND</sup> ED. 2012 - 4500-Cl <sup>-</sup> -B               |
| 9       | SULPHATES                  | BDL            | mg/l                      | 400.00                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 4500-SO <sub>4</sub> <sup>-2</sup> -E |
| 10      | FLOURIDES                  | BDL            | mg/l                      | 1.50                                                                     | APHA 22 <sup>ND</sup> ED. 2012 - 4500-F <sup>-</sup> -D                |
| 11      | PHENOLPHTHALEIN ALKALINITY | BDL            | mg/l as CaCO <sub>3</sub> | NS                                                                       | APHA 22 <sup>ND</sup> ED. 2012 - 2320-B                                |
| 12      | TOTAL ALKALINITY           | 97.00          | mg/l as CaCO <sub>3</sub> | 600.00                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 2320-B                                |
| 13      | ACIDITY                    | 14.00          | mg/l as CaCO <sub>3</sub> | NS                                                                       | APHA 22 <sup>ND</sup> ED. 2012 - 2310-B                                |
| 14      | MPN INDEX/100ML            | < 2            | -                         | < 2                                                                      | APHA 22 <sup>ND</sup> ED. 2012 - 9221-B,C,D                            |
| 15      | COLIFORM ORGANISMS         | ABSENT         | -                         | ABSENT                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 9221-B,C,D                            |

BDL - BELOW DETECTABLE LIMIT, NS - NOT SPECIFIED

TEST REPORT APPROVED BY: F. T. KANPURWALA  
DESIGNATION: ENV. LAB INCHARGE

Disclaimer:

- a) The Results produced above relates to the sample tested only.  
b) Test Report shall not be reproduced except in full, without written permission of the management of the institute.



**Principal**  
**Lakshya International School**  
**Ahmedabad**

**GICEA TEST REPORT**

**C. C. PATEL ENVIRONMENT TESTING LABORATORY**

TEST REPORT ID NO.: 696/PWR/25-26

REPORT DATE: 22/01/2026

- 1) NAME & ADDRESS OF THE CUSTOMER : LAKSHYA INTERNATIONAL SCHOOL, OPP. APPLEWOOD, SHANTIPRA,  
AHMEDABAD
- 2) SAMPLE TYPE & TESTING REQUIRED : CHEMICAL AND MICROBIOLOGICAL TESTING OF 'A' BLOCK R.O. WATER.
- 3) SAMPLE COLLECTED & SUPPLIED BY : CUSTOMER
- 4) DATE OF SAMPLE RECEIVED : 19/01/2026
- 5) DATE OF SAMPLE TESTING : 19/01/2026
- 6) SAMPLE CONDITION ON RECEIPT : SATISFACTORY
- 7) CUSTOMER REFERENCE NO. IF ANY :-


| SR. NO. | PARAMETER ANALYSED         | ANALYSIS VALUE | UNITS                     | PERMISSIBLE LIMIT IN ABSENCE OF ALTERNATE SOURCE AS PER IS - 10500, 2012 | REFERENCE TEST METHOD NO. USED                                         |
|---------|----------------------------|----------------|---------------------------|--------------------------------------------------------------------------|------------------------------------------------------------------------|
| 1       | PH AT 25.0 °C              | 6.72           | -                         | 6.5 - 8.5                                                                | APHA 22 <sup>ND</sup> ED. 2012 - 4500 H <sup>+</sup> B                 |
| 2       | CONDUCTIVITY@ 25°C         | 171.00         | µS/CM                     | NS                                                                       | APHA 22 <sup>ND</sup> ED. 2012 - 2510 B                                |
| 3       | COLOUR                     | BDL            | HAZEN UNITS               | 15.00                                                                    | APHA 22 <sup>ND</sup> ED. 2012 - 2120 B                                |
| 4       | ODOUR                      | AGREEABLE      | -                         | AGREEABLE                                                                | APHA 22 <sup>ND</sup> ED. 2012 - 2150 B                                |
| 5       | TURBIDITY                  | BDL            | NTU                       | 5.00                                                                     | APHA 22 <sup>ND</sup> ED. 2012 - 2130-B                                |
| 6       | TOTAL DISSOLVED SOLIDS     | 116.00         | mg/l                      | 2000.00                                                                  | APHA 22 <sup>ND</sup> ED. 2012 - 2540-C                                |
| 7       | TOTAL HARDNESS             | 52.00          | mg/l as CaCO <sub>3</sub> | 600.00                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 2340-C                                |
| 8       | CHLORIDES                  | 14.00          | mg/l                      | 1000.00                                                                  | APHA 22 <sup>ND</sup> ED. 2012 - 4500-Cl <sup>-</sup> -B               |
| 9       | SULPHATES                  | BDL            | mg/l                      | 400.00                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 4500-SO <sub>4</sub> <sup>-2</sup> -E |
| 10      | FLOURIDES                  | BDL            | mg/l                      | 1.50                                                                     | APHA 22 <sup>ND</sup> ED. 2012 - 4500-F <sup>-</sup> -D                |
| 11      | PHENOLPHTHALEIN ALKALINITY | BDL            | mg/l as CaCO <sub>3</sub> | NS                                                                       | APHA 22 <sup>ND</sup> ED. 2012 - 2320-B                                |
| 12      | TOTAL ALKALINITY           | 85.00          | mg/l as CaCO <sub>3</sub> | 600.00                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 2320-B                                |
| 13      | ACIDITY                    | 20.00          | mg/l as CaCO <sub>3</sub> | NS                                                                       | APHA 22 <sup>ND</sup> ED. 2012 - 2310-B                                |
| 14      | MPN INDEX/100ML            | < 2            | -                         | < 2                                                                      | APHA 22 <sup>ND</sup> ED. 2012 - 9221-B,C,D                            |
| 15      | COLIFORM ORGANISMS         | ABSENT         | -                         | ABSENT                                                                   | APHA 22 <sup>ND</sup> ED. 2012 - 9221-B,C,D                            |

BDL - BELOW DETECTABLE LIMIT, NS - NOT SPECIFIED

TEST REPORT APPROVED BY: F. T. KANPURWALA  
DESIGNATION: ENV. LAB INCHARGE

Disclaimer:

- a) The Results produced above relates to the sample tested only.  
b) Test Report shall not be reproduced except in full, without written permission of the management of the institute.



**Principal**  
**Lakshya International School**  
**Ahmedabad**