

CRUDE DISTILLATION UNIT FLANGE MAINTENANCE SPECIFICATION

Effective Date: 2024-01-15 | Department: Mechanical Maintenance

Section 4.1 Flange Torquing:

Before hot bolting, verify line temperature is below 150 deg C.

For ASTM A193 B7 bolts on Heat Exchanger E-204 nozzle flanges, apply cross-pattern torque in three stages:

Stage 1: 30% (90 Nm)

Stage 2: 60% (180 Nm)

Stage 3: 100% final (300 Nm).

Always replace spiral-wound gaskets with 316L SS inner ring.