

# NATIONAL THERMAL POWER CORPORATION (NTPC)

## TECHNICAL SPECIFICATION SHEET & INQUIRY SCHEDULE

Document Ref: NTPC/MECH/SPEC/2026/088 | Date: 05-Oct-2026

### 1. GENERAL INQUIRY INFORMATION

Client / Buyer: National Thermal Power Corporation  
Project Title: 2x800 MW Supercritical Thermal Expansion Project  
RFQ / Inquiry No: RFQ-NTPC-FGD-2026-904  
Delivery Destination: NTPC Ramagundam Site Store, Telangana

### 2. MECHANICAL EQUIPMENT REQUIREMENTS

| Parameter                 | Specification Value                | Engineering Remarks                                      |
|---------------------------|------------------------------------|----------------------------------------------------------|
| Equipment Type            | Rack & Pinion Damper               | Heavy duty isolation damper for flue gas ducting         |
| Equipment Tag No.         | DMP-FGD-ISOL-01                    | Stainless steel etched nameplate required                |
| Quantity                  | 1 Nos                              | Single set complete with drive unit                      |
| Duct Length (L)           | 1600 mm                            | Flange-to-flange internal clear dimension                |
| Duct Width / Diameter (W) | 1400 mm                            | Duct opening width                                       |
| Casing Depth (D)          | 450 mm                             | Overall housing depth including flange thickness         |
| Body / Housing Material   | IS 2062                            | Structural carbon steel plate casing                     |
| Flap / Blade Material     | SS 304 L                           | Corrosion resistant austenitic stainless steel           |
| Actuation Type            | Pneumatic                          | Double acting pneumatic actuator with 5/2 solenoid valve |
| Design Pressure           | ± 6.5 kPa (Gauge)                  | Continuous operating flue gas static pressure            |
| Design Temperature        | 180 °C continuous, 220 °C peak     | Thermal expansion allowances mandatory                   |
| Service Medium            | Flue Gas with fly ash particulates | Gland seals with graphite rings                          |
| Seat Leakage Class        | Class II as per AMCA 500-D         | Metallic seal strip design                               |

### 3. SPECIAL VENDOR INSTRUCTIONS

Vendor must furnish itemized Bill of Materials with unit weights, raw material grades, and manufacturing fabrication breakdowns. Final quotation must include standard test certificates.