




Fig:1.1




Fig:1.2




Fig 1.3: Helical Winding




Fig 1.4 : Cross over Winding

DESIGN DETAIL TABLE

Sr.no	Parameters	Values
1	To Conservator Breather	-
2	Cold oil Level	826
3	Oil Drane Valve	-
4	Cooling Tubes	15 nos
5	Window width(Ww)	127
6	Window Height (Hw)	320
7	Depth of Francis(Dy)	114
8	Tank of length(LT)	376.5000
9	Tank Width (Wt)	962.7000
10	Height of tank (Ht)	1000
11	LV Inner Dia (ID)	167
12	LV Outer Dia (OD)	192
13	HV Inner Dia (ID)	222
14	HV Outer Dia (ID)	276.5000
15	L V winding	4 Strips of 5.5*2.5
16	Axial Depth of LV winding (Lcs)	319
17	Radial Depth of LV winding (Lcs)	12.5000
18	H V windingDia(with insulation)	1.4500
19	Axial Depth of HV winding (Lcp)	294.2500
20	Radial Depth of HV winding (bp)	294.2500
21	Total no of secondary turns	56
22	Total no of primary turns	2464
23	Dh(clearance of tube from both 163.5000)	163.5000
24	Dv(clearance of tube from both 163.5000)	163.5000
25	Tapping Leads	-
26	Tapping Switch	-

SVPM's Collage of Engineering (BK)

Name:- Darekar Harshavardhan Atmaram

Roll No :- 408/24/EE

Class :- TE Electrical

Date :-

Sign of Staff :-