

Synthetic Compressor Maintenance Report

Equipment ID: COMP-B44

Inspection date: 2026-08-31

Measured discharge pressure: 11.2 bar

Measured oil temperature: 72 C

Main finding: Intake filter loading is above the preferred range.