

Ridgeline Roofing and Inspection

744 N Washington St, Naperville, IL 60563
(630) 555-0601 ridgelineroof.com
Licensed IL Roofing Contractor 104-009812

RESIDENTIAL ROOF INSPECTION REPORT

Property: 1428 Ashbury Ridge Drive, Naperville, IL 60565
Homeowner: Christopher M. Morris
Inspection Date: May 18, 2024
Inspector: Tony Marek, Senior Estimator
Report Number: RR-2024-0518-44

CONDITION SUMMARY

Roof Type	Architectural asphalt shingle
Approximate Age	19 years (original 2005 build)
Overall Condition	Good
Estimated Remaining Life	10 to 12 years
Flashing and Boots	Intact, minor sealant refresh suggested
Gutters	Functional, cleaned during inspection
Leaks or Active Damage	None observed

No repairs required at this time. Recommend re-inspection in 2029 or after any major storm event.
Note: shingles in good shape; homeowner's nearer-term project is the 12 year old furnace, not the roof.