

SOP-DC-4000: Data Center and Control Room Equipment Safety

Document owner: IT Infrastructure Department **Effective date:** 2024-06-15 **Review cycle:** 24 months

Section 1. Purpose and Scope

Governs physical safety and access controls for server rooms, data centers, and control room equipment racks supporting site operations.

Section 2. Access Control

Clause 2.1 — Physical access to a data center or server room is restricted to authorized personnel via badge/biometric control; a visitor or contractor requires escort at all times and is logged in the access register.

Section 3. Fire Suppression Interface

Clause 3.1 — Rooms with clean-agent fire suppression (e.g., FM-200, Novec) shall have the suppression system's pre-discharge alarm and abort-switch procedure posted at each entrance; personnel shall evacuate immediately upon the pre-discharge alarm unless actively aborting a false discharge per posted procedure.

Section 4. Electrical Safety

Clause 4.1 — Rack-mounted equipment work (installation, cabling) on live power distribution units shall follow SOP-ELEC-500 for any exposed energized terminals; hot-swappable component replacement per manufacturer procedure does not require a full energized work permit.

Section 5. Environmental Monitoring

Clause 5.1 — Temperature and humidity are continuously monitored with alarms at thresholds defined by the equipment manufacturer's operating specification; a sustained excursion beyond 30 minutes is escalated to IT Infrastructure Department management.

Section 6. Records

Clause 6.1 — Access logs and environmental monitoring data are filed to the IT Infrastructure File and retained for 2 years.