

SOP-ENV-1400: Environmental Spill Prevention and Response

Document owner: Environmental Compliance Department **Effective date:** 2024-04-15 **Review cycle:** 24 months

Section 1. Purpose and Scope

Governs spill prevention control measures (SPCC) and response procedures for petroleum products and regulated chemicals with potential to reach navigable waters or soil.

Section 2. Secondary Containment

Clause 2.1 — Bulk storage tanks over 660 gallons (petroleum) require secondary containment sized for 110% of the largest tank's capacity, inspected monthly for integrity and accumulated water/product.

Section 3. Spill Classification and Notification

Clause 3.1 — A spill reaching secondary containment only, fully contained, is a Tier 1 event requiring internal documentation but no external notification.

Clause 3.2 — A spill reaching soil, a storm drain, or any water body is a Tier 2 event requiring immediate notification to the Environmental Compliance Department and activation of the spill response team, regardless of volume.

Clause 3.4 — A Tier 2 spill exceeding the regulatory reportable quantity for the specific substance requires notification to the appropriate environmental agency within the regulatory timeframe (typically 24 hours) — the Environmental Compliance Department, not the field responder, makes this determination and files the notification.

Section 4. Response Actions

Clause 4.1 — Stop the source if it can be done safely, then contain before attempting cleanup; absorbent material shall never be applied before the source is stopped or isolated.

Section 5. SPCC Plan Review

Clause 5.1 — The site SPCC Plan is reviewed and re-certified by a professional engineer every 5 years, or immediately following any facility modification that changes storage capacity or containment design.

Section 6. Records

Clause 6.1 — Spill incident reports and SPCC inspections are filed to the Environmental Compliance File and retained for 5 years.