

SOP-HAZMAT-1000: Hazardous Materials Storage and Handling

Document owner: Environmental Health and Safety Department **Effective date:** 2024-02-15 **Review cycle:** 24 months

Section 1. Purpose and Scope

Governs storage, segregation, and handling of hazardous chemicals classified under the facility's GHS (Globally Harmonized System) inventory.

Section 2. Segregation

Clause 2.1 — Incompatible chemical classes (e.g., oxidizers and flammables, acids and bases) shall be stored with physical separation of at least 20 feet or a fire-rated barrier, per the facility's compatibility chart.

Clause 2.2 — Flammable liquid storage in excess of 25 gallons outside an approved flammable storage cabinet or room is prohibited.

Section 3. Container and Labeling

Clause 3.1 — Every container of hazardous material shall bear a GHS-compliant label; an unlabeled or illegibly labeled container shall be quarantined and relabeled before further use.

Clause 3.2 — Secondary containers (decanted from bulk) require at minimum the product name and primary hazard pictogram unless used entirely within the immediate work shift by the person who decanted it.

Section 4. Spill Response

Clause 4.1 — Spill kits appropriate to the stored material class shall be located within 50 feet of any hazardous material storage area.

Clause 4.3 — A spill exceeding 1 gallon, or any spill reaching a floor drain, requires immediate notification to the Environmental Health and Safety Department regardless of whether it was fully contained.

Section 5. SDS Availability

Clause 5.1 — A current Safety Data Sheet (SDS) for every stored chemical shall be accessible at the point of use, either physically or via the facility's electronic SDS system.

Section 6. Records

Clause 6.1 — Chemical inventory and SDS records are filed to the Environmental Health and Safety File and reviewed annually for currency.