GOVERNMENT OF UTTAR PRADESH

DIRECTORATE OF FIRE & EMERGENCY SERVICES

OFFICE OF THE CHIEF FIRE OFFICER, DISTRICT GAUTAM BUDDHA NAGAR

Dispatch No: UP/FS/GBN/2024/NOC-EXP-31048 **Date of Issue: 15-May-2024**

STATUTORY FIRE SAFETY NO OBJECTION CERTIFICATE

STATUS: EXPIRED ON 14-MAY-2025 • DEFICIENT FOR AY 2026-27 (APH REGULATION 3.4)

TO WHOMSOEVER IT MAY CONCERN

1. This is to certify that the educational premises of:

APEX INSTITUTE OF TECHNOLOGY & MANAGEMENT

Plot No. 402/1, Knowledge Park III, Greater Noida, District Gautam Buddha Nagar (U.P.)

AICTE Permanent Institute ID: 1-102938475

2. The academic, administrative, and laboratory blocks (Ground + 4 floors) were inspected by the Divisional Fire Officer on 10-May-2024 as per NBC 2016 Part 4.

3. Fire Fighting Equipment & Emergency Systems Recorded:

- Wet Riser & Down-comer system: Operational during 2024 inspection.
- Yard Hydrants & Hose Reels: Installed across floors.
- Dedicated Static Water Tank: 1,50,000 Litres.
- Terrace Overhead Tank: 25,000 Litres.
- Serviced Fire Extinguishers: 140 units (Last inspected May 2024).

4. MANDATORY STATUTORY EXPIRY NOTICE (CRITICAL):

This certificate was strictly valid for ONE YEAR ONLY from date of issue:

VALIDITY PERIOD: 15-May-2024 to 14-May-2025 (EXPIRED).

THIS NOC HAS LAPSED AND IS NULL & VOID FOR ACADEMIC YEAR 2026-27.

Under AICTE APH Regulation 3.4, approval cannot be granted on a lapsed clearance.

[LAPSED QR]
Scan indicates:
EXPIRED RECORD

DOCUMENT STATUS: LAPSED
CHIEF FIRE OFFICER (RECORDS)
Fire Division, Gautam Buddha Nagar
Expired Date: 14-May-2025 (Overdue)
Digital Seal: UPFS:ARCHIVE:EXP-2024-918