GOVERNMENT OF UTTAR PRADESH

DIRECTORATE OF FIRE & EMERGENCY SERVICES

OFFICE OF THE CHIEF FIRE OFFICER, DISTRICT GAUTAM BUDDHA NAGAR

Dispatch No: UP/FS/GBN/2025/NOC-49210 **Date of Issue: 28-Nov-2025**

STATUTORY FIRE SAFETY NO OBJECTION CERTIFICATE (NOC)

TO WHOMSOEVER IT MAY CONCERN

1. This is to certify that the educational institutional premises of:

APEX INSTITUTE OF TECHNOLOGY & MANAGEMENT

Plot No. 402/1, Knowledge Park III, Greater Noida, District Gautam Buddha Nagar (U.P.)

AICTE Permanent ID: 1-102938475

2. The multi-storey academic, administrative, and laboratory blocks comprising Ground + 4 floors were inspected by the Divisional Fire Officer on 22-Nov-2025 as per the provisions of the National Building Code (NBC 2016 Part 4 - Fire & Life Safety) and UP Fire Prevention Act.

3. Fire Fighting Equipment & Infrastructure Verified On-Site:

- Wet Riser & Down-comer system: Operational with 2500 LPM electric main pump & diesel standby.
- Yard Hydrants & First Aid Hose Reels: Installed across all instructional floors.
- Underground Static Water Tank: 1,50,000 Litres capacity dedicated solely to fire safety.
- Overhead Tank: 25,000 Litres capacity at terrace level.
- Fire Extinguishers (ABC & CO2): 140 units installed and serviced.
- Fire Alarm & Public Address System: Fully operational in all blocks.

4. CONDITIONS OF VALIDITY:

This No Objection Certificate is valid for ONE YEAR from date of issue, expiring on 15-Nov-2026.

The institutional management must apply for annual renewal at least 30 days prior to expiry.

All fire exit passages and emergency staircases must remain clear of any obstructions at all times.

[OFFICIAL QR]
Scan to verify on
upfireservice.gov.in

DIGITALLY SIGNED & SEALED
CHIEF FIRE OFFICER
Fire Services Division, Gautam Buddha Nagar
Digital Token: 2025:UPFS:DSC:89421A
Date: 28-Nov-2025 15:42:10 IST