




MINIMAL-INTERVENTION CONTROL BARRIER FUNCTION (CBF) PROJECTION

Projecting Untrusted Neural Action Proposals onto the Forward-Invariant Safe Set $\mathcal{C}$ at 1000 Hz

🏠 **State Space: Forward Invariance** $\mathcal{C} = \{x \in \mathbb{R}^n : h(x) \geq 0\}$

Nagumo's Theorem: Invariant trajectories satisfy $\dot{h}(x, u) \geq -\alpha(h(x))$ on boundary $\partial\mathcal{C}$.



🏠 **Action Space: Minimal-Intervention Quadratic Program**

Embedded Realization: Closed-form active-set KKT solver on Cortex-M4 in $< 100 \mu\text{s}$.


The Real-Time Safety Filter Formulation:

$$u_t^* = \arg \min_{u \in \mathcal{U}} \frac{1}{2} \|u - p_t\|_H^2$$

Subject to Lie Derivative Safety Invariant:

$$\underbrace{L_f h(x) + L_g h(x)u}_{\dot{h}(x, u)} \geq -\alpha(h(x))$$

Actuator Bounds: $u_{\min} \leq u \leq u_{\max}$ (Zero Heap, $\mathcal{O}(1)$ KKT Active-Set)



Three Inviolable Properties of the Minimal-Intervention CBF Filter:

- 1. Transparency:** If $p_t \in \mathcal{U}_{\text{safe}}$, then $u_t = p_t$ (0% modification).
- 2. Minimality:** If $p_t \notin \mathcal{U}_{\text{safe}}$, u_t is the least-squares projection onto $\partial\mathcal{U}_{\text{safe}}$.
- 3. Forward Invariance:** State $x(t)$ mathematically cannot cross $h(x) = 0$.