

		DRAINAGE & FINAL GRADING CHECKLIST			Contractor logo	
No : Project : Scope of Work :						
Work Permit No : Inspection Date : Location / Position : Drawing Reference No :						
NO	INSPECTION ITEM	INSPECTION RESULT			Remark	
		Acceptance Criteria	Actual Result	Status		
I. Drainage Works Inspection						
	Side Drain (Saluran Longitudinal)	Dimensi, kedalaman, slope sesuai drawing				
	Cross Drain / Gorong-gorong	Posisi, invert level, headwall				
	Longitudinal Slope	≥ 0.5% - 1% (no ponding)				
	Camber / Cross Slope	2% - 2.5%				
	Drainage Outfall	Tersambung ke saluran utama / badan air				
	Erosion Protection	Sesuai spesifikasi				
II. Final Grading & Surface Works						
	Final Elevation	± 50 mm dari desain				
	Final Surface Grading	Rata, halus, tidak ada genangan / tonjolan				
	Proof Rolling Test	Tidak ada defleksi berlebihan				
	Surface Condition	Bersih, tidak ada material lepas				
	Overall Drainage Performance	Air mengalir lancar, tidak ada genangan				
III. Others						
Notes :						
PT. Lombok Torok Developments				Contractor		
ANDI CAHYA MULIA				ANTONIO CR		
Site Manager				QC Site Inspector		
PC/Infra/IF-004						