B post 5s

Saved dynamic state, t = 6.15 s | Droop: tau_p=1.00 s, mp=5% | Bus6 = 1 pu ∠0°



P: blue arrows Q: green arrows Line labels (a / b): signed power from each bus into the line [pu].

Two positive terminal Q values mean reactive absorption along the line. Device P/Q: positive injection into the network.

GFM 2.824 + grid -0.327 = load 2.244 + fault 0.000 + line losses 0.253 pu