

EISBÄR DEHUMIDIFIER DAS-E8K.2				8HR PREVENTIVE MAINTENANCE	
Asset Activity:	eisbÄr Dehumidifier DAS-E8K.2 8hr PM		Work Order #:	WO-AUDIT	
Machine ID:	DEHUMIDIFIER-L3		Actual Start Date:	_____	
Interval:	8 Operating Hours		Actual End Date:	_____	
Team Member(s):	Audit Test		Machine Hours:	_____	
Generated:	07 May 2026 19:00 UTC		Comments:	_____	

RUNNING TASKS					
TASK #	AREA	ACTION	DESCRIPTION	INITIAL	DONE ■
10	SAFETY	CONFIRM	CONFIRM DEHUMIDIFIER IS RUNNING IN AUTOMATIC MODE â€” VERIFY FAN OVERRUN FUNCTION IS ACTIVE â€” NEVER SWITCH OFF USING MAIN SWITCH WHILE UNIT IS HOT		■
20	INSPECT	CHECK	READ AND RECORD INLET DEW POINT TEMPERATURE FROM DISPLAY PANEL â€” VERIFY READING IS WITHIN ACCEPTABLE OPERATIONAL RANGE â€” LOG VALUE IN SHIFT RECORD		■
30	INSPECT	CHECK	READ AND RECORD OUTLET DEW POINT TEMPERATURE FROM DISPLAY PANEL â€” VERIFY DRYING PERFORMANCE IS ADEQUATE â€” COMPARE TO PREVIOUS READINGS â€” ALERT MAINTENANCE IF DRYING PERFORMANCE HAS DROPPED		■
40	INSPECT	CHECK	READ AND RECORD PROCESS AIR TEMPERATURE FROM DISPLAY PANEL â€” VERIFY TEMPERATURE IS WITHIN OPERATIONAL PARAMETERS â€” REPORT ANY READING OUTSIDE NORMAL RANGE		■
50	INSPECT	CHECK	CHECK FILTER STATUS INDICATOR ON DISPLAY PANEL â€” VERIFY NO FILTER CHANGE ALARM IS ACTIVE â€” IF FILTER ALARM IS ACTIVE SCHEDULE FILTER CHANGE IMMEDIATELY â€” DO NOT RUN WITH DIRTY FILTERS (VOIDS WARRANTY)		■
60	GENERAL	CONFIRM	LOG ALL DISPLAY READINGS IN SHIFT MAINTENANCE LOG â€” RECORD TIME OF CHECK, TECHNICIAN NAME AND ALL FOUR VALUES â€” REPORT ANY ALARMS OR DEVIATIONS TO MAINTENANCE SUPERVISOR		■

Technician Name:	_____	Supervisor Approval:	_____	Date:	_____
------------------	-------	----------------------	-------	-------	-------

**** END OF REPORT ****

GENERAL — PRIOR TO RETURNING TO SERVICE FOLLOW ALL GMP PROCEDURES

■ Remove all LOTO (Lockout/Tagout) devices before returning to service

■ Re-check all E-STOP (Emergency Stop) and control switches

■ This document must be signed and retained as a maintenance record

Document hash: (see system) | Generated: 2026-05-07 19:00 UTC | System: PM Automation v1.0