Fire extinguisher maintenance schedule

FleetOptima
fleetoptima.org

For portable, wall-mounted extinguishers. The monthly check is quick and anybody can do it. The yearly service and the longer dates are for a licensed service company.

Based on NFPA 10 and OSHA 1910.157, which most fire codes point to. Your extinguisher's label and your local fire marshal come first.

Monthly (you can do this)

TASK	HOW OFTEN	NOTES	✓
In its spot, visible, nothing blocking it	Monthly		
Pin and tamper seal intact	Monthly		
Gauge in the green	Monthly		
Still full	Monthly	Lift it; it should feel heavy	
No damage, rust, leaks or clogged nozzle	Monthly		
Instructions readable	Monthly		
Initial and date the tag or log	Monthly	Keep the record	

Yearly

TASK	HOW OFTEN	NOTES	✓
Annual maintenance by a service company	Yearly	Or sooner if a monthly check finds a problem	

Longer dates (service company)

TASK	HOW OFTEN	NOTES	✓
Internal exam of dry chemical units	Every 6 years	Stored-pressure units with a 12-year hydro test	
Hydrostatic test: water, foam, CO2, wet chemical	Every 5 years	Also stainless dry chemical	
Hydrostatic test: most dry chemical (ABC)	Every 12 years	Steel, brass or aluminum shells	
Disposable units: replace	12 years after the date on the shell	They can't be refilled	

Required by code? Monthly inspections and yearly maintenance are required by NFPA 10 where it's adopted, and by OSHA 1910.157 for extinguishers provided for employees, which also requires keeping the yearly service record. Extinguishers exposed to weather, vehicles or tampering may need checking more often than monthly. Code items apply where your city, state or insurer has adopted them. Requirements vary by jurisdiction, so check local code.

Service log: fire extinguisher

Machine / unit: _____ Make & model: _____

FleetOptima
fleetoptima.org

DATE	MONTH	WORK DONE	PARTS USED	INITIALS

Free printable from fleetoptima.org/maintenance-schedules