HVAC unit maintenance schedule

FleetOptima
fleetoptima.org

For rooftop (packaged) units and split systems in a shop or small commercial building. Filters are the monthly job; everything else is a spring check before cooling season and a fall check before heating season.

Typical intervals from manufacturer manuals and published service schedules. Your machine's manual comes first.

Monthly

TASK	HOW OFTEN	NOTES	✓
Check air filters, replace when dirty	Monthly	Most get replaced every 1 to 3 months; dusty sites more often	
Condensate drain pan and line clear	Monthly in cooling season	Clogged drains are the classic water-on-the-floor call	

Quarterly

TASK	HOW OFTEN	NOTES	✓
Blower belt tension and wear	Quarterly	Belt-drive units only	
Clear debris from around the outdoor coil	Quarterly	Leaves, cottonwood, trash	

Spring (cooling check)

TASK	HOW OFTEN	NOTES	✓
Clean the outdoor (condenser) coil	Yearly	Microchannel coils: no detergent, low pressure	
Clean the indoor (evaporator) coil	Yearly		
Check refrigerant charge	Yearly	Technician	
Tighten electrical connections, check motor amps	Yearly		
Check thermostat and controls	Yearly		

Fall (heating check)

TASK	HOW OFTEN	NOTES	✓
Gas connections, gas pressure, burner combustion	Yearly	Gas heat only; technician	
Inspect the heat exchanger	Yearly	Cracks can leak carbon monoxide	
Clean and adjust the blower, lubricate moving parts	Yearly	Where the unit has lube points	

Service log: hvac unit

Machine / unit: _____ Make & model: _____

FleetOptima
fleetoptima.org

DATE	DATE / SEASON	WORK DONE	PARTS USED	INITIALS