Dust collector maintenance schedule

FleetOptima
fleetoptima.org

For cartridge and baghouse dust collectors. The pressure gauge is the whole story: log it daily, and a steady climb tells you the filters are loading up or the pulse cleaning has quit.

Typical intervals from manufacturer manuals and published service schedules. Your machine's manual comes first.

Daily

TASK	HOW OFTEN	NOTES	✓
Read and log the pressure drop	Daily	Watch the trend, not just the number	
Pulse cleaning works	Daily	Valves fire, timer set, air pressure right, no air line leaks	
Drain water from the pulse air supply	Daily	Wet or oily air cakes dust on the filters	
Check the dust bin or drum, empty it	Daily	Drums: empty by 2/3 full	
Look for dust at the exhaust	Daily	Dust coming out means a filter problem	

Weekly

TASK	HOW OFTEN	NOTES	✓
Hopper empties; seals, bolts and leaks	Weekly		
Fan: vibration, belts, amp draw, buildup	Weekly		
Filters seated, no tears or damage	Weekly		

By the gauge and yearly

TASK	HOW OFTEN	NOTES	✓
Replace filters	When pressure stays high after cleaning	Often 3 to 6 months in heavy dust, about yearly in light duty	
Compressed-air filters on the pulse system	Per your manual		
Full filter and module inspection	Yearly	Abrasion, tears, heavy buildup	
Drum lid clamps and gaskets	Yearly		
Explosion vents and isolation dampers	Yearly at least	Unblocked, undamaged; replace damaged parts right away	
Dust hazard analysis (DHA) current	Review at least every 5 years	And after any change to materials or process	

Required by code? NFPA 660 (2025 edition) pulls NFPA 652, 654, 664 and the other combustible dust standards into one document. Facilities handling combustible dust need a dust hazard analysis (DHA), revalidated at least every 5 years and after process changes, and housekeeping is reviewed as part of it. If your collector has explosion vents, isolation valves or suppression, those carry inspection requirements of their own. Code items apply where your city, state or insurer has adopted them. Requirements vary by jurisdiction, so check local code.

Service log: dust collector

Machine / unit: _____ Make & model: _____

FleetOptima
fleetoptima.org

DATE	PRESSURE DROP	WORK DONE	PARTS USED	INITIALS

Free printable from fleetoptima.org/maintenance-schedules