

FusionSolar Troubleshooting Report

Date: 25-05-2026
Generated At: 26-05-2026 08:59:54
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	138
Total low-performing inverters	141
Total low-performing strings	63
Total alarms	76
Total high-temperature inverters	71
Unsuccessful task sections	0

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
BIMB BDR PENAWAR - 1ST FLOOR	2.97	2.96	0.17
BIMB BDR PENAWAR - G FLOOR	2.96	2.96	-0.17
KOMPLEX PKNS BANGI	2.21	2.21	0.00
JIANN LIH SAFETY PRODUCT	2.68	2.68	0.00
BP PLASTICS BP9	1.69	1.69	0.15
BP PLASTICS HQ	1.54	1.69	-8.74
CK PACKAGING AND PLASTIC INDUSTRIES	1.90	1.69	12.59
SINCERELY DYEING	1.62	1.69	-4.00
C0176_GETHA	0.00	0.00	-
C0172_ATRIA NORTH	2.16	2.37	-8.73

Plant Name	Plant PSH	City Average PSH	Deviation
C0172_ATRIA SOUTH	2.18	2.37	-7.89
RESTORAN CHIMAEK (KFRY)	2.76	2.37	16.62
PROGUARD SAFETY MANUFACTURING SDN BHD	2.40	2.40	0.00
GLASS PLASTIC PACKAGING	4.07	4.55	-10.55
PLEASURE LATEX	2.94	1.47	100.00
PLEASURE LATEX PHASE 2	0.00	1.47	-100.00
LKW FROZEN SDN BHD	2.80	3.22	-13.07
AMT PC DISTRIBUTORS SDN. BHD.	2.33	2.08	12.17
ASHITA COMMUNICATION	0.00	2.08	-100.00
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	2.63	2.08	26.62
ADVANCE VI TECH LOT 1629	2.71	2.08	30.47
BUNCHO (M) SDN BHD	2.88	2.08	38.65
HOON YUEN FURNITURE	2.58	2.08	24.21
KCCCI 2FLOOR	2.09	2.08	0.62
KCCCI FIRST FLOOR	2.01	2.08	-3.23
KCCCI GROUND FLOOR	1.94	2.08	-6.60
KOSSAN PAINT SDN BHD	2.30	2.08	10.73
KAMMA KLANG ENTERPRISE	2.36	2.08	13.62
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	1.42	2.08	-31.64
LIAN TECK SENG LOT 11	0.00	2.08	-100.00
MAJOR ENGINEERING LOT 10	1.85	2.08	-10.94
MAJOR ENGINEERING LOT 8	0.96	2.08	-53.78
MEWAH OILS SDN BHD	1.81	2.08	-12.86
MIAW FRESH	0.11	2.08	-94.70
MAXTWO ENGINEERING (FACTORY)	2.67	2.08	28.54

Plant Name	Plant PSH	City Average PSH	Deviation
PKT THE SHIP	2.22	2.08	6.88
ROYAL KLANG CLUB	2.15	2.08	3.51
RS POLY INDUSTRY	2.83	2.08	36.24
SIME KANSAI PAINT SDN BHD	1.83	2.08	-11.90
SJK (C) WU TECK	2.50	2.08	20.36
SJK ■ C ■ PIN HWA 1	2.06	2.08	-0.83
SM CHUNG CHUNG HUA (PSDN) KLANG	2.24	2.08	7.84
SP LOGISTICS SDN BHD	2.38	2.08	14.58
TOMEI	2.46	2.08	18.43
TEMBIKAR WEI KHING	2.81	2.08	35.28
TONG SEH	2.48	2.08	19.39
UC BLASTING PAINTING	2.70	2.08	29.99
VINDA PHASE 4 (MSB 3-2)	2.47	2.08	18.91
VISKO INDUSTRIES SDN BHD	2.86	2.08	37.69
VINDA PHASE 1 AND 2 (MSB 2)	2.08	2.08	0.14
VINDA PHASE 3 (MSB 3-1)	2.15	2.08	3.51
KWANG HUA PERSENDIRIAN METER 1	1.83	2.08	-11.90
APEX UNIPARTS	2.24	2.44	-8.07
KLUANG COFFEE POWDER	2.38	2.44	-2.33
SAWIPAC SDN BHD	2.69	2.44	10.40
SWEE CHEONG WATCH SDN BHD (METER 2)	4.13	4.87	-15.20
SUCCESS ELECTRONIC LOT 3	1.83	1.94	-5.67
SUCCESS ELECTRONIC LOT 7	2.05	1.94	5.67
QL AGROFOOD SDN BHD	2.92	2.92	0.00
KIARA BAY	2.61	2.69	-2.85

Plant Name	Plant PSH	City Average PSH	Deviation
MENARA PJD	2.56	2.69	-4.71
TOA PAINT KEPONG WAREHOUSE	2.89	2.69	7.57
QL ENDAU MARINE	0.00	1.75	-100.00
REDANG LAGOON RESORT	0.00	2.65	-100.00
ECO OILS - LAHAD DATU	2.68	2.68	0.00
LIAN FOO POULTRY FARM SDN BHD	0.00	0.00	-
WEIDA MARKETING SDN. BHD.	2.16	2.65	-18.49
QL AGROVENTURE	2.31	2.31	0.00
ECOOILS (PHASE 2) - P.GUDANG	1.52	1.38	10.55
IOI PAN - CENTURY	1.98	1.38	44.00
KISWIRE CORD PHASE 1 (DATA)	0.00	1.38	-100.00
KISWIRE CORD SDN BHD	2.00	1.38	45.45
LEAN GIAP ENTERPRISE SDN BHD	3.74	4.20	-10.88
PKT 12 WAVES	3.68	4.20	-12.31
PENGERANG INDEPENDENT TERMINAL	2.87	2.87	0.00
GEMILITE SDN BERHAD	1.98	1.30	52.31
MENARA PKNS PJ	0.00	1.30	-100.00
SUCCESS ELECTRONIC LOT 5	1.92	1.30	47.69
FUNGICULTURE	2.53	2.21	14.22
JY1(PHASE 1)	2.83	2.21	27.77
JY1(PHASE 2)	2.75	2.21	24.15
JY2	2.81	2.21	26.86
JAYA NETS	2.37	2.21	7.00
SJK (C) TSHING NIAN	0.00	2.21	-100.00
AMEBA MGMT	2.81	2.57	9.41

Plant Name	Plant PSH	City Average PSH	Deviation
IOI MALL PUCHONG (NEW WING)	2.50	2.57	-2.66
IOI MALL PUCHONG (NEW WING) PHASE 2	2.34	2.57	-8.89
IOI MALL PUCHONG (OLD WING)	2.25	2.57	-12.39
MCC TECHNIQUE SDN BHD LOT 10	2.81	2.57	9.41
MCC TECHNIQUE SDN BHD LOT 12	2.70	2.57	5.13
BREMFIELD SDN BHD	1.77	1.69	4.53
C0149_VERTEX MISSION	1.74	1.69	2.76
C150_VERTEX MISSION	1.57	1.69	-7.28
FUJI M1	2.27	2.32	-2.26
FUJI M2	2.41	2.32	3.77
FUJI M3	1.83	2.32	-21.21
FUJI M4	2.78	2.32	19.70
MARINE GOLD SDN BHD	0.00	2.62	-100.00
WCS UNIT 6	2.73	2.62	4.33
WCS UNIT 7	2.80	2.62	7.01
BM COCO MARKETING	2.31	2.46	-5.97
BM COCO PALM	2.17	2.46	-11.67
CHONG HWA SBR RENGIT	2.89	2.46	17.64
P.A FOOD SDN BHD 2ATKT	3.07	3.62	-15.08
P.A. FOOD WAREHOUSE NO. 9	3.21	3.62	-11.20
LYBASE SDN BHD	2.22	2.17	2.54
SUPERMICRO COMPUTER SDN BHD	2.11	2.17	-2.54
ENGE PLAS	2.66	2.66	0.00
CIC CONTRACT SDN BHD	2.80	2.80	0.00
BJC FOOD (MALAYSIA) SDN. BHD.	1.63	1.93	-15.51

Plant Name	Plant PSH	City Average PSH	Deviation
KUASA BAKTI (PETRON SETIA ALAM)	2.15	1.93	11.44
KOSSAN RUBBER INDUSTRIES BERHAD	0.00	1.93	-100.00
MARBACH ASIA PACIFIC LOT17	2.18	1.93	12.99
MARBACH ASIA PACIFIC LOT 15	2.40	1.93	24.40
MITSUI COPPER FOIL P3	2.62	1.93	35.80
NEW AGE 160	2.23	1.93	15.58
NEW AGE 510	2.35	1.93	21.80
PKT 8 WAVES	0.00	1.93	-100.00
QL MAXINCOME	2.16	1.93	11.96
QL LOT 14	2.12	1.93	9.88
QL LOT 16	2.19	1.93	13.51
SAN SOON SENG FOOD INDUSTRIES SDN BHD	2.65	1.93	37.35
SUCCESFUEL SDN. BHD.	2.08	1.93	7.81
THOR SPECIALTIES	2.18	1.93	12.99
PERBADANAN PENGURUSAN VILLA RAINTREE II	4.35	4.87	-10.68
JEBSEN AND JESSEN MALAYSIA SDN BHD (MHE)	1.78	1.78	0.00
ATS AIR SOLUTION	2.50	1.25	100.00
BOILERMECH LOT 873	0.00	1.25	-100.00
QL FARM SDN BHD	0.00	1.30	-100.00
QL TAWAU FEEDMILL	2.65	1.30	103.53
SABAH CHINESE HIGH SCHOOL (CANTEEN)	1.41	1.30	8.29
SABAH CHINESE HIGH SCHOOL (CULTURE AND EDUCATION)	0.00	1.30	-100.00
SABAH CHINESE HIGH SCHOOL (TAK YUEN BUILDING)	2.45	1.30	88.17
CHAN KAH WHYE	2.64	2.34	12.98
DSG MALAYSIA SDN. BHD	1.94	2.34	-16.98

Plant Name	Plant PSH	City Average PSH	Deviation
LAM SOON EDIBLE OILS	2.43	2.34	3.99
LAU AND TAN PHARMACY (G.FLOOR)	3.07	3.62	-15.31
WASCO PIPE SDN BHD (COATING)	1.97	2.56	-23.05

Low-performing Inverters

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
KOMPLEX PKNS BANGI	100KTL-M1(COM1-12)	6T22C9018812	3.162	3.696	14.45
KOMPLEX PKNS BANGI	50KTL-M3(COM1-14)	6T22A9024868	3.004	3.696	18.72
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	0.304	3.696	91.77
BP PLASTICS BP9	INVERTER 2 (AREA C)	BN24A1084697	1.593	1.876	15.09
BP PLASTICS BP9	INVERTER 3 (AREA C)	BN24A1081068	1.606	1.876	14.39
BP PLASTICS BP9	INVERTER 4 (AREA C)	BN24A1083681	1.651	1.876	11.99
BP PLASTICS BP9	INVERTER 7 (AREA A)	BN24A1093033	1.669	1.876	11.03
BP PLASTICS BP9	INVERTER 1 (AREA C)	BN24A1093051	1.549	1.876	17.43
BP PLASTICS BP9	INVERTER 1 (AREA A)	BN24A1093025	1.522	1.876	18.87
BP PLASTICS BP9	INVERTER 2 (AREA A)	BN24A1093027	1.521	1.876	18.92
BP PLASTICS BP9	INVERTER 4 (AREA A)	BN24A1093036	1.532	1.876	18.34
BP PLASTICS BP9	INVERTER 5 (AREA A)	BN24A1092953	1.499	1.876	20.10
BP PLASTICS BP9	INVERTER 3 (AREA A)	BN24A1093038	1.458	1.876	22.28
BP PLASTICS BP9	INVERTER 2 (AREA B)	BN24A1084693	1.688	1.876	10.02
BP PLASTICS BP9	INVERTER 6 (AREA A)	BN24A1093023	1.175	1.876	37.37
BP PLASTICS BP9	INVERTER 9 (AREA A)	ES24A0149486	1.497	1.876	20.20
BP PLASTICS BP9	INVERTER 5 (AREA C)	6T24A9018015	1.615	1.876	13.91
BP PLASTICS HQ	INVERTER_9	ES2460041537	1.698	2.075	18.17
BP PLASTICS HQ	INVERTER_4	ES2460076787	1.581	2.075	23.81

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
BP PLASTICS HQ	INVERTER_10	ES2460041538	1.514	2.075	27.04
BP PLASTICS HQ	INVERTER_5	ES2460076788	1.506	2.075	27.42
BP PLASTICS HQ	INVERTER_1	6T2479016090	1.460	2.075	29.64
BP PLASTICS HQ	INVERTER_7	6T2479016026	0.984	2.075	52.58
BP PLASTICS HQ	INVERTER_2	ES2440060550	1.567	2.075	24.48
BP PLASTICS HQ	INVERTER_3	6T2489015626	1.437	2.075	30.75
SINCERELY DYEING	TERA INV 8	ES25A0082804	0.566	0.786	27.99
SINCERELY DYEING	TERA INV 5	ES24A0054424	0.063	0.786	91.98
C0172_ATRIA SOUTH	INVERTER 4(COM2-1)	HV22A0105615	0.019	0.022	13.64
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	INVERTER(COM3-1)	6T24B9008138	1.563	2.292	31.81
ADVANCE VI TECH LOT 1629	INVERTER 3 - TERA	6T24B9059721	2.300	2.880	20.14
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	BLOCK B2-INVERTER 6 - METER 6	6T21C9025214	1.544	1.995	22.61
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	BLOCK C - INVERTER 7 - METER 2	6T21C9024903	1.241	1.995	37.79
ROYAL KLANG CLUB	INVERTER 2	6T2519013816	1.946	2.362	17.61
SP LOGISTICS SDN BHD	INV-6T23B9005457	6T23B9005457	2.265	2.696	15.99
TOMEI	INV-(4)	NS2461304513	2.416	2.802	13.78
TOMEI	INV-(10-2)	NS2461304314	2.308	2.802	17.63
TOMEI	INV-(6-3)	NS2461304514	2.276	2.802	18.77
TOMEI	INV-(16-2)	TA2470059985	2.203	2.802	21.38
TOMEI	INV-(10-3)	TA2470060794	2.036	2.802	27.34
TOMEI	INV-(8-3)	HV2330348451	1.978	2.802	29.41
TOMEI	INV-(4-3)	HV2330348461	1.977	2.802	29.44
TONG SEH	INVERTER 2	6T2279009207	2.344	2.614	10.33

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
SAWIPAC SDN BHD	INV-6T2519015310	6T2519015310	2.403	3.566	32.61
SUCCESS ELECTRONIC LOT 3	TERA INVERTER 2	6T2519005164	1.506	1.956	23.01
SUCCESS ELECTRONIC LOT 7	TERA INVERTER 5	ES24B0023406	2.050	2.409	14.90
SUCCESS ELECTRONIC LOT 7	TERA INVERTER 8	ES24B0023689	2.018	2.409	16.23
SUCCESS ELECTRONIC LOT 7	TERA INVERTER 7	ES24B0023682	2.046	2.409	15.07
QL AGROFOOD SDN BHD	INVERTER(COM3-16)	ES24A0186554	2.606	3.449	24.44
QL AGROFOOD SDN BHD	INVERTER(COM3-14)	ES24A0149520	2.610	3.449	24.33
QL AGROFOOD SDN BHD	INVERTER(COM3-15)	NS2481027923	1.994	3.449	42.19
KIARA BAY	INVERTER 5 - TERA	6T22B9036273	2.949	3.594	17.95
KIARA BAY	INVERTER 7 - TERA	ES2470045863	2.524	3.594	29.77
KIARA BAY	INVERTER 8 - TERA	ES2470045868	2.395	3.594	33.36
KIARA BAY	INVERTER 10 - TERA	6T22B9036236	2.243	3.594	37.59
KIARA BAY	INVERTER 11 - TERA	6T22B9036233	2.238	3.594	37.73
KIARA BAY	INVERTER 3 - TERA	6T2449022934	2.824	3.594	21.42
KIARA BAY	INVERTER 4 - TERA	6T2449023252	2.722	3.594	24.26
KIARA BAY	INVERTER 6 - TERA	ES2350101155	2.033	3.594	43.43
KIARA BAY	INVERTER 9 - TERA	ES2350101147	2.001	3.594	44.32
ECO OILS - LAHAD DATU	INVERTER 2 - TERA	6T2449021233	2.270	2.852	20.41
WEIDA MARKETING SDN. BHD.	100KTL-M1(COM2-2)	ES2190053085	2.058	2.299	10.48
QL AGROVENTURE	6T21A9013577	6T21A9013577	1.671	2.592	35.53
ECOOILS (PHASE 2) - P.GUDANG	INV-2(LAB)	TA2470005967	1.354	1.810	25.19
KISWIRE CORD SDN BHD	INVERTER_7F	6T2459004828	2.216	2.473	10.39
KISWIRE CORD SDN BHD	INVERTER_1G	6T2459004846	2.219	2.473	10.27
KISWIRE CORD SDN BHD	INVERTER_4G	6T2459006693	2.210	2.473	10.63
KISWIRE CORD SDN BHD	INVERTER_2D R1	6T24A9011027	2.180	2.473	11.85

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
KISWIRE CORD SDN BHD	INVERTER_3G	6T2459004842	2.127	2.473	13.99
KISWIRE CORD SDN BHD	INVERTER_2G	6T2449050035	2.125	2.473	14.07
KISWIRE CORD SDN BHD	INVERTER_1D	6T2449044103	2.130	2.473	13.87
KISWIRE CORD SDN BHD	INVERTER_1C	6T2459006705	1.980	2.473	19.94
KISWIRE CORD SDN BHD	VASOLAR_INV_5	6T2279009089	2.001	2.473	19.09
KISWIRE CORD SDN BHD	VASOLAR_INV_4	ES22C0017683	2.000	2.473	19.13
KISWIRE CORD SDN BHD	VASOLAR_INV_2	6T22B9063383	1.894	2.473	23.41
KISWIRE CORD SDN BHD	VASOLAR_INV_3	6T2279009192	1.984	2.473	19.77
KISWIRE CORD SDN BHD	VASOLAR_INV_6	ES22C0017677	2.000	2.473	19.13
KISWIRE CORD SDN BHD	VASOLAR_INV_7	6T22B9049892	1.968	2.473	20.42
KISWIRE CORD SDN BHD	INVERTER_4C	6T2459004863	1.913	2.473	22.64
KISWIRE CORD SDN BHD	INVERTER_3F	6T2459004868	2.136	2.473	13.63
KISWIRE CORD SDN BHD	INVERTER_3D	6T2459004858	2.118	2.473	14.36
KISWIRE CORD SDN BHD	INVERTER_3C	6T2459006697	1.885	2.473	23.78
KISWIRE CORD SDN BHD	INVERTER_2C	6T2459006681	1.878	2.473	24.06
KISWIRE CORD SDN BHD	VASOLAR_INV_1	6T22B9063335	1.972	2.473	20.26
KISWIRE CORD SDN BHD	INVERTER_9C	6T2459004757	1.829	2.473	26.04
KISWIRE CORD SDN BHD	INVERTER_8F	6T2459006692	1.913	2.473	22.64
KISWIRE CORD SDN BHD	INVERTER_2F	6T2459004874	2.004	2.473	18.96
KISWIRE CORD SDN BHD	INVERTER_11C	6T2459004845	1.779	2.473	28.06
KISWIRE CORD SDN BHD	VASOLAR_INV_9	6T2279011551	1.768	2.473	28.51
KISWIRE CORD SDN BHD	VASOLAR_INV_8	6T22B9049899	1.783	2.473	27.90
KISWIRE CORD SDN BHD	INVERTER_5C	6T2459004861	1.753	2.473	29.11
KISWIRE CORD SDN BHD	INVERTER_8C	6T2459004811	1.622	2.473	34.41
KISWIRE CORD SDN BHD	INVERTER_6C	6T2459004829	1.629	2.473	34.13

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
KISWIRE CORD SDN BHD	INVERTER_10C	6T2449050062	1.725	2.473	30.25
KISWIRE CORD SDN BHD	INVERTER_1F	6T2459004864	1.789	2.473	27.66
KISWIRE CORD SDN BHD	INVERTER_7C	6T2449031996	1.561	2.473	36.88
KISWIRE CORD SDN BHD	VASOLAR_INV_10	6T2269040723	1.969	2.473	20.38
KISWIRE CORD SDN BHD	VASOLAR_INV_11	6T21A9008894	1.924	2.473	22.20
KISWIRE CORD SDN BHD	VASOLAR_INV_12	HV22A0243263	1.847	2.473	25.31
PKT 12 WAVES	INVERTER 10	6T2449041556	3.694	4.565	19.08
PKT 12 WAVES	INVERTER 3	6T2449041406	3.671	4.565	19.58
PKT 12 WAVES	INVERTER 4	ES2470045168	3.663	4.565	19.76
PKT 12 WAVES	INVERTER 2	6T2459004831	3.663	4.565	19.76
PKT 12 WAVES	INVERTER 1	6T2459004867	3.654	4.565	19.96
PKT 12 WAVES	INVERTER 6	ES2470045204	3.648	4.565	20.09
PKT 12 WAVES	INVERTER 8	6T2459004809	3.631	4.565	20.46
PKT 12 WAVES	INVERTER 9	6T2449032075	3.628	4.565	20.53
PKT 12 WAVES	INVERTER 7	6T2449033633	3.625	4.565	20.59
PKT 12 WAVES	INVERTER 5	6T2459004824	3.620	4.565	20.70
PENGERANG INDEPENDENT TERMINAL	VASOLAR INV 1 ADMIN	6T2379018333	3.249	3.621	10.27
PENGERANG INDEPENDENT TERMINAL	VASOLAR INV9 LCS304	ES2410011693	3.114	3.621	14.00
SUCCESS ELECTRONIC LOT 5	TERA INVERTER 3	ES2540045172	1.711	2.119	19.25
FUNGICULTURE	INVERTER 1 (M4)	ES22B0007042	2.280	2.699	15.52
JY2	100KTL-M1(COM1-12)	6T21A9037851	2.682	3.301	18.75
JY2	100KTL-M1(COM2-12)	6T21A9013444	2.565	3.301	22.30
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 12	GR2569071077	2.258	2.609	13.45
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 1	GR2569094290	2.347	2.609	10.04

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 2	GR2569071128	1.045	2.609	59.95
IOI MALL PUCHONG (OLD WING)	INVERTER 4 - TERA	6T2479017517	2.237	2.643	15.36
IOI MALL PUCHONG (OLD WING)	INVERTER 18 - TERA	6T2489022315	2.003	2.643	24.21
BREMFIELD SDN BHD	INV 4	HV22B0435140	1.663	1.867	10.93
FUJI M1	VASOLAR INV2	6T2279008973	2.132	2.400	11.17
SUPERMICRO COMPUTER SDN BHD	INVERTER(COM1-20)	6T24B9020443	1.963	2.220	11.58
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	1.486	1.737	14.45
NEW AGE 160	INVERTER 3-36KTL M3	6T2489036764	1.621	2.641	38.62
PKT 8 WAVES	INVERTER_2	6T2439012020	0.000	0.004	100.00
QL MAXINCOME	INVERTER 2	6T2489021016	2.037	2.265	10.07
THOR SPECIALTIES	INV-ES2580092068	ES2580092068	1.442	3.164	54.42
QL TAWAU FEEDMILL	INVERTER 4	ES2480078358	2.255	2.578	12.53
QL TAWAU FEEDMILL	INVERTER 3	ES2480078359	2.081	2.578	19.28
SABAH CHINESE HIGH SCHOOL (TAK YUEN BUILDING)	20KTL-M5(COM1-1)	NS2311057237	2.047	2.650	22.75
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	6T21A9013292	1.798	2.192	17.97
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	6T21A9013349	1.788	2.192	18.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	6T2199029888	1.784	2.192	18.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	6T2199029909	1.782	2.192	18.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	6T21A9013305	1.782	2.192	18.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	6T2199029932	1.778	2.192	18.89
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	6T21A9013323	1.775	2.192	19.02
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	6T21A9013390	1.773	2.192	19.11
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	6T2199029874	1.769	2.192	19.30
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	6T21A9013339	1.766	2.192	19.43

Plant Name	Inverter Name	Inverter SN	Inverter PSH	Benchmark PSH	Deviation
LAM SOON EDIBLE OILS	INV-1	6T24A9018029	2.206	2.656	16.94

Low-performing Strings

Plant Name	Inverter Name	Inverter SN	String Name	Total Current	Benchmark	Deviation
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-1)	6T24B9008138	PV20 input current(A)	459.460	583.440	21.25
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV7 input current(A)	336.510	524.900	35.89
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV9 input current(A)	383.350	524.900	26.97
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV11 input current(A)	329.990	524.900	37.13
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV13 input current(A)	342.800	524.900	34.69
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV15 input current(A)	370.990	524.900	29.32
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV17 input current(A)	248.220	524.900	52.71
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	6T21A9037832	PV19 input current(A)	294.660	524.900	43.86
BP PLASTICS BP9	INVERTER 3 (AREA C)	BN24A1081068	PV10 input current(A)	289.080	368.050	21.46
BP PLASTICS BP9	INVERTER 8 (AREA A)	BN24A1093030	PV19 input current(A)	166.910	228.770	27.04
BP PLASTICS BP9	INVERTER 8 (AREA A)	BN24A1093030	PV18 input current(A)	168.320	228.770	26.42
BP PLASTICS HQ	Inverter_1	6T2479016090	PV3 input current(A)	208.060	323.580	35.70
BP PLASTICS HQ	Inverter_1	6T2479016090	PV7 input current(A)	246.210	323.580	23.91
BP PLASTICS HQ	Inverter_1	6T2479016090	PV15 input current(A)	239.600	323.580	25.95
BP PLASTICS HQ	Inverter_1	6T2479016090	PV19 input current(A)	197.560	323.580	38.95

Plant Name	Inverter Name	Inverter SN	String Name	Total Current	Benchmark	Deviation
BP PLASTICS HQ	Inverter_4	ES2460076787	PV1 input current(A)	243.070	338.890	28.27
BP PLASTICS HQ	Inverter_4	ES2460076787	PV11 input current(A)	266.700	338.890	21.30
BP PLASTICS HQ	Inverter_4	ES2460076787	PV13 input current(A)	267.510	338.890	21.06
BP PLASTICS HQ	Inverter_4	ES2460076787	PV15 input current(A)	269.550	338.890	20.46
BP PLASTICS HQ	Inverter_4	ES2460076787	PV2 input current(A)	230.170	338.890	32.08
BP PLASTICS HQ	Inverter_5	ES2460076788	PV1 input current(A)	212.190	302.030	29.75
BP PLASTICS HQ	Inverter_5	ES2460076788	PV11 input current(A)	233.310	302.030	22.75
BP PLASTICS HQ	Inverter_5	ES2460076788	PV13 input current(A)	232.800	302.030	22.92
BP PLASTICS HQ	Inverter_5	ES2460076788	PV15 input current(A)	238.360	302.030	21.08
BP PLASTICS HQ	Inverter_5	ES2460076788	PV17 input current(A)	208.740	302.030	30.89
BP PLASTICS HQ	Inverter_5	ES2460076788	PV2 input current(A)	200.220	302.030	33.71
BP PLASTICS HQ	Inverter_7	6T2479016026	PV9 input current(A)	89.690	215.260	58.33
BP PLASTICS HQ	Inverter_7	6T2479016026	PV11 input current(A)	125.150	215.260	41.86
BP PLASTICS HQ	Inverter_7	6T2479016026	PV13 input current(A)	96.090	215.260	55.36
BP PLASTICS HQ	Inverter_7	6T2479016026	PV15 input current(A)	99.150	215.260	53.94
BP PLASTICS HQ	Inverter_7	6T2479016026	PV17 input current(A)	76.840	215.260	64.30
BP PLASTICS HQ	Inverter_7	6T2479016026	PV19 input current(A)	83.900	215.260	61.02
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	6T21A9013292	PV19 input current(A)	236.210	320.450	26.29
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 12	GR2569071077	PV1 input current(A)	418.360	552.480	24.28
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 12	GR2569071077	PV9 input current(A)	427.050	552.480	22.70
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 12	GR2569071077	PV19 input current(A)	410.510	552.480	25.70
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 12	GR2569071077	PV21 input current(A)	409.730	552.480	25.84
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 12	GR2569071077	PV20 input current(A)	358.110	552.480	35.18
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 2	GR2569071128	PV5 input current(A)	174.520	238.380	26.79

Plant Name	Inverter Name	Inverter SN	String Name	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 2	GR2569071128	PV6 input current(A)	142.320	238.380	40.30
IOI MALL PUCHONG (NEW WING) PHASE 2	inverter 1	GR2569094290	PV13 input current(A)	413.620	542.320	23.73
IOI MALL PUCHONG (NEW WING) PHASE 2	inverter 1	GR2569094290	PV19 input current(A)	406.970	542.320	24.96
IOI MALL PUCHONG (NEW WING) PHASE 2	inverter 1	GR2569094290	PV12 input current(A)	379.290	542.320	30.06
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	6T2489022315	PV2 input current(A)	199.680	522.570	61.79
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	6T2479017517	PV4 input current(A)	420.660	552.190	23.82
JY2	100KTL-M1(COM1-12)	6T21A9037851	PV7 input current(A)	601.420	819.610	26.62
JY2	100KTL-M1(COM1-12)	6T21A9037851	PV9 input current(A)	391.780	819.610	52.20
JY2	100KTL-M1(COM1-12)	6T21A9037851	PV15 input current(A)	509.850	819.610	37.79
JY2	100KTL-M1(COM1-12)	6T21A9037851	PV17 input current(A)	563.170	819.610	31.29
JY2	100KTL-M1(COM1-12)	6T21A9037851	PV19 input current(A)	581.800	819.610	29.02
JY2	100KTL-M1(COM2-12)	6T21A9013444	PV1 input current(A)	602.750	762.270	20.93
JY2	100KTL-M1(COM2-12)	6T21A9013444	PV5 input current(A)	606.420	762.270	20.45
JY2	100KTL-M1(COM2-12)	6T21A9013444	PV11 input current(A)	605.210	762.270	20.60
JY2	100KTL-M1(COM2-12)	6T21A9013444	PV15 input current(A)	572.920	762.270	24.84
KIARA BAY	Inverter 7 - TERA	ES2470045863	PV10 input current(A)	356.920	466.270	23.45
KISWIRE CORD SDN BHD	Inverter_8F	6T2459006692	PV18 input current(A)	277.820	393.420	29.38
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV1 input current(A)	59.140	85.220	30.60
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV5 input current(A)	68.120	85.220	20.07

Plant Name	Inverter Name	Inverter SN	String Name	Total Current	Benchmark	Deviation
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV7 input current(A)	66.920	85.220	21.47
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV9 input current(A)	59.220	85.220	30.51
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV11 input current(A)	56.310	85.220	33.92
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV13 input current(A)	54.780	85.220	35.72
KOMPLEX PKNS BANGI	100KTL-M1(COM1-1)	6T22C9018811	PV15 input current(A)	65.760	85.220	22.84

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
GUH METER 1	VASOLAR_INV_1	6T2379018351	ABNORMAL EXTERNAL FAN	MAJOR	-
C0176_GETHA	LOGGER-102256528260	102256528260	NETWORK CONNECTION ERROR	MAJOR	-
C0172_ATRIA SOUTH	LOGGER-102256528212	102256528212	NETWORK CONNECTION ERROR	MAJOR	-
PLEASURE LATEX PHASE 2	LOGGER-102347282208	102347282208	NETWORK CONNECTION ERROR	MAJOR	-
KOSSAN PAINT SDN BHD	DONGLE-BT2590184594	BT2590184594	NETWORK CONNECTION ERROR	MAJOR	-
KOSSAN PAINT SDN BHD	INV (OFFICE)	HV2580239907	GRID LOSS	MAJOR	-
LIAN TECK SENG LOT 11	DONGLE-BT24C0060275	BT24C0060275	NETWORK CONNECTION ERROR	MAJOR	-
PKT THE SHIP	INVERTER_1	6T2379018298	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT THE SHIP	INVERTER_2 R1	BN2531021024	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT THE SHIP	INVERTER_3	6T2379019623	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT THE SHIP	INVERTER_4	6T2379019776	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT THE SHIP	INVERTER_5	6T2379019768	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
PKT THE SHIP	INVERTER_6	6T2379019622	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT THE SHIP	INVERTER_7	6T2379019759	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
VINDA PHASE 4 (MSB 3-2)	INVERTER7 PHASE4 R1	ES2580051502	AC OVERCURRENT	MAJOR	-
VINDA PHASE 4 (MSB 3-2)	INVERTER7 PHASE4 R1	ES2580051502	GRID LOSS	MAJOR	-
VINDA PHASE 4 (MSB 3-2)	INVERTER7 PHASE4 R1	ES2580051502	THE PV STRING IS SHORT-CIRCUITED TO THE GROUND.	MAJOR	-
QL ENDAU MARINE	LOGGER-HV24C0331342	HV24C0331342	NETWORK CONNECTION ERROR	MAJOR	-
REDANG LAGOON RESORT	DONGLE-2102312EHS10N9115979	2102312EHS10N9115979	NETWORK CONNECTION ERROR	MAJOR	-
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	GRID LOSS	MAJOR	-
LIAN FOO POULTRY FARM SDN BHD	DONGLE-BT2541519026	BT2541519026	NETWORK CONNECTION ERROR	MAJOR	-
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	GRID LOSS	MAJOR	-
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	GRID LOSS	MAJOR	-
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	GRID LOSS	MAJOR	-
FIBERTEX PHASE 2	INVERTER 2 L3 OLD	6T2379019735	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 1	6T2459004867	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 10	6T2449041556	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 2	6T2459004831	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 3	6T2449041406	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 4	ES2470045168	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
PKT 12 WAVES	INVERTER 5	6T2459004824	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 6	ES2470045204	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 7	6T2449033633	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 8	6T2459004809	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PKT 12 WAVES	INVERTER 9	6T2449032075	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
PENGERANG INDEPENDENT TERMINAL	DONGLE-LAB	TA23B0087782	NETWORK CONNECTION ERROR	MAJOR	-
MENARA PKNS PJ	LOGGER-102466288020	102466288020	NETWORK CONNECTION ERROR	MAJOR	-
SJK (C) TSHING NIAN	DONGLE-BT2590184500	BT2590184500	NETWORK CONNECTION ERROR	MAJOR	-
SJK (C) TSHING NIAN	DONGLE-BT2590184504	BT2590184504	NETWORK CONNECTION ERROR	MAJOR	-
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 3	GR2569071111	STRING LOSS	WARNING	-
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 3	GR2569071111	STRING LOSS	WARNING	-
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 3	GR2569071111	STRING LOSS	WARNING	-
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 3	GR2569071111	STRING LOSS	WARNING	-
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 4	GR2569071069	STRING LOSS	WARNING	-
IOI MALL PUCHONG (NEW WING) PHASE 2	INVERTER 4	GR2569071069	STRING LOSS	WARNING	-
IOI MALL PUCHONG (OLD WING)	INVERTER 1 - TERA	BN2461065466	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 10 - TERA	6T2469039407	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
IOI MALL PUCHONG (OLD WING)	INVERTER 11 - TERA	BN2461066739	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 12 - TERA	BN2461066801	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 2 - TERA	BN2461066770	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 21 R1-TERA	6T2599057796	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 3 R1 - TERA	BN2521059950	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 4 - TERA	6T2479017517	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 5 - TERA	BN2461066760	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 6 - TERA	BN2461066754	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 7 - TERA	6T2479017524	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 8 - TERA	BN2461065428	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
IOI MALL PUCHONG (OLD WING)	INVERTER 9 - TERA	6T2479017523	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
MARINE GOLD SDN BHD	DONGLE-HV2310773587	HV2310773587	NETWORK CONNECTION ERROR	MAJOR	-
MARINE GOLD SDN BHD	DONGLE-HV2310776105	HV2310776105	NETWORK CONNECTION ERROR	MAJOR	-
MARINE GOLD SDN BHD	DONGLE-HV2310776109	HV2310776109	NETWORK CONNECTION ERROR	MAJOR	-
MARINE GOLD SDN BHD	DONGLE-TA2340291437	TA2340291437	NETWORK CONNECTION ERROR	MAJOR	-
MARINE GOLD SDN BHD	DONGLE-TA2340293153	TA2340293153	NETWORK CONNECTION ERROR	MAJOR	-
MARINE GOLD SDN BHD	DONGLE-TA2340293476	TA2340293476	NETWORK CONNECTION ERROR	MAJOR	-
PKT 8 WAVES	INVERTER_1	BN2441065390	GRID LOSS	MAJOR	-
PKT 8 WAVES	INVERTER_2	6T2439012020	GRID LOSS	MAJOR	-

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
THP MEDICAL	VASOLAR INV 1	6T2279009011	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
THP MEDICAL	VASOLAR INV 2	6T2279008977	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
THP MEDICAL	VASOLAR INV 3	6T2279009018	UPGRADE FAILED OR VERSION MISMATCH	MINOR	-
BOILERMECH LOT 873	LOGGER-102516002824	102516002824	NETWORK CONNECTION ERROR	MAJOR	-
QL FARM SDN BHD	INVERTER 1	ES2580051653	GRID LOSS	MAJOR	-
QL FARM SDN BHD	INVERTER 2	ES2580051643	GRID LOSS	MAJOR	-
QL FARM SDN BHD	INVERTER3	ES2490076207	GRID LOSS	MAJOR	-
QL FARM SDN BHD	LOGGER-102466853213	102466853213	NETWORK CONNECTION ERROR	MAJOR	-
SABAH CHINESE HIGH SCHOOL (CULTURE AND EDUCATION)	LOGGER-102297461111	102297461111	NETWORK CONNECTION ERROR	MAJOR	-

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
AFI BRAKE MANUFACTURING SDN BHD	INV 4 - GROUND FLOOR	HV22B0337098	72.8
AFI BRAKE MANUFACTURING SDN BHD	INV 5 - FIRST FLOOR	HV22B0337097	73.2
AFI BRAKE MANUFACTURING SDN BHD	INV 6 - SECOND FLOOR	HV22A0405534	71.8
AFI BRAKE MANUFACTURING SDN BHD	INV 7 - THIRD FLOOR	HV22B0337096	71.2
ATS AIR SOLUTION	INV-HV22A0242778	HV22A0242778	74.1
Advance Vi Tech Lot 1629	INVERTER 2 - TERA	ES2330108240	71.0
C0102_QL batang kali	150K-MG0(COM3-2)	GR2479026710	76.7
C0102_QL batang kali	150K-MG0(COM3-3)	GR2479026770	76.7
C0102_QL batang kali	50KTL-M3(COM3-4)	6T24C9048091	72.0
CHAN KAH WHYE	INV-NS249G082061	NS249G082061	80.9
Durasafe Sdn. Bhd.	INV 1-6T2479002464	6T2479002464	75.8

Plant Name	Inverter Name	Inverter SN	Temperature
Durasafe Sdn. Bhd.	INV 2-6T2469038783	6T2469038783	73.4
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 1	6T2569054829	70.4
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 2	ES2580087345	78.3
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 4	ES2580087312	76.8
FOX ONE LOT 8	TERA INVERTER 2	6T25B9000067	73.5
FOX ONE MARKETING SDN BHD	TERA INV 1	6T2499021789	70.4
Farm Fresh Taiping (Factory)	50KTL-M3(COM1-12)	6T22A9038815	76.3
Fungiculture	Inverter 2 (M3)	HV22B0337400	73.2
Fungiculture	Inveter 2 (M1)	HV22B0337398	70.6
GLASS PLASTIC PACKAGING	INV 2 - (No.23)	6T2489010546	75.4
GLASS PLASTIC PACKAGING	INV 3 - (Lot 65999)	6T2489010635	75.1
GLASS PLASTIC PACKAGING	INV 4 - (Lot 65999)	6T2489010593	73.5
IOI City Mall Inc. Feeder 1	Inverter 2.1 - TERA	6T22C9011475	70.2
IOI City Mall Inc. Feeder 1	Inverter 2.2 - TERA	6T22B9036192	71.2
IOI City Mall Inc. Feeder 1	Inverter 2.5 - TERA	6T22C9011507	71.7
IOI City Mall Inc. Feeder 1	Inverter 2.6 - TERA	6T22C9011480	74.1
IOI Mall Puchong (New Wing)	Inverter 16 - TERA	6T2449030262	71.3
Jiann Lih safety product	40KTL-M3(COM1-15)	ES2290059762	73.4
Jiann Lih safety product	40KTL-M3(COM1-16)	ES2290059727	75.4
KB AIS SDN. BHD.	Inverter-1	6T21C9025324	75.7
Kiara Bay	Inverter 3 - TERA	6T2449022934	74.1
Kiara Bay	Inverter 4 - TERA	6T2449023252	70.7
Komplex PKNS Bangi	40KTL-M3(COM1-13)	ES22A0040484	80.7
Mitsui Copper Foil P3	Inverter 3 (AREA A)	6T24A9009773	75.5
Mitsui Copper Foil P3	Inverter 4 (AREA A)	6T24A9013004	72.8

Plant Name	Inverter Name	Inverter SN	Temperature
Multi Choice (M) Sdn Bhd	TERA INV 3	ES2560208616	79.1
P.A Food Sdn Bhd 2ATKT	INV-ES2420001275	ES2420001275	74.9
P.A Food Sdn Bhd Lot 10	INV-6T2449029469	6T2449029469	79.8
P.A Food Sdn Bhd Lot 12	INV-6T2449029471	6T2449029471	80.0
P.A. Food Warehouse No. 9	INV-HV2290797189	HV2290797189	73.5
Pengerang Independent Terminal	VASOLAR INV 2 CP 1	ES2330104289	71.2
Pengerang Independent Terminal	VASOLAR INV 3 CP 1	ES2340146417	75.9
Pengerang Independent Terminal	VASOLAR INV 4 CP 2	6T23A9016705	73.8
Pengerang Independent Terminal	VASOLAR INV7 MC	ES2340146422	80.7
QL ENDAU DEEP SEA FISHING	Inverter 1 (COM1-12)	GR2479028683	75.6
QL ENDAU DEEP SEA FISHING	Inverter 2 (COM3-13)	6T2519005200	78.3
QL ENDAU DEEP SEA FISHING	Inverter 3 (COM3-14)	GR2479020699	75.0
QL ENDAU DEEP SEA FISHING	Inverter 4 (COM3-15)	GR2479020734	72.2
QL ENDAU DEEP SEA FISHING	Inverter 5 (COM3-16)	GR2479028681	76.0
QL FOODS	INVERTER_10	6T2449032177	76.8
QL FOODS	INVERTER_7	6T22A9046723	71.4
QL FOODS	TERA INV2_HOSTEL	6T2599013072	71.7
RS POLY INDUSTRY	VASOLAR INV 1	ES2420000999	72.8
RS POLY INDUSTRY	VASOLAR INV 2	ES2420001084	70.6
SCENT PUR MANUFACTURING SDN BHD NO.35	INV-TA2470078151	TA2470078151	70.7
SCENT PUR MANUFACTURING SDN BHD NO.37	INV-NS245G038275	NS245G038275	77.9
SWEE CHEONG WATCH SDN BHD (Meter 1)	INV-TA2470383341	TA2470383341	73.6
SWEE CHEONG WATCH SDN BHD (Meter 2)	INV-TA2470383489	TA2470383489	70.0
SWH INDUSTRIES (PLOT 132113)	VASOLAR INV 6	6T22A9048188	70.0
TOMEI	INV-(12-1)	HV2330348462	74.2

Plant Name	Inverter Name	Inverter SN	Temperature
TOMEI	INV-(16-1)	HV2330348376	76.3
TOMEI	INV-(4-1)	HV2330348450	70.8
TOMEI	INV-(4-2)	HV2330348386	71.5
TOMEI	INV-(6-1)	HV2330348465	72.0
TOMEI	INV-(8)	HV2330348453	71.9
Tembikar Wei Khing	Inverter 8 - TERA	6T2469033043	70.2
Teong Huat Medical	TERA INV 1	6T2539003818	70.0
Teong Huat Medical	TERA INV 3 R1	6T2599029908	79.5
UCS_Block B	10KTL-M1(COM1-12)	BT2240736599	70.9
WCS UNIT 6	INVERTER UNIT 6	HV2290931617	71.8