

FusionSolar Troubleshooting Report

Date: 05-05-2026
Generated At: 05-05-2026 20:30:07
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	2
Total alarms	56
Total high-temperature inverters	4

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
KOSSAN PAINT SDN BHD	0.23	0.74	-68.75
MAJOR ENGINEERING Lot 8	0.29	0.74	-60.60

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
BIMB Bdr Penawar - 1st Floor	Dongle- INV1	BT24C0060244	Network Connection Error	Major	15-04-2026 18:07
BOILERMECH LOT 873	Logger-102516002824	102516002824	Network Connection Error	Major	02-05-2026 00:57
C0176_GETHA	Logger-102256528260	102256528260	Network Connection Error	Major	28-04-2026 21:09
Dong Sing Food Link Sdn Bhd	Inverter(COM2-1)	ES2570023845	Grid Loss	Major	05-05-2026 06:50
Fibertex Phase 2	Inverter 2 L3 Old	6T2379019735	Upgrade Failed or Version Mismatch	Minor	18-07-2025 15:24
GUH METER 1	VASOLAR_INV_1	6T2379018351	Abnormal External Fan	Major	05-05-2026 08:05
IOI Mall Puchong (New Wing)	Inverter 14 - TERA	ES2470053866	Upgrade Failed or Version Mismatch	Minor	17-04-2026 23:52
IOI Mall Puchong (New Wing)	Inverter 17 - TERA	6T2479017623	Upgrade Failed or Version Mismatch	Minor	17-04-2026 23:52

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
IOI Mall Puchong (New Wing)	Inverter 13 - TERA	6T2479017534	Upgrade Failed or Version Mismatch	Minor	17-04-2026 23:52
IOI Mall Puchong (New Wing) Phase 2	Inverter 4	GR2569071069	Grid Loss	Major	16-04-2026 09:37
IOI Mall Puchong (New Wing) Phase 2	Inverter(COM1-1)	GR2569071128	Grid Loss	Major	10-04-2026 16:33
IOI Mall Puchong (Old Wing)	Inverter 21 R1-TERA	6T2599057796	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 3 R1 - TERA	BN2521059950	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 2 - TERA	BN2461066770	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 4 - TERA	6T2479017517	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 1 - TERA	BN2461065466	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 5 - TERA	BN2461066760	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
KILANG BATU BATA	Dongle-TA2510047367	TA2510047367	Network Connection Error	Major	02-05-2026 11:29
LIAN FOO POULTRY FARM SDN BHD	Dongle-BT2541519026	BT2541519026	Network Connection Error	Major	30-04-2026 18:40
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	Grid Loss	Major	30-04-2026 17:55
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	Grid Loss	Major	30-04-2026 17:54
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	Grid Loss	Major	30-04-2026 17:54
Lian Teck Seng Lot 11	Dongle-BT24C0060275	BT24C0060275	Network Connection Error	Major	29-01-2026 15:54

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
MARINE GOLD SDN BHD	Dongle-TA2340293153	TA2340293153	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340293476	TA2340293476	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340291437	TA2340291437	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-HV2310776105	HV2310776105	Network Connection Error	Major	26-03-2026 14:56
MARINE GOLD SDN BHD	Dongle-HV2310776109	HV2310776109	Network Connection Error	Major	26-03-2026 14:55
MARINE GOLD SDN BHD	Dongle-HV2310773587	HV2310773587	Network Connection Error	Major	26-03-2026 14:54
MENARA PKNS PJ	Logger-102466288020	102466288020	Network Connection Error	Major	04-05-2026 01:08
Menara PJD	Logger-102347282182	102347282182	Network Connection Error	Major	25-04-2026 01:26
Pengerang Independent Terminal	Dongle-LAB	TA23B0087782	Network Connection Error	Major	20-04-2026 13:52
Pleasure Latex Phase 2	Logger-102347282208	102347282208	Network Connection Error	Major	19-02-2026 03:00
QL FARM SDN BHD	Logger-102466853213	102466853213	Network Connection Error	Major	24-04-2026 10:56
QL FARM SDN BHD	Inverter 1	ES2580051653	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter 2	ES2580051643	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter3	ES2490076207	Grid Loss	Major	24-04-2026 10:07
REDANG LAGOON RESORT	Dongle-2102312EHS10N9115979	2102312EHS10N9115979	Network Connection Error	Major	30-01-2026 19:29
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	Grid Loss	Major	30-01-2026 07:23
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	Upgrade Failed or Version Mismatch	Minor	19-11-2025 21:35
THP MEDICAL	VASOLAR INV 3	6T2279009018	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 2	6T2279008977	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 1	6T2279009011	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
Telewiring	VASOLAR_INV_1	HV2330869769	Grid Loss	Major	04-05-2026 08:17
VINDA PHASE 4 (MSB 3-2)	MASTER LOG HT P4	102595350697	Southbound Device Communication Abnormal	Minor	29-04-2026 15:30
WASCO PIPE SDN BHD (MILL)	Inverter 1	GR2569103020	Grid Loss	Major	05-05-2026 09:39

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
WASCO PIPE SDN BHD (MILL)	Inverter 5	ES2540189908	Grid Loss	Major	30-04-2026 11:25
WASCO PIPE SDN BHD (MILL)	Inverter 3	GR2569101626	Grid Loss	Major	30-04-2026 11:25
WASCO PIPE SDN BHD (MILL)	Inverter 2	GR2569101664	Grid Loss	Major	30-04-2026 11:25

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
BP PLASTICS HQ	Inverter_11	6T2499023013	71.0
BP PLASTICS HQ	Inverter_2	ES2440060550	77.5
BP PLASTICS HQ	Inverter_6	6T2499021622	75.1
BP PLASTICS HQ	Inverter_8	6T2499021624	71.4