

FusionSolar Troubleshooting Report

Date 10-04-2026
Generated At 10-04-2026 09:33:21
Prepared By TERA Service Team

Executive Summary

Metric	Value
Total plants analysed	186
Total low-performing plants	33
Total alarms	159
Total high-temperature inverters	0

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation (%)
ASHITA COMMUNICATION	0.00	0.12	-100.00
BJC FOOD (MALAYSIA) SDN. BHD.	0.10	0.12	-15.58
BM COCO PALM	0.11	0.13	-17.50
BP PLASTICS HQ	0.02	0.10	-80.65
BRC INDUSTRIES	0.00	0.11	-100.00
Dong Sing Food Link Sdn Bhd	0.15	0.17	-13.04
FUJI M3	0.06	0.11	-45.45
GUH METER 3	0.00	0.11	-100.00

Plant Name	Plant PSH	City Average PSH	Deviation (%)
IOI Knowledge Vision Sdn Bhd	0.08	0.13	-40.00
IOI Mall Puchong (New Wing) Phase 2	0.11	0.14	-19.51
IOI Mayang Development	0.04	0.13	-70.00
Jaya Nets	0.12	0.14	-13.25
KCCCI Ground Floor	0.11	0.12	-10.43
KISWIRE CORD PHASE 1 (DATA)	0.00	0.13	-100.00
Kwang Hua Persendirian meter 2-3-4-5-6	0.10	0.12	-18.58
LAM SOON EDIBLE OILS	0.00	0.10	-100.00
Lau and Tan Pharmacy (1st Floor)	0.06	0.07	-14.29
Lian Teck Seng Lot 11	0.00	0.12	-100.00
MARINE GOLD SDN BHD	0.00	0.10	-100.00
MENARA PKNS PJ	0.00	0.09	-100.00
MEWAH OILS SDN BHD	0.00	0.12	-100.00
P.A. Food Warehouse No. 9	0.15	0.17	-13.04
PKT 8 WAVES	0.00	0.12	-100.00
Pleasure Latex Phase 2	0.00	0.07	-100.00
QL FOODS	0.14	0.16	-12.50
QL TAWAU FEEDMILL	0.05	0.21	-76.47
REDANG LAGOON RESORT	0.00	0.13	-100.00
SAWIPAC SDN BHD	0.06	0.08	-21.74
SUPERMICRO COMPUTER SDN BHD	0.00	0.08	-100.00
SWEE CHEONG WATCH SDN BHD (Meter 1)	0.15	0.23	-34.78
SWEE CHEONG WATCH SDN BHD (Meter 2)	0.14	0.23	-39.13

Plant Name	Plant PSH	City Average PSH	Deviation (%)
SWH INDUSTRIES (PLOT6311)	0.11	0.14	-23.26
WEIDA MARKETING SDN. BHD.	0.14	0.17	-17.65

Active Alarms

Plant Name	Device SN	Alarm Name	Severity
BRC INDUSTRIES	TA2340258607	Network Connection Error	Major
C0102_QL batang kali	102140076076	Network Connection Error	Major
Fibertex Phase 2	6T2379019735	Upgrade Failed or Version Mismatch	Minor
GUH METER 3	102275906798	Network Connection Error	Major
IOI Knowledge Vision Sdn Bhd	6T2519015499	Grid Loss	Major
IOI Mall Puchong (New Wing) Phase 2	GR2569071069	Grid Loss	Major
LAM SOON EDIBLE OILS	BT24C0060212	Network Connection Error	Major
Lian Teck Seng Lot 11	BT24C0060275	Network Connection Error	Major
MARINE GOLD SDN BHD	HV2310776105	Network Connection Error	Major
MARINE GOLD SDN BHD	TA2340291437	Network Connection Error	Major
MARINE GOLD SDN BHD	HV2310773587	Network Connection Error	Major
MARINE GOLD SDN BHD	TA2340293153	Network Connection Error	Major
MARINE GOLD SDN BHD	TA2340293476	Network Connection Error	Major
MARINE GOLD SDN BHD	HV2310776109	Network Connection Error	Major
MEWAH OILS SDN BHD	JV2549090778	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090684	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091378	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090736	Abnormal output voltage	Major

Plant Name	Device SN	Alarm Name	Severity
MEWAH OILS SDN BHD	JV2549090974	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091380	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091015	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090679	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091299	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091043	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091347	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091061	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091375	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091107	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091032	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091052	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090973	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091006	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091176	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091138	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091360	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091482	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091038	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090835	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091010	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091174	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090961	Abnormal output voltage	Major

Plant Name	Device SN	Alarm Name	Severity
MEWAH OILS SDN BHD	JV2549091168	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091340	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091266	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091276	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091028	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091013	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090783	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090740	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090797	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090854	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091356	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091242	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091474	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090686	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091050	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091336	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091473	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091381	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091484	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091150	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090955	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091246	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091359	Abnormal output voltage	Major

Plant Name	Device SN	Alarm Name	Severity
MEWAH OILS SDN BHD	JV2549091132	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090990	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090964	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090949	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091185	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091239	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091120	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091254	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091389	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091328	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091137	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091337	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090982	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091189	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091249	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091488	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090848	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091021	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091233	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091472	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091025	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090983	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091382	Abnormal output voltage	Major

Plant Name	Device SN	Alarm Name	Severity
MEWAH OILS SDN BHD	JV2549090999	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090803	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091310	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091313	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090703	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091476	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090682	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091012	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090883	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091343	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091167	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091169	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091471	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091258	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090967	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091374	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091001	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091141	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091440	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091180	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091364	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091135	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091373	Abnormal output voltage	Major

Plant Name	Device SN	Alarm Name	Severity
MEWAH OILS SDN BHD	JV2549091369	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091235	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090989	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091346	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091125	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090812	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091335	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091051	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091184	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091119	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091131	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090678	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091105	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091244	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090674	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091178	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090826	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091475	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090793	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091117	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090958	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090833	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091165	Abnormal output voltage	Major

Plant Name	Device SN	Alarm Name	Severity
MEWAH OILS SDN BHD	JV2549091114	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090858	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549090954	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091272	Abnormal output voltage	Major
MEWAH OILS SDN BHD	JV2549091048	Abnormal output voltage	Major
MEWAH OILS SDN BHD	102518022607	Network Connection Error	Major
PKT 8 WAVES	6T2439012020	Grid Loss	Major
PKT 8 WAVES	BN2441065390	Grid Loss	Major
Pengerang Independent Terminal	BN2531034435	Grid Loss	Major
Pleasure Latex Phase 2	102347282208	Network Connection Error	Major
REDANG LAGOON RESORT	ES22A0089681	Grid Loss	Major
REDANG LAGOON RESORT	2102312EHS10N9115979	Network Connection Error	Major
SABAH CHINESE HIGH SCHOOL (TAK YUEN BUILDING)	102297461092	Network Connection Error	Major
SIME KANSAI PAINT SDN BHD	ES2550146111	Upgrade Failed or Version Mismatch	Minor
SUPERMICRO COMPUTER SDN BHD	102528408833	Network Connection Error	Major
Sedania Bank Islam Bandar Penawar Meter 1	BT24C0060244	Network Connection Error	Major
Sedania Bank Islam Bandar Penawar Meter 2	BT24C0060755	Network Connection Error	Major
THP MEDICAL	6T2279009011	Upgrade Failed or Version Mismatch	Minor
THP MEDICAL	6T2279008977	Upgrade Failed or Version Mismatch	Minor
THP MEDICAL	6T2279009018	Upgrade Failed or Version Mismatch	Minor
Teong Huat Medical	ES2540190345	Grid Loss	Major
WASCO PIPE SDN BHD (COATING)	102516002786	Network Connection Error	Major
WASCO PIPE SDN BHD (MILL)	GR2569103020	Grid Loss	Major

Plant Name	Device SN	Alarm Name	Severity
WASCO PIPE SDN BHD (MILL)	GR2459039441	Grid Loss	Major
WASCO PIPE SDN BHD (MILL)	GR2569101664	Grid Loss	Major
WASCO PIPE SDN BHD (MILL)	GR2569101626	Grid Loss	Major

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature (°C)
No high-temperature inverters found	-	-	-