

FusionSolar Troubleshooting Report

Date: 15-05-2026
Generated At: 15-05-2026 08:30:08
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	2
Total low-performing inverters	54
Total low-performing strings	472
Total alarms	49
Total high-temperature inverters	133

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
MAJOR ENGINEERING Lot 10	3.61	4.43	-18.51
MAJOR ENGINEERING Lot 8	0.71	4.43	-83.97

Low-performing Inverters

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	1.950	2.376	17.93
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	2.507	2.881	12.98
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	2.543	2.881	11.73
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	2.580	2.881	10.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	1.734	2.037	14.87
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	1.736	2.037	14.78

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	1.728	2.037	15.17
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	1.712	2.037	15.95
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	1.729	2.037	15.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	1.725	2.037	15.32
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	1.724	2.037	15.37
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	1.735	2.037	14.83
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	1.733	2.037	14.92
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	1.725	2.037	15.32
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 4	NE=82071817	0.187	2.530	92.61
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	1.780	2.825	36.99
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	1.977	2.825	30.02
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	1.951	2.825	30.94
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	1.935	2.825	31.50
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	1.674	2.825	40.74
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	1.985	2.825	29.73
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	1.969	2.825	30.30
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	1.831	2.825	35.19
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	1.902	2.825	32.67
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	1.955	2.825	30.80
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	1.926	2.825	31.82
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	1.921	2.825	32.00
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	1.938	2.825	31.40
KIARA BAY	Inverter 1 - TERA	NE=55735156	2.003	2.287	12.42
KIARA BAY	Inverter 10 - TERA	NE=55735154	1.232	2.287	46.13
KIARA BAY	Inverter 11 - TERA	NE=55735153	1.274	2.287	44.29

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
KIARA BAY	Inverter 3 - TERA	NE=55735162	1.807	2.287	20.99
KIARA BAY	Inverter 4 - TERA	NE=55735161	1.683	2.287	26.41
KIARA BAY	Inverter 5 - TERA	NE=55735155	1.826	2.287	20.16
KIARA BAY	Inverter 6 - TERA	NE=55735160	1.248	2.287	45.43
KIARA BAY	Inverter 7 - TERA	NE=55735157	1.474	2.287	35.55
KIARA BAY	Inverter 8 - TERA	NE=55735158	1.426	2.287	37.65
KIARA BAY	Inverter 9 - TERA	NE=55735159	1.180	2.287	48.40
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	1.675	2.121	21.03
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	1.458	2.121	31.26
QL FOODS	INVERTER_10	NE=53679611	1.926	2.460	21.71
QL FOODS	INVERTER_15	NE=53679053	2.099	2.460	14.67
QL FOODS	INVERTER_3	NE=53678487	2.194	2.460	10.81
QL FOODS	INVERTER_7	NE=53676713	1.979	2.460	19.55
QL FOODS	INVERTER_9	NE=53679667	2.079	2.460	15.49
TEONG HUAT MEDICAL	TERA INV 1	NE=79838602	3.012	3.402	11.46
TEONG HUAT MEDICAL	TERA INV 4	NE=79838604	3.011	3.402	11.49
TOMEI	INV-(10-2)	NE=54352010	1.500	1.855	19.14
TOMEI	INV-(10-3)	NE=54351494	1.231	1.855	33.64
TOMEI	INV-(16-2)	NE=54352004	1.392	1.855	24.96
TOMEI	INV-(4)	NE=55086008	1.594	1.855	14.07
TOMEI	INV-(4-3)	NE=54351850	1.304	1.855	29.70
TOMEI	INV-(6-3)	NE=54351644	1.443	1.855	22.21
TOMEI	INV-(8-3)	NE=54351578	1.331	1.855	28.25

Low-performing Strings

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV10 input current(A)	-0.310	1053.590	100.03
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV11 input current(A)	745.730	1053.590	29.22
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV12 input current(A)	-0.320	1053.590	100.03
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV13 input current(A)	731.940	1053.590	30.53
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV14 input current(A)	-0.170	1053.590	100.02
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV15 input current(A)	716.870	1053.590	31.96
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV16 input current(A)	-0.760	1053.590	100.07
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV17 input current(A)	540.130	1053.590	48.73
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV18 input current(A)	-1.530	1053.590	100.15
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV19 input current(A)	607.960	1053.590	42.30
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV2 input current(A)	-0.190	1053.590	100.02
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV20 input current(A)	-1.150	1053.590	100.11
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV4 input current(A)	-0.270	1053.590	100.03
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV5 input current(A)	934.960	1053.590	11.26
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV6 input current(A)	-0.170	1053.590	100.02
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV7 input current(A)	690.760	1053.590	34.44

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV8 input current(A)	0.000	1053.590	100.00
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV9 input current(A)	833.600	1053.590	20.88
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV0 input current(A)	2.000	1116.360	99.82
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV11 input current(A)	1.290	1116.360	99.88
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV13 input current(A)	1.430	1116.360	99.87
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV15 input current(A)	0.830	1116.360	99.93
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV17 input current(A)	23.640	1116.360	97.88
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV19 input current(A)	1.420	1116.360	99.87
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV3 input current(A)	2.100	1116.360	99.81
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV5 input current(A)	1.010	1116.360	99.91
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV7 input current(A)	0.840	1116.360	99.92
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV9 input current(A)	1.250	1116.360	99.89
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV0 input current(A)	2.000	1100.190	99.82
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV11 input current(A)	0.400	1100.190	99.96
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV13 input current(A)	1.410	1100.190	99.87
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV15 input current(A)	0.970	1100.190	99.91

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV17 input current(A)	36.120	1100.190	96.72
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV19 input current(A)	980.770	1100.190	10.85
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV20 input current(A)	956.880	1100.190	13.03
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV3 input current(A)	1.600	1100.190	99.85
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV5 input current(A)	1.350	1100.190	99.88
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV7 input current(A)	0.990	1100.190	99.91
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV9 input current(A)	1.320	1100.190	99.88
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV input current(A) 6	6.000	1121.610	99.47
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV11 input current(A)	0.780	1121.610	99.93
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV12 input current(A)	930.180	1121.610	17.07
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV13 input current(A)	1.290	1121.610	99.88
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV14 input current(A)	858.380	1121.610	23.47
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV15 input current(A)	-0.480	1121.610	100.04
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV17 input current(A)	20.170	1121.610	98.20
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV19 input current(A)	1.470	1121.610	99.87
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV3 input current(A)	1.610	1121.610	99.86

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV5 input current(A)	0.810	1121.610	99.93
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV7 input current(A)	1.300	1121.610	99.88
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV9 input current(A)	1.220	1121.610	99.89
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV input current(A) 2	2.000	325.180	99.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV10 input current(A)	-1.160	325.180	100.36
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV12 input current(A)	-1.050	325.180	100.32
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV13 input current(A)	284.030	325.180	12.65
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV14 input current(A)	-1.830	325.180	100.56
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV16 input current(A)	-0.870	325.180	100.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV18 input current(A)	-1.350	325.180	100.42
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV19 input current(A)	67.300	325.180	79.30
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV2 input current(A)	287.610	325.180	11.55
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV20 input current(A)	-7.330	325.180	102.25
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV3 input current(A)	291.410	325.180	10.39
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV5 input current(A)	279.240	325.180	14.13
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV6 input current(A)	0.570	325.180	99.82

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV7 input current(A)	278.550	325.180	14.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV8 input current(A)	-1.090	325.180	100.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV9 input current(A)	291.500	325.180	10.36
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV input current(A) 1	1.000	393.670	99.75
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV input current(A) 2	2.000	393.670	99.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV1 input current(A)	340.800	393.670	13.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV10 input current(A)	-1.570	393.670	100.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV11 input current(A)	253.000	393.670	35.73
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV12 input current(A)	-1.480	393.670	100.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV13 input current(A)	251.850	393.670	36.03
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV14 input current(A)	-2.840	393.670	100.72
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV16 input current(A)	-1.820	393.670	100.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV17 input current(A)	301.310	393.670	23.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV18 input current(A)	-2.600	393.670	100.66
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV19 input current(A)	286.000	393.670	27.35
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV2 input current(A)	217.240	393.670	44.82

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV20 input current(A)	-1.290	393.670	100.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV3 input current(A)	344.960	393.670	12.37
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV4 input current(A)	214.820	393.670	45.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV5 input current(A)	237.550	393.670	39.66
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV6 input current(A)	-4.580	393.670	101.16
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV7 input current(A)	242.390	393.670	38.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV8 input current(A)	-2.630	393.670	100.67
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV9 input current(A)	347.970	393.670	11.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV1 input current(A)	266.870	362.930	26.47
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV10 input current(A)	-3.960	362.930	101.09
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV11 input current(A)	289.030	362.930	20.36
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV12 input current(A)	-1.160	362.930	100.32
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV13 input current(A)	227.070	362.930	37.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV14 input current(A)	-4.700	362.930	101.30
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV15 input current(A)	235.570	362.930	35.09
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV16 input current(A)	-1.600	362.930	100.44

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV17 input current(A)	278.950	362.930	23.14
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV18 input current(A)	-0.150	362.930	100.04
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV19 input current(A)	231.230	362.930	36.29
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV20 input current(A)	-1.880	362.930	100.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV3 input current(A)	284.820	362.930	21.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV5 input current(A)	295.850	362.930	18.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV6 input current(A)	-1.220	362.930	100.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV7 input current(A)	288.370	362.930	20.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV8 input current(A)	-1.600	362.930	100.44
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV9 input current(A)	233.050	362.930	35.79
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV input current(A) 1	1.000	314.110	99.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV10 input current(A)	-2.420	314.110	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV12 input current(A)	-1.750	314.110	100.56
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV14 input current(A)	-1.780	314.110	100.57
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV15 input current(A)	214.790	314.110	31.62
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV16 input current(A)	-3.050	314.110	100.97

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV17 input current(A)	261.940	314.110	16.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV18 input current(A)	-1.360	314.110	100.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV19 input current(A)	258.220	314.110	17.79
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV20 input current(A)	-3.330	314.110	101.06
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV6 input current(A)	-1.790	314.110	100.57
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV8 input current(A)	-1.960	314.110	100.62
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV9 input current(A)	237.450	314.110	24.41
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV1 input current(A)	282.780	404.680	30.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV10 input current(A)	-4.180	404.680	101.03
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV11 input current(A)	245.310	404.680	39.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV12 input current(A)	-9.270	404.680	102.29
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV13 input current(A)	241.670	404.680	40.28
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV14 input current(A)	-4.050	404.680	101.00
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV15 input current(A)	164.570	404.680	59.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV16 input current(A)	-3.880	404.680	100.96
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV17 input current(A)	270.680	404.680	33.11

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV18 input current(A)	-1.650	404.680	100.41
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV19 input current(A)	225.410	404.680	44.30
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV20 input current(A)	-1.540	404.680	100.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV3 input current(A)	266.010	404.680	34.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV6 input current(A)	-0.670	404.680	100.17
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV7 input current(A)	355.350	404.680	12.19
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV8 input current(A)	-0.840	404.680	100.21
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV9 input current(A)	170.720	404.680	57.81
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV input current(A) 2	4.000	335.450	98.81
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV1 input current(A)	251.040	335.450	25.16
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV10 input current(A)	-1.460	335.450	100.44
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV12 input current(A)	-1.380	335.450	100.41
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV13 input current(A)	298.650	335.450	10.97
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV14 input current(A)	-2.060	335.450	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV16 input current(A)	-1.750	335.450	100.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV18 input current(A)	-1.890	335.450	100.56

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV2 input current(A)	203.200	335.450	39.42
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV20 input current(A)	-2.820	335.450	100.84
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV3 input current(A)	248.500	335.450	25.92
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV4 input current(A)	206.390	335.450	38.47
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV6 input current(A)	-2.760	335.450	100.82
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV8 input current(A)	-2.900	335.450	100.86
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 1	2.000	349.520	99.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 2	2.000	349.520	99.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV1 input current(A)	226.840	349.520	35.10
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV10 input current(A)	-2.810	349.520	100.80
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV11 input current(A)	295.840	349.520	15.36
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV12 input current(A)	-2.300	349.520	100.66
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV13 input current(A)	298.910	349.520	14.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV14 input current(A)	-1.140	349.520	100.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV15 input current(A)	282.780	349.520	19.09
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV16 input current(A)	-1.960	349.520	100.56

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV17 input current(A)	287.130	349.520	17.85
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV18 input current(A)	-1.680	349.520	100.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV2 input current(A)	251.840	349.520	27.95
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV20 input current(A)	-2.540	349.520	100.73
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV3 input current(A)	229.750	349.520	34.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV4 input current(A)	243.480	349.520	30.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV6 input current(A)	-1.830	349.520	100.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV7 input current(A)	309.710	349.520	11.39
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV8 input current(A)	-2.390	349.520	100.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV9 input current(A)	291.660	349.520	16.55
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV10 input current(A)	-2.340	380.600	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV11 input current(A)	278.300	380.600	26.88
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV12 input current(A)	-1.260	380.600	100.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV13 input current(A)	261.360	380.600	31.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV14 input current(A)	-1.970	380.600	100.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV16 input current(A)	-2.210	380.600	100.58

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV17 input current(A)	229.680	380.600	39.65
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV18 input current(A)	-2.220	380.600	100.58
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV19 input current(A)	205.910	380.600	45.90
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV2 input current(A)	282.580	380.600	25.75
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV20 input current(A)	-1.420	380.600	100.37
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV4 input current(A)	282.390	380.600	25.80
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV5 input current(A)	264.660	380.600	30.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV6 input current(A)	-2.020	380.600	100.53
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV7 input current(A)	261.150	380.600	31.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV8 input current(A)	-0.530	380.600	100.14
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV9 input current(A)	204.600	380.600	46.24
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV input current(A) 1	2.000	325.890	99.39
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV1 input current(A)	241.480	325.890	25.90
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV10 input current(A)	-1.380	325.890	100.42
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV12 input current(A)	-1.560	325.890	100.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV14 input current(A)	-1.130	325.890	100.35

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV16 input current(A)	-1.080	325.890	100.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV18 input current(A)	0.550	325.890	99.83
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV2 input current(A)	237.130	325.890	27.24
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV20 input current(A)	-1.550	325.890	100.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV3 input current(A)	227.410	325.890	30.22
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV4 input current(A)	216.510	325.890	33.56
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV6 input current(A)	-0.460	325.890	100.14
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV8 input current(A)	-2.240	325.890	100.69
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV9 input current(A)	284.760	325.890	12.62
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV input current(A) 1	1.000	332.870	99.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV1 input current(A)	193.120	332.870	41.98
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV10 input current(A)	-2.040	332.870	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV12 input current(A)	-1.510	332.870	100.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV14 input current(A)	-1.610	332.870	100.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV16 input current(A)	-1.810	332.870	100.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV18 input current(A)	-1.500	332.870	100.45

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV2 input current(A)	211.220	332.870	36.55
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV20 input current(A)	-1.970	332.870	100.59
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV3 input current(A)	201.810	332.870	39.37
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV4 input current(A)	201.760	332.870	39.39
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV6 input current(A)	-1.440	332.870	100.43
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV8 input current(A)	-1.490	332.870	100.45
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV input current(A) 15	15.000	993.800	98.49
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV input current(A) 3	3.000	993.800	99.70
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV10 input current(A)	-0.590	993.800	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV12 input current(A)	-1.020	993.800	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV14 input current(A)	-0.490	993.800	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV16 input current(A)	-0.470	993.800	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV18 input current(A)	5.660	993.800	99.43
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV19 input current(A)	883.680	993.800	11.08
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV20 input current(A)	-0.050	993.800	100.01
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV4 input current(A)	679.660	993.800	31.61
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV6 input current(A)	-0.490	993.800	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV8 input current(A)	-0.490	993.800	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV input current(A) 4	4.000	1004.780	99.60
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV input current(A) 7	7.000	1004.780	99.30
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV1 input current(A)	876.790	1004.780	12.74
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV10 input current(A)	-0.840	1004.780	100.08

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV12 input current(A)	-2.910	1004.780	100.29
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV14 input current(A)	-1.110	1004.780	100.11
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV16 input current(A)	-28.260	1004.780	102.81
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV18 input current(A)	5.250	1004.780	99.48
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV20 input current(A)	-0.990	1004.780	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV6 input current(A)	903.080	1004.780	10.12
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV7 input current(A)	899.850	1004.780	10.44
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV8 input current(A)	902.520	1004.780	10.18
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV input current(A) 2	2.000	967.200	99.79
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV10 input current(A)	-0.610	967.200	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV11 input current(A)	796.950	967.200	17.60
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV12 input current(A)	-0.770	967.200	100.08
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV14 input current(A)	-0.700	967.200	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV16 input current(A)	-18.400	967.200	101.90
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV18 input current(A)	8.780	967.200	99.09
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV20 input current(A)	9.080	967.200	99.06
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV8 input current(A)	-0.430	967.200	100.04
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV input current(A) 2	2.000	1001.700	99.80
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV0 input current(A)	4.000	1001.700	99.60
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV1 input current(A)	894.170	1001.700	10.73
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV10 input current(A)	-1.060	1001.700	100.11
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV12 input current(A)	-0.730	1001.700	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV14 input current(A)	-0.960	1001.700	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV16 input current(A)	-36.820	1001.700	103.68
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV18 input current(A)	4.980	1001.700	99.50

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV2 input current(A)	867.180	1001.700	13.43
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV20 input current(A)	874.070	1001.700	12.74
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV4 input current(A)	-1.080	1001.700	100.11
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV6 input current(A)	-29.290	1001.700	102.92
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV8 input current(A)	-25.720	1001.700	102.57
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV9 input current(A)	851.210	1001.700	15.02
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV1 input current(A)	801.410	916.200	12.53
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV2 input current(A)	518.450	916.200	43.41
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV3 input current(A)	774.550	916.200	15.46
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV4 input current(A)	0.000	916.200	100.00
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV5 input current(A)	767.110	916.200	16.27
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV6 input current(A)	0.000	916.200	100.00
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV8 input current(A)	0.000	916.200	100.00
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV input current(A) 15	15.000	994.880	98.49
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV input current(A) 2	2.000	994.880	99.80
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV10 input current(A)	-0.500	994.880	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV12 input current(A)	-0.560	994.880	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV14 input current(A)	-0.670	994.880	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV16 input current(A)	-0.700	994.880	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV18 input current(A)	5.830	994.880	99.41
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV20 input current(A)	0.850	994.880	99.91
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV6 input current(A)	-0.620	994.880	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV8 input current(A)	-0.240	994.880	100.02
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV input current(A) 2	2.000	987.000	99.80

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV input current(A) 3	3.000	987.000	99.70
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV10 input current(A)	-0.550	987.000	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV12 input current(A)	-12.150	987.000	101.23
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV14 input current(A)	-0.610	987.000	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV16 input current(A)	-18.000	987.000	101.82
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV17 input current(A)	882.730	987.000	10.56
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV18 input current(A)	14.740	987.000	98.51
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV20 input current(A)	0.100	987.000	99.99
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV5 input current(A)	883.650	987.000	10.47
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV6 input current(A)	-1.190	987.000	100.12
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV8 input current(A)	-15.280	987.000	101.55
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV10 input current(A)	-0.370	953.270	100.04
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV12 input current(A)	0.450	953.270	99.95
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV14 input current(A)	-0.580	953.270	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV16 input current(A)	-34.570	953.270	103.63
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV18 input current(A)	-0.470	953.270	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV20 input current(A)	-0.910	953.270	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV3 input current(A)	826.450	953.270	13.30
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV4 input current(A)	800.080	953.270	16.07

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV6 input current(A)	-3.420	953.270	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV8 input current(A)	-0.740	953.270	100.08
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV input current(A) 1	1.000	993.490	99.90
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV10 input current(A)	-0.630	993.490	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV12 input current(A)	-1.710	993.490	100.17
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV14 input current(A)	-0.610	993.490	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV16 input current(A)	-10.120	993.490	101.02
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV17 input current(A)	871.770	993.490	12.25
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV18 input current(A)	8.700	993.490	99.12
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV20 input current(A)	-0.470	993.490	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV6 input current(A)	-0.610	993.490	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV8 input current(A)	-0.570	993.490	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV10 input current(A)	-0.690	1006.840	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV12 input current(A)	-1.460	1006.840	100.15
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV14 input current(A)	-0.830	1006.840	100.08
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV16 input current(A)	-24.570	1006.840	102.44
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV18 input current(A)	10.380	1006.840	98.97
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV2 input current(A)	-0.580	1006.840	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV20 input current(A)	-0.880	1006.840	100.09
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV3 input current(A)	883.790	1006.840	12.22
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV4 input current(A)	859.770	1006.840	14.61
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV6 input current(A)	900.240	1006.840	10.59
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV8 input current(A)	-1.050	1006.840	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV input current(A) 6	6.000	999.580	99.40
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV10 input current(A)	-0.400	999.580	100.04

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV12 input current(A)	-0.340	999.580	100.03
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV14 input current(A)	-0.580	999.580	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV15 input current(A)	851.390	999.580	14.83
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV16 input current(A)	-1.000	999.580	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV17 input current(A)	828.920	999.580	17.07
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV18 input current(A)	-0.570	999.580	100.06
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV19 input current(A)	822.630	999.580	17.70
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	PV20 input current(A)	-0.970	999.580	100.10
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV10 input current(A)	-0.690	976.740	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV12 input current(A)	866.520	976.740	11.28
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV14 input current(A)	-0.720	976.740	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV15 input current(A)	788.110	976.740	19.31
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV16 input current(A)	-0.790	976.740	100.08
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV18 input current(A)	-0.860	976.740	100.09
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV20 input current(A)	1.170	976.740	99.88
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV5 input current(A)	859.620	976.740	11.99
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV6 input current(A)	878.290	976.740	10.08
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV8 input current(A)	867.120	976.740	11.22
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV input current(A) 2	2.000	992.730	99.80
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV1 input current(A)	829.220	992.730	16.47
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV10 input current(A)	-0.520	992.730	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV12 input current(A)	-30.030	992.730	103.02
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV14 input current(A)	-0.650	992.730	100.07
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV16 input current(A)	-21.540	992.730	102.17
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV18 input current(A)	-0.360	992.730	100.04

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV2 input current(A)	886.320	992.730	10.72
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV20 input current(A)	-0.510	992.730	100.05
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV8 input current(A)	882.950	992.730	11.06
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV0 input current(A)	2.000	953.140	99.79
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV11 input current(A)	1.200	953.140	99.87
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV12 input current(A)	739.820	953.140	22.38
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV13 input current(A)	1.530	953.140	99.84
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV14 input current(A)	809.570	953.140	15.06
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV15 input current(A)	1.450	953.140	99.85
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV16 input current(A)	802.840	953.140	15.77
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV17 input current(A)	1.500	953.140	99.84
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV18 input current(A)	814.920	953.140	14.50
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV19 input current(A)	1.530	953.140	99.84
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV20 input current(A)	797.830	953.140	16.29
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV3 input current(A)	1.340	953.140	99.86
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV5 input current(A)	1.250	953.140	99.87
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV7 input current(A)	1.170	953.140	99.88
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV9 input current(A)	1.230	953.140	99.87
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV input current(A) 1	1.000	750.530	99.87
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV0 input current(A)	2.000	750.530	99.73
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV1 input current(A)	641.810	750.530	14.49
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV11 input current(A)	3.610	750.530	99.52
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV12 input current(A)	663.510	750.530	11.59
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV13 input current(A)	2.640	750.530	99.65
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV15 input current(A)	3.300	750.530	99.56

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV16 input current(A)	661.890	750.530	11.81
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV17 input current(A)	3.400	750.530	99.55
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV18 input current(A)	653.740	750.530	12.90
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV19 input current(A)	2.700	750.530	99.64
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV2 input current(A)	658.980	750.530	12.20
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV20 input current(A)	652.130	750.530	13.11
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV3 input current(A)	642.990	750.530	14.33
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV4 input current(A)	640.280	750.530	14.69
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV5 input current(A)	2.710	750.530	99.64
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV7 input current(A)	2.250	750.530	99.70
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV9 input current(A)	2.660	750.530	99.65
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV input current(A) 1	1.000	743.140	99.87
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV input current(A) 10	10.000	743.140	98.65
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV10 input current(A)	640.910	743.140	13.76
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV11 input current(A)	4.760	743.140	99.36
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV12 input current(A)	616.440	743.140	17.05
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV13 input current(A)	4.410	743.140	99.41
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV14 input current(A)	636.370	743.140	14.37
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV15 input current(A)	4.010	743.140	99.46
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV17 input current(A)	3.920	743.140	99.47
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV19 input current(A)	2.850	743.140	99.62
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV3 input current(A)	2.790	743.140	99.62
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV5 input current(A)	4.430	743.140	99.40
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV6 input current(A)	662.890	743.140	10.80
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV7 input current(A)	3.540	743.140	99.52

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV9 input current(A)	4.610	743.140	99.38
KIARA BAY	Inverter 3 - TERA	NE=55735162	PV2 input current(A)	0.650	833.280	99.92
KIARA BAY	Inverter 3 - TERA	NE=55735162	PV4 input current(A)	0.110	833.280	99.99
KIARA BAY	Inverter 3 - TERA	NE=55735162	PV5 input current(A)	747.780	833.280	10.26
KIARA BAY	Inverter 3 - TERA	NE=55735162	PV6 input current(A)	0.060	833.280	99.99
KIARA BAY	Inverter 3 - TERA	NE=55735162	PV8 input current(A)	-0.700	833.280	100.08
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV2 input current(A)	-7.510	897.850	100.84
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV4 input current(A)	-2.980	897.850	100.33
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV6 input current(A)	-1.720	897.850	100.19
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV8 input current(A)	-1.200	897.850	100.13
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV input current(A) 9	9.000	880.820	98.98
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV10 input current(A)	763.280	880.820	13.34
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV11 input current(A)	1.780	880.820	99.80
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV13 input current(A)	2.920	880.820	99.67
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV14 input current(A)	789.620	880.820	10.35
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV15 input current(A)	1.660	880.820	99.81
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV16 input current(A)	789.790	880.820	10.33
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV17 input current(A)	1.700	880.820	99.81
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV18 input current(A)	791.160	880.820	10.18
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV3 input current(A)	1.750	880.820	99.80
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV5 input current(A)	1.730	880.820	99.80
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV7 input current(A)	2.680	880.820	99.70
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV8 input current(A)	773.720	880.820	12.16
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV9 input current(A)	749.600	880.820	14.90
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV2 input current(A)	-1.000	815.500	100.12

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV4 input current(A)	-2.250	815.500	100.28
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV6 input current(A)	-0.750	815.500	100.09
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV8 input current(A)	-1.750	815.500	100.21
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV input current(A) 12	12.000	776.620	98.45
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV0 input current(A)	1.000	776.620	99.87
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV1 input current(A)	698.560	776.620	10.05
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV10 input current(A)	608.790	776.620	21.61
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV11 input current(A)	2.570	776.620	99.67
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV13 input current(A)	2.780	776.620	99.64
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV15 input current(A)	3.200	776.620	99.59
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV16 input current(A)	687.720	776.620	11.45
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV17 input current(A)	3.260	776.620	99.58
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV19 input current(A)	2.820	776.620	99.64
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV2 input current(A)	679.080	776.620	12.56
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV3 input current(A)	698.830	776.620	10.02
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV4 input current(A)	680.780	776.620	12.34
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV5 input current(A)	2.830	776.620	99.64
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV7 input current(A)	3.250	776.620	99.58
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV9 input current(A)	3.550	776.620	99.54
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV input current(A) 1	1.000	754.930	99.87
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV11 input current(A)	2.700	754.930	99.64
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV13 input current(A)	3.230	754.930	99.57
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV15 input current(A)	3.900	754.930	99.48
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV16 input current(A)	658.430	754.930	12.78
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV17 input current(A)	17.150	754.930	97.73

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV18 input current(A)	676.110	754.930	10.44
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV19 input current(A)	3.420	754.930	99.55
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV2 input current(A)	629.300	754.930	16.64
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV3 input current(A)	3.090	754.930	99.59
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV5 input current(A)	3.400	754.930	99.55
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV7 input current(A)	2.940	754.930	99.61
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV9 input current(A)	2.800	754.930	99.63
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV2 input current(A)	-0.290	751.340	100.04
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV4 input current(A)	-2.310	751.340	100.31
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV6 input current(A)	-0.340	751.340	100.05
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV8 input current(A)	-1.360	751.340	100.18
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV input current(A) 1	1.000	968.710	99.90
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV2 input current(A)	607.710	968.710	37.27
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV3 input current(A)	667.850	968.710	31.06
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV4 input current(A)	0.000	968.710	100.00
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV5 input current(A)	702.580	968.710	27.47
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV6 input current(A)	0.000	968.710	100.00
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV8 input current(A)	0.000	968.710	100.00
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV1 input current(A)	535.400	827.090	35.27
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV2 input current(A)	0.000	827.090	100.00

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV3 input current(A)	510.760	827.090	38.25
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV4 input current(A)	0.000	827.090	100.00
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV6 input current(A)	0.000	827.090	100.00
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV8 input current(A)	0.000	827.090	100.00

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
BIMB Bdr Penawar - 1st Floor	Dongle- INV1	BT24C0060244	Network Connection Error	Major	15-04-2026 18:07
BOILERMECH LOT 873	Logger-102516002824	102516002824	Network Connection Error	Major	13-05-2026 12:52
BP PLASTICS BP9	Logger-102556511876	102556511876	Network Connection Error	Major	10-05-2026 16:38
C0172_ATRIA SOUTH	Logger-102256528212	102256528212	Network Connection Error	Major	08-05-2026 01:02
C0176_GETHA	Logger-102256528260	102256528260	Network Connection Error	Major	28-04-2026 21:09
Fibertex Phase 2	Inverter 2 L3 Old	6T2379019735	Upgrade Failed or Version Mismatch	Minor	18-07-2025 15:24
GUH METER 1	VASOLAR_INV_1	6T2379018351	Abnormal External Fan	Major	14-05-2026 09:17
IOI Mall Puchong (Old Wing)	Inverter 21 R1-TERA	6T2599057796	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 3 R1 - TERA	BN2521059950	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 2 - TERA	BN2461066770	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 4 - TERA	6T2479017517	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 1 - TERA	BN2461065466	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 5 - TERA	BN2461066760	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
LIAN FOO POULTRY FARM SDN BHD	Dongle-BT2541519026	BT2541519026	Network Connection Error	Major	30-04-2026 18:40
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	Grid Loss	Major	30-04-2026 17:55
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	Grid Loss	Major	30-04-2026 17:54
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	Grid Loss	Major	30-04-2026 17:54
Lian Teck Seng Lot 11	Dongle-BT24C0060275	BT24C0060275	Network Connection Error	Major	29-01-2026 15:54
MARINE GOLD SDN BHD	Dongle-TA2340293153	TA2340293153	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340293476	TA2340293476	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340291437	TA2340291437	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-HV2310776105	HV2310776105	Network Connection Error	Major	26-03-2026 14:56
MARINE GOLD SDN BHD	Dongle-HV2310776109	HV2310776109	Network Connection Error	Major	26-03-2026 14:55
MARINE GOLD SDN BHD	Dongle-HV2310773587	HV2310773587	Network Connection Error	Major	26-03-2026 14:54
MENARA PKNS PJ	Logger-102466288020	102466288020	Network Connection Error	Major	10-05-2026 01:00
MAIAW FRESH	VASOLAR INV 1	NS2331625509	Grid Loss	Major	07-05-2026 12:49
Pengerang Independent Terminal	Dongle-LAB	TA23B0087782	Network Connection Error	Major	20-04-2026 13:52
Pleasure Latex Phase 2	Logger-102347282208	102347282208	Network Connection Error	Major	19-02-2026 03:00
QL FARM SDN BHD	Logger-102466853213	102466853213	Network Connection Error	Major	24-04-2026 10:56
QL FARM SDN BHD	Inverter 1	ES2580051653	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter 2	ES2580051643	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter3	ES2490076207	Grid Loss	Major	24-04-2026 10:07
QL PAJAM PHASE 2	INV 4	6T2549059627	Grid Loss	Major	14-05-2026 07:45
QL PAJAM PHASE 2	INV 5	6T2559006722	Grid Loss	Major	14-05-2026 07:45

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
REDANG LAGOON RESORT	Dongle-2102312EHS10N9115979	2102312EHS10N9115979	Network Connection Error	Major	30-01-2026 19:29
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	Grid Loss	Major	30-01-2026 07:23
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	Upgrade Failed or Version Mismatch	Minor	19-11-2025 21:35
SJK (C) TSHING NIAN	INV-TA2530374153	TA2530374153	Grid Undervoltage	Major	14-05-2026 06:53
THP MEDICAL	VASOLAR INV 3	6T2279009018	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 2	6T2279008977	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 1	6T2279009011	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
VINDA PHASE 4 (MSB 3-2)	MASTER LOG HT P4	102595350697	Southbound Device Communication Abnormal	Minor	29-04-2026 15:30

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
-	-	-	78.2
AFI BRAKE MANUFACTURING SDN BHD	INV 4 - GROUND FLOOR	HV22B0337098	75.5
AFI BRAKE MANUFACTURING SDN BHD	INV 5 - FIRST FLOOR	HV22B0337097	79.2
AFI BRAKE MANUFACTURING SDN BHD	INV 6 - SECOND FLOOR	HV22A0405534	74.2
AFI BRAKE MANUFACTURING SDN BHD	INV 7 - THIRD FLOOR	HV22B0337096	74.8
AMEBA MGMT	INV-HV2290878023	HV2290878023	70.6
AMT PC DISTRIBUTORS SDN. BHD.	INV-6T22B9024620	6T22B9024620	75.6
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-12)	ES2550064320	76.1
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-13)	ES2550064305	76.1
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-14)	ES2550064253	78.2
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-15)	ES2550064258	80.0
ATS AIR SOLUTION	INV-HV22A0242778	HV22A0242778	74.0
Apex Uniparts	VASOLAR_INV_1	ES2420001215	72.7

Plant Name	Inverter Name	Inverter SN	Temperature
BP PLASTICS BP9	INVERTER 5 (AREA C)	6T24A9018015	72.6
BREMFIELD SDN BHD	INV 1	ES2320221246	71.1
C0102_QL batang kali	150K-MG0(COM3-2)	GR2479026710	74.7
C0102_QL batang kali	150K-MG0(COM3-3)	GR2479026770	74.3
C0149_VERTEX MISSION	HV21B0210137	HV21B0210137	78.5
CHAN KAH WHYE	INV-NS249G082061	NS249G082061	92.4
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 1	6T2569054829	77.7
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 2	ES2580087345	86.5
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 3	6T2569054834	75.9
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 4	ES2580087312	85.5
FOX ONE LOT 14	INV 1	ES2540189953	71.2
Fibertex Phase 2	Inv. CarPark Roof A	ES2420001055	73.4
Fibertex Phase 2	Inverter 1 L3	6T23A9016283	74.1
Fibertex Phase 2	Inverter 4 L3	6T2379019613	71.2
Fibertex Phase 2	Inverter 8 L3	6T2379019736	70.6
Fibertex Phase 2	Inverter 9 L3	6T2379019637	70.0
Fibertex Phase 2	Roof 2C Bridge R1	6T2469046697	70.9
Fungiculture	Inverter 2 (M3)	HV22B0337400	72.3
Fungiculture	Inverter 2 (M4)	HV22B0004571	70.7
Fungiculture	Inveter 2 (M1)	HV22B0337398	71.4
GLASS PLASTIC PACKAGING	INV 2 - (No.23)	6T2489010546	73.8
GLASS PLASTIC PACKAGING	INV 4 - (Lot 65999)	6T2489010593	72.5
Hoon Yuen Furniture	Inverter 1	ES22B0024091	70.2
IOI City Mall Inc. Feeder 1	Inverter 2.1 - TERA	6T22C9011475	70.9
IOI City Mall Inc. Feeder 1	Inverter 2.2 - TERA	6T22B9036192	71.3

Plant Name	Inverter Name	Inverter SN	Temperature
IOI City Mall Inc. Feeder 1	Inverter 2.5 - TERA	6T22C9011507	72.3
IOI City Mall Inc. Feeder 1	Inverter 2.6 - TERA	6T22C9011480	73.5
IOI Knowledge Vision Sdn Bhd	Tera Inverter 1	NS2481218152	72.8
IOI Knowledge Vision Sdn Bhd	Tera Inverter 2	6T2519015499	72.4
IOI Mall Puchong (New Wing)	Inverter 16 - TERA	6T2449030262	76.3
IOI Mall Puchong (New Wing)	Inverter 17 - TERA	6T2479017623	71.5
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	72.0
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	72.9
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	72.4
IOI Mall Puchong (Old Wing)	Inverter 20 - TERA	6T24C9047414	73.4
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	73.0
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	74.5
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	70.0
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	75.8
Jebsen And Jessen Malaysia Sdn Bhd (MHE)	Inverter 2 - Tera	6T2489031215	73.3
Jiann Lih safety product	40KTL-M3(COM1-15)	ES2290059762	85.0
Jiann Lih safety product	40KTL-M3(COM1-16)	ES2290059727	86.2
KISWIRE CORD SDN BHD	VASOLAR_INV_10	6T2269040723	71.8
KISWIRE CORD SDN BHD	VASOLAR_INV_11	6T21A9008894	70.6
KISWIRE CORD SDN BHD	VASOLAR_INV_12	HV22A0243263	73.9
KOSSAN PAINT SDN BHD	Inv 1 (Production)	ES2580051607	77.1
KUASA BAKTI (PETRON SETIA ALAM)	INV-6T2489035314	6T2489035314	78.3
Kamma Klang Enterprise	Inverter 2	HV22A0153968	72.1
Kiara Bay	Inverter 2 - TERA	ES2330110574	73.7
Kiara Bay	Inverter 3 - TERA	6T2449022934	78.3

Plant Name	Inverter Name	Inverter SN	Temperature
Kiara Bay	Inverter 4 - TERA	6T2449023252	81.3
Kiara Bay	Inverter 6 - TERA	ES2350101155	75.6
Kiara Bay	Inverter 8 - TERA	ES2470045868	71.9
Kiara Bay	Inverter 9 - TERA	ES2350101147	74.0
Komplex PKNS Bangi	40KTL-M3(COM1-13)	ES22A0040484	81.3
Komplex PKNS Bangi	50KTL-M3(COM1-14)	6T22A9024868	72.8
LAM SOON EDIBLE OILS	INV-1	6T24A9018029	72.0
LAM SOON EDIBLE OILS	INV-2	6T2449022953	80.1
Marbach Asia Pacific Lot17	INV-6T2489012207	6T2489012207	81.8
Marbach Asia Pacific lot 15	INV-6T2489012205	6T2489012205	78.2
Mitsui Copper Foil P3	Inverter 1 (AREA A)	GR2459039442	72.3
Mitsui Copper Foil P3	Inverter 2 (AREA A)	GR2459039444	72.5
Mitsui Copper Foil P3	Inverter 3 (AREA A)	6T24A9009773	81.8
Mitsui Copper Foil P3	Inverter 4 (AREA A)	6T24A9013004	78.6
Mitsui Copper Foil P3	Inverter 5 (AREA B)	6T2519017589	74.4
Multi Choice (M) Sdn Bhd	TERA INV 3	ES2560208616	70.9
New Age 160	INV 1	6T2469012777	72.6
New Age 160	Inverter 2 R1	6T23B9005979	77.4
New Age 160	Inverter 3-36ktl m3	6T2489036764	74.4
P.A Food Sdn Bhd 2ATKT	INV-ES2420001275	ES2420001275	82.5
P.A Food Sdn Bhd Lot 10	INV-6T2449029469	6T2449029469	77.9
P.A Food Sdn Bhd Lot 12	INV-6T2449029471	6T2449029471	80.8
P.A. Food Warehouse No. 9	INV-HV2290797189	HV2290797189	73.0
PKT 8 WAVES	Inverter_2	6T2439012020	81.0
PKT THE SHIP	Inverter_3	6T2379019623	74.2

Plant Name	Inverter Name	Inverter SN	Temperature
PKT THE SHIP	Inverter_4	6T2379019776	70.8
PKT THE SHIP	Inverter_5	6T2379019768	71.3
PKT THE SHIP	Inverter_6	6T2379019622	71.4
PKT THE SHIP	Inverter_7	6T2379019759	70.0
PKT THE SHIP	Inverter_8 R1	ES24C0173071	75.4
Pengerang Independent Terminal	VASOLAR INV 4 CP 2	6T23A9016705	72.0
Pengerang Independent Terminal	VASOLAR INV7 MC	ES2340146422	80.7
Pengerang Independent Terminal	VASOLAR INV8 LCS304	ES2410011406	71.2
Pengerang Independent Terminal	VASOLAR INV9 LCS304	ES2410011693	70.3
QL FOODS	INVERTER_10	6T2449032177	72.0
QL Maxincome	Inverter 1	6T2449023173	74.1
QL Maxincome	Inverter 2	6T2489021016	72.3
QL PAJAM PHASE 2	INV 4	6T2549059627	71.1
QI Lot 16	INV-ES24A0149130	ES24A0149130	76.9
ROYAL KLANG CLUB	Inverter 1	6T2559006760	74.5
RS POLY INDUSTRY	VASOLAR INV 1	ES2420000999	77.5
RS POLY INDUSTRY	VASOLAR INV 2	ES2420001084	74.9
SABAH CHINESE HIGH SCHOOL (TAK YUEN BUILDING)	50KTL-M3(COM1-2)	ES22A0076308	76.5
SCENT PUR MANUFACTURING SDN BHD NO.35	INV-TA2470078151	TA2470078151	74.8
SCENT PUR MANUFACTURING SDN BHD NO.37	INV-NS245G038275	NS245G038275	85.9
SJK (C) WU TECK	INV 1	6T25B9000135	86.2
SJK ■ C ■ PIN HWA 1	INVERTER-2	ES2560208642	83.8
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-3)	ES2190075764	70.0
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-4)	ES2190080965	73.3
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-5)	ES2190075672	72.5

Plant Name	Inverter Name	Inverter SN	Temperature
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-6)	ES2190081021	70.4
SP Logistics Sdn Bhd	INV-6T23B9005457	6T23B9005457	72.3
San Soon Seng Food Industries Sdn Bhd	Inv 02 (Racking WH)	6T2549057201	75.4
San Soon Seng Food Industries Sdn Bhd	Inv 04 (GP 2B)	ES24A0060037	70.7
Succesfuel Sdn. Bhd.	INVERTER 1 R1	6T24C9072224	78.2
THOR SPECIALTIES	INV-ES25C0123936	ES25C0123936	72.9
TOMEI	INV-(12-1)	HV2330348462	85.7
TOMEI	INV-(16-1)	HV2330348376	85.1
TOMEI	INV-(4-1)	HV2330348450	82.3
TOMEI	INV-(4-2)	HV2330348386	84.1
TOMEI	INV-(4-3)	HV2330348461	79.3
TOMEI	INV-(6-1)	HV2330348465	80.9
TOMEI	INV-(8)	HV2330348453	81.5
TOMEI	INV-(8-2)	HV2330348466	80.1
TOMEI	INV-(8-3)	HV2330348451	79.2
UC BLASTING PAINTING	VASOLAR_INV_3	6T2359030790	70.9
VINDA PHASE 4 (MSB 3-2)	Inverter11 - Phase 4	GR2479020739	70.6
VISKO INDUSTRIES SDN BHD	VASOLAR_INV_8	ES2180084993	70.9
Vinda Phase 1 and 2 (MSB 2)	Inverter 7 - Phase 1	6T21C9025215	70.4
WCS UNIT 6	INVERTER UNIT 6	HV2290931617	70.1