

FusionSolar Troubleshooting Report

Date: 16-05-2026
Generated At: 16-05-2026 08:30:08
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	2
Total low-performing inverters	54
Total low-performing strings	218
Total alarms	48
Total high-temperature inverters	23

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
MAJOR ENGINEERING Lot 10	2.12	2.37	-10.55
MAJOR ENGINEERING Lot 8	1.04	2.37	-56.12

Low-performing Inverters

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	1.950	2.376	17.93
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	2.507	2.881	12.98
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	2.543	2.881	11.73
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	2.580	2.881	10.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	1.734	2.037	14.87
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	1.736	2.037	14.78

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	1.728	2.037	15.17
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	1.712	2.037	15.95
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	1.729	2.037	15.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	1.725	2.037	15.32
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	1.724	2.037	15.37
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	1.735	2.037	14.83
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	1.733	2.037	14.92
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	1.725	2.037	15.32
IOI MALL PUCHONG (NEW WING) PHASE 2	Inverter 4	NE=82071817	0.187	2.530	92.61
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	1.780	2.825	36.99
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	1.977	2.825	30.02
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	1.951	2.825	30.94
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	1.935	2.825	31.50
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	1.674	2.825	40.74
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	1.985	2.825	29.73
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	1.969	2.825	30.30
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	1.831	2.825	35.19
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	1.902	2.825	32.67
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	1.955	2.825	30.80
IOI MALL PUCHONG (OLD WING)	Inverter 7 - TERA	NE=57818391	1.926	2.825	31.82
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	1.921	2.825	32.00
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	1.938	2.825	31.40
KIARA BAY	Inverter 1 - TERA	NE=55735156	2.003	2.287	12.42
KIARA BAY	Inverter 10 - TERA	NE=55735154	1.232	2.287	46.13
KIARA BAY	Inverter 11 - TERA	NE=55735153	1.274	2.287	44.29

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
KIARA BAY	Inverter 3 - TERA	NE=55735162	1.807	2.287	20.99
KIARA BAY	Inverter 4 - TERA	NE=55735161	1.683	2.287	26.41
KIARA BAY	Inverter 5 - TERA	NE=55735155	1.826	2.287	20.16
KIARA BAY	Inverter 6 - TERA	NE=55735160	1.248	2.287	45.43
KIARA BAY	Inverter 7 - TERA	NE=55735157	1.474	2.287	35.55
KIARA BAY	Inverter 8 - TERA	NE=55735158	1.426	2.287	37.65
KIARA BAY	Inverter 9 - TERA	NE=55735159	1.180	2.287	48.40
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	1.675	2.121	21.03
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	1.458	2.121	31.26
QL FOODS	INVERTER_10	NE=53679611	1.926	2.460	21.71
QL FOODS	INVERTER_15	NE=53679053	2.099	2.460	14.67
QL FOODS	INVERTER_3	NE=53678487	2.194	2.460	10.81
QL FOODS	INVERTER_7	NE=53676713	1.979	2.460	19.55
QL FOODS	INVERTER_9	NE=53679667	2.079	2.460	15.49
TEONG HUAT MEDICAL	TERA INV 1	NE=79838602	3.012	3.402	11.46
TEONG HUAT MEDICAL	TERA INV 4	NE=79838604	3.011	3.402	11.49
TOMEI	INV-(10-2)	NE=54352010	1.500	1.855	19.14
TOMEI	INV-(10-3)	NE=54351494	1.231	1.855	33.64
TOMEI	INV-(16-2)	NE=54352004	1.392	1.855	24.96
TOMEI	INV-(4)	NE=55086008	1.594	1.855	14.07
TOMEI	INV-(4-3)	NE=54351850	1.304	1.855	29.70
TOMEI	INV-(6-3)	NE=54351644	1.443	1.855	22.21
TOMEI	INV-(8-3)	NE=54351578	1.331	1.855	28.25

Low-performing Strings

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV11 input current(A)	266.610	388.120	31.31
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV13 input current(A)	266.000	388.120	31.46
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV15 input current(A)	278.560	388.120	28.23
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV17 input current(A)	207.380	388.120	46.57
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV18 input current(A)	-1.470	388.120	100.38
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV19 input current(A)	237.030	388.120	38.93
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV20 input current(A)	-1.790	388.120	100.46
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV7 input current(A)	264.130	388.120	31.95
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV9 input current(A)	300.330	388.120	22.62
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV11 input current(A)	1.880	383.060	99.51
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV13 input current(A)	2.340	383.060	99.39
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV15 input current(A)	1.220	383.060	99.68
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV17 input current(A)	2.730	383.060	99.29
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV19 input current(A)	2.270	383.060	99.41
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV3 input current(A)	2.430	383.060	99.37
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV5 input current(A)	1.460	383.060	99.62

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV7 input current(A)	1.560	383.060	99.59
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV9 input current(A)	2.150	383.060	99.44
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV input current(A) 6	6.000	390.600	98.46
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV11 input current(A)	1.010	390.600	99.74
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV13 input current(A)	1.940	390.600	99.50
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV15 input current(A)	1.380	390.600	99.65
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV17 input current(A)	4.890	390.600	98.75
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV3 input current(A)	2.150	390.600	99.45
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV5 input current(A)	2.110	390.600	99.46
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV7 input current(A)	1.380	390.600	99.65
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV9 input current(A)	1.940	390.600	99.50
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV input current(A) 4	4.000	393.890	98.98
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV11 input current(A)	1.440	393.890	99.63
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV13 input current(A)	1.950	393.890	99.50
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV15 input current(A)	1.350	393.890	99.66
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV17 input current(A)	2.730	393.890	99.31

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV19 input current(A)	2.290	393.890	99.42
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV3 input current(A)	2.450	393.890	99.38
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV5 input current(A)	1.480	393.890	99.62
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV7 input current(A)	2.100	393.890	99.47
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV9 input current(A)	1.970	393.890	99.50
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV input current(A) 2	4.000	233.920	98.29
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV10 input current(A)	-1.140	233.920	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV14 input current(A)	-1.040	233.920	100.44
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV16 input current(A)	-1.060	233.920	100.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV19 input current(A)	103.870	233.920	55.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV20 input current(A)	-1.800	233.920	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV input current(A) 2	2.000	243.150	99.18
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV16 input current(A)	-1.120	243.150	100.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV18 input current(A)	-1.320	243.150	100.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV2 input current(A)	189.480	243.150	22.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV20 input current(A)	-1.640	243.150	100.67

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV4 input current(A)	188.820	243.150	22.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV input current(A) 2	4.000	216.910	98.16
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV input current(A) 3	3.000	216.910	98.62
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV10 input current(A)	-1.320	216.910	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV12 input current(A)	-1.130	216.910	100.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV14 input current(A)	-1.060	216.910	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV16 input current(A)	-1.450	216.910	100.67
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV20 input current(A)	-1.790	216.910	100.83
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV6 input current(A)	-1.530	216.910	100.71
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV input current(A) 2	6.000	219.410	97.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV18 input current(A)	-1.110	219.410	100.51
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV input current(A) 2	2.000	233.620	99.14
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV input current(A) 3	3.000	233.620	98.72
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV12 input current(A)	-1.530	233.620	100.65
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV20 input current(A)	-1.090	233.620	100.47
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV9 input current(A)	182.190	233.620	22.01

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV input current(A) 2	2.000	226.910	99.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV10 input current(A)	-1.010	226.910	100.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV12 input current(A)	-1.550	226.910	100.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV14 input current(A)	-1.050	226.910	100.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV16 input current(A)	-1.140	226.910	100.50
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV18 input current(A)	-1.260	226.910	100.56
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV20 input current(A)	-1.720	226.910	100.76
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV6 input current(A)	-1.330	226.910	100.59
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV8 input current(A)	-1.740	226.910	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 1	2.000	235.090	99.15
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 2	2.000	235.090	99.15
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV10 input current(A)	-1.800	235.090	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV12 input current(A)	-1.470	235.090	100.63
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV14 input current(A)	-1.240	235.090	100.53
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV16 input current(A)	-1.380	235.090	100.59
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV18 input current(A)	-1.080	235.090	100.46

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV20 input current(A)	-2.130	235.090	100.91
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV6 input current(A)	-1.280	235.090	100.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV8 input current(A)	-1.930	235.090	100.82
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV10 input current(A)	-1.140	236.580	100.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV12 input current(A)	-1.260	236.580	100.53
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV16 input current(A)	-1.780	236.580	100.75
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV18 input current(A)	-1.980	236.580	100.84
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV20 input current(A)	-2.000	236.580	100.85
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV6 input current(A)	-1.660	236.580	100.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV8 input current(A)	-1.150	236.580	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV9 input current(A)	176.650	236.580	25.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV input current(A) 2	6.000	228.740	97.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV12 input current(A)	-1.120	228.740	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV20 input current(A)	-1.570	228.740	100.69
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV8 input current(A)	-1.400	228.740	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV9 input current(A)	157.220	228.740	31.27

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV input current(A) 2	2.000	227.990	99.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV input current(A) 3	3.000	227.990	98.68
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV input current(A) 4	4.000	311.680	98.72
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV4 input current(A)	233.160	311.680	25.19
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV12 input current(A)	-1.200	318.810	100.38
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV14 input current(A)	-1.010	318.810	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV16 input current(A)	-1.850	318.810	100.58
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV10 input current(A)	-1.140	314.300	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV12 input current(A)	-1.480	314.300	100.47
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV14 input current(A)	-1.010	314.300	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV16 input current(A)	-4.670	314.300	101.49
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV8 input current(A)	-1.060	314.300	100.34
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV10 input current(A)	-1.540	319.300	100.48
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV14 input current(A)	-1.080	319.300	100.34
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV16 input current(A)	-5.140	319.300	101.61
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV6 input current(A)	-2.550	319.300	100.80
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV8 input current(A)	-1.480	319.300	100.46
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV9 input current(A)	252.220	319.300	21.01
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV2 input current(A)	192.510	296.770	35.13
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV12 input current(A)	-1.020	322.100	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV8 input current(A)	-1.700	322.100	100.53
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV10 input current(A)	-1.020	319.590	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV12 input current(A)	-1.390	319.590	100.43

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV16 input current(A)	-1.490	319.590	100.47
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV18 input current(A)	-1.080	319.590	100.34
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV20 input current(A)	-1.670	319.590	100.52
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV8 input current(A)	-1.880	319.590	100.59
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV input current(A) 4	4.000	314.370	98.73
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV input current(A) 7	7.000	314.370	97.77
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV10 input current(A)	-1.100	314.370	100.35
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV12 input current(A)	-1.610	314.370	100.51
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV14 input current(A)	-1.650	314.370	100.52
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV16 input current(A)	-5.530	314.370	101.76
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV4 input current(A)	235.610	314.370	25.05
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV6 input current(A)	-1.610	314.370	100.51
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV8 input current(A)	-2.070	314.370	100.66
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV12 input current(A)	-1.150	315.610	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV16 input current(A)	-1.040	315.610	100.33
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV8 input current(A)	-1.370	315.610	100.43
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV10 input current(A)	-1.110	320.370	100.35
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV12 input current(A)	-1.950	320.370	100.61
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV14 input current(A)	-1.140	320.370	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV16 input current(A)	-4.950	320.370	101.55
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV20 input current(A)	-1.160	320.370	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV input current(A) 4	4.000	316.750	98.74
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV12 input current(A)	241.470	316.750	23.77

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV15 input current(A)	252.270	316.750	20.36
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV input current(A) 2	2.000	313.240	99.36
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV12 input current(A)	-2.300	313.240	100.73
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV16 input current(A)	-2.000	313.240	100.64
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV18 input current(A)	-1.560	313.240	100.50
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV input current(A) 4	4.000	441.090	99.09
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV11 input current(A)	1.560	441.090	99.65
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV13 input current(A)	1.330	441.090	99.70
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV15 input current(A)	2.100	441.090	99.52
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV17 input current(A)	1.450	441.090	99.67
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV19 input current(A)	1.320	441.090	99.70
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV3 input current(A)	1.590	441.090	99.64
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV5 input current(A)	1.370	441.090	99.69
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV7 input current(A)	1.450	441.090	99.67
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV9 input current(A)	1.350	441.090	99.69
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV input current(A) 2	2.000	379.560	99.47
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV11 input current(A)	2.580	379.560	99.32
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV13 input current(A)	1.960	379.560	99.48
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV15 input current(A)	2.450	379.560	99.35
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV17 input current(A)	2.200	379.560	99.42
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV19 input current(A)	1.970	379.560	99.48
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV5 input current(A)	1.840	379.560	99.52
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV7 input current(A)	1.980	379.560	99.48
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV9 input current(A)	1.930	379.560	99.49
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV input current(A) 2	2.000	379.260	99.47

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV11 input current(A)	2.290	379.260	99.40
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV13 input current(A)	2.310	379.260	99.39
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV15 input current(A)	2.430	379.260	99.36
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV17 input current(A)	2.190	379.260	99.42
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV19 input current(A)	2.010	379.260	99.47
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV3 input current(A)	2.240	379.260	99.41
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV5 input current(A)	2.320	379.260	99.39
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV7 input current(A)	2.000	379.260	99.47
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV9 input current(A)	2.020	379.260	99.47
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV input current(A) 3	6.000	447.140	98.66
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV2 input current(A)	-5.550	447.140	101.24
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV4 input current(A)	-3.030	447.140	100.68
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV6 input current(A)	-2.380	447.140	100.53
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV8 input current(A)	-2.220	447.140	100.50
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV11 input current(A)	1.930	428.620	99.55
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV13 input current(A)	2.620	428.620	99.39
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV15 input current(A)	1.730	428.620	99.60
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV17 input current(A)	1.870	428.620	99.56
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV3 input current(A)	1.600	428.620	99.63
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV5 input current(A)	1.970	428.620	99.54
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV7 input current(A)	2.430	428.620	99.43
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV input current(A) 3	3.000	400.500	99.25
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV4 input current(A)	-1.750	400.500	100.44
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV8 input current(A)	-1.500	400.500	100.37
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV input current(A) 4	4.000	389.430	98.97

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV10 input current(A)	306.900	389.430	21.19
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV11 input current(A)	1.660	389.430	99.57
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV13 input current(A)	2.260	389.430	99.42
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV15 input current(A)	2.250	389.430	99.42
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV17 input current(A)	2.500	389.430	99.36
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV19 input current(A)	2.280	389.430	99.41
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV5 input current(A)	1.760	389.430	99.55
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV7 input current(A)	2.150	389.430	99.45
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV9 input current(A)	2.880	389.430	99.26
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV input current(A) 2	2.000	374.140	99.47
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV11 input current(A)	2.130	374.140	99.43
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV13 input current(A)	2.740	374.140	99.27
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV15 input current(A)	2.390	374.140	99.36
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV17 input current(A)	5.710	374.140	98.47
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV19 input current(A)	2.800	374.140	99.25
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV3 input current(A)	2.910	374.140	99.22
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV5 input current(A)	2.550	374.140	99.32
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV7 input current(A)	2.610	374.140	99.30
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV9 input current(A)	2.520	374.140	99.33
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV4 input current(A)	-1.500	370.700	100.40
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV8 input current(A)	-1.040	370.700	100.28
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV2 input current(A)	256.460	417.020	38.50
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV3 input current(A)	307.900	417.020	26.17

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV5 input current(A)	314.630	417.020	24.55
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV1 input current(A)	210.500	366.150	42.51
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV3 input current(A)	187.250	366.150	48.86

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
AFI METAL	Dongle-TA2340291486	TA2340291486	Network Connection Error	Major	14-05-2026 22:36
BIMB Bdr Penawar - 1st Floor	Dongle- INV1	BT24C0060244	Network Connection Error	Major	15-04-2026 18:07
BOILERMECH LOT 873	Logger-102516002824	102516002824	Network Connection Error	Major	13-05-2026 12:52
BP PLASTICS BP9	Logger-102556511876	102556511876	Network Connection Error	Major	10-05-2026 16:38
C0149_VERTEX MISSION	HV21B0210137	HV21B0210137	Grid Loss	Major	15-05-2026 10:25
C0172_ATRIA SOUTH	Logger-102256528212	102256528212	Network Connection Error	Major	08-05-2026 01:02
C0176_GETHA	Logger-102256528260	102256528260	Network Connection Error	Major	28-04-2026 21:09
Fibertex Phase 2	Inverter 2 L3 Old	6T2379019735	Upgrade Failed or Version Mismatch	Minor	18-07-2025 15:24
GUH METER 1	VASOLAR_INV_1	6T2379018351	Abnormal External Fan	Major	15-05-2026 10:23
IOI Mall Puchong (Old Wing)	Inverter 21 R1-TERA	6T2599057796	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 3 R1 - TERA	BN2521059950	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 2 - TERA	BN2461066770	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 4 - TERA	6T2479017517	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 1 - TERA	BN2461065466	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
IOI Mall Puchong (Old Wing)	Inverter 5 - TERA	BN2461066760	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
LIAN FOO POULTRY FARM SDN BHD	Dongle-BT2541519026	BT2541519026	Network Connection Error	Major	30-04-2026 18:40
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	Grid Loss	Major	30-04-2026 17:55
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	Grid Loss	Major	30-04-2026 17:54
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	Grid Loss	Major	30-04-2026 17:54
Lian Teck Seng Lot 11	Dongle-BT24C0060275	BT24C0060275	Network Connection Error	Major	29-01-2026 15:54
MARINE GOLD SDN BHD	Dongle-TA2340293153	TA2340293153	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340293476	TA2340293476	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340291437	TA2340291437	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-HV2310776105	HV2310776105	Network Connection Error	Major	26-03-2026 14:56
MARINE GOLD SDN BHD	Dongle-HV2310776109	HV2310776109	Network Connection Error	Major	26-03-2026 14:55
MARINE GOLD SDN BHD	Dongle-HV2310773587	HV2310773587	Network Connection Error	Major	26-03-2026 14:54
MENARA PKNS PJ	Logger-102466288020	102466288020	Network Connection Error	Major	10-05-2026 01:00
Pengerang Independent Terminal	Dongle-LAB	TA23B0087782	Network Connection Error	Major	20-04-2026 13:52
Pleasure Latex Phase 2	Logger-102347282208	102347282208	Network Connection Error	Major	19-02-2026 03:00
QL FARM SDN BHD	Logger-102466853213	102466853213	Network Connection Error	Major	24-04-2026 10:56
QL FARM SDN BHD	Inverter 1	ES2580051653	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter 2	ES2580051643	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter3	ES2490076207	Grid Loss	Major	24-04-2026 10:07
REDANG LAGOON RESORT	Dongle-2102312EHS10N9115979	2102312EHS10N9115979	Network Connection Error	Major	30-01-2026 19:29
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	Grid Loss	Major	30-01-2026 07:23

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	Upgrade Failed or Version Mismatch	Minor	19-11-2025 21:35
SJK (C) TSHING NIAN	INV-TA2530374153	TA2530374153	Grid Loss	Major	15-05-2026 06:52
THP MEDICAL	VASOLAR INV 3	6T2279009018	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 2	6T2279008977	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 1	6T2279009011	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
VINDA PHASE 4 (MSB 3-2)	MASTER LOG HT P4	102595350697	Southbound Device Communication Abnormal	Minor	29-04-2026 15:30

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
AFI BRAKE MANUFACTURING SDN BHD	INV 4 - GROUND FLOOR	HV22B0337098	80.6
AFI BRAKE MANUFACTURING SDN BHD	INV 5 - FIRST FLOOR	HV22B0337097	82.7
AFI BRAKE MANUFACTURING SDN BHD	INV 6 - SECOND FLOOR	HV22A0405534	78.3
AFI BRAKE MANUFACTURING SDN BHD	INV 7 - THIRD FLOOR	HV22B0337096	75.5
CHAN KAH WHYE	INV-NS249G082061	NS249G082061	75.7
Durasafe Sdn. Bhd.	INV 1-6T2479002464	6T2479002464	78.3
Durasafe Sdn. Bhd.	INV 2-6T2469038783	6T2469038783	73.5
Farm Fresh Taiping (Factory)	50KTL-M3(COM1-12)	6T22A9038815	75.7
GLASS PLASTIC PACKAGING	INV 2 - (No.23)	6T2489010546	77.6
GLASS PLASTIC PACKAGING	INV 3 - (Lot 65999)	6T2489010635	73.1
GLASS PLASTIC PACKAGING	INV 4 - (Lot 65999)	6T2489010593	75.5
KB AIS SDN. BHD.	Inverter-1	6T21C9025324	71.5
KOSSAN PAINT SDN BHD	Inv 1 (Production)	ES2580051607	73.0
Multi Choice (M) Sdn Bhd	TERA INV 3	ES2560208616	73.5
New Age 160	Inverter 2 R1	6T23B9005979	70.1

Plant Name	Inverter Name	Inverter SN	Temperature
QL FOODS	INVERTER_10	6T2449032177	76.0
QL FOODS	INVERTER_7	6T22A9046723	72.0
QL FOODS	TERA INV2_HOSTEL	6T2599013072	73.3
SABAH CHINESE HIGH SCHOOL (TAK YUEN BUILDING)	50KTL-M3(COM1-2)	ES22A0076308	78.4
SCENT PUR MANUFACTURING SDN BHD NO.37	INV-NS245G038275	NS245G038275	71.7
SJK ■ C ■ PIN HWA 1	INVERTER-2	ES2560208642	70.8
San Soon Seng Food Industries Sdn Bhd	Inv 02 (Racking WH)	6T2549057201	71.8
Teong Huat Medical	INV-6T2599029908	6T2599029908	71.9