

FusionSolar Troubleshooting Report

Date: 17-05-2026
Generated At: 17-05-2026 08:30:08
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	30
Total low-performing inverters	16
Total low-performing strings	218
Total alarms	64
Total high-temperature inverters	5

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
ASHITA COMMUNICATION	0.00	2.10	-100.00
BIMB Bdr Penawar - 1st Floor	0.00	0.26	-100.00
BJC FOOD (MALAYSIA) SDN. BHD.	1.67	2.50	-33.16
BOILERMECH LOT 873	0.00	1.10	-100.00
BP PLASTICS BP9	1.09	1.41	-22.51
C0149_VERTEX MISSION	1.99	2.36	-15.56
C0172_ATRIA SOUTH	0.00	1.75	-100.00
DSG Malaysia Sdn. Bhd	1.68	2.20	-23.52
KISWIRE CORD PHASE 1 (DATA)	0.00	0.39	-100.00
Kwang Hua Persendirian meter 2-3-4-5-6	1.55	2.10	-26.21
Lau and Tan Pharmacy (G.Floor)	2.27	2.65	-14.18

Plant Name	Plant PSH	City Average PSH	Deviation
Lian Teck Seng Lot 11	0.00	2.10	-100.00
MAJOR ENGINEERING Lot 8	0.87	2.10	-58.58
MARINE GOLD SDN BHD	0.00	2.03	-100.00
MENARA PKNS PJ	0.00	1.12	-100.00
MAIW FRESH	0.00	2.10	-100.00
Mitsui Copper Foil P3	2.18	2.50	-12.75
Pleasure Latex Phase 2	0.00	1.45	-100.00
QL FARM SDN BHD	0.00	1.50	-100.00
REDANG LAGOON RESORT	0.00	1.87	-100.00
SABAH CHINESE HIGH SCHOOL (CANTEEN)	1.27	1.50	-15.33
SJK (C) TSHING NIAN	1.26	2.23	-43.37
SUCCESS ELECTRONIC LOT 5	0.93	1.12	-16.96
SUCCESS ELECTRONIC LOT 7	1.91	2.38	-19.92
SWEE CHEONG WATCH SDN BHD (Meter 2)	3.84	4.39	-12.46
TIMURIKAN TRENGGANU MARINE PRODUCTS SDN BHD	0.70	1.28	-45.31
Toa Paint Kepong Warehouse	2.13	2.47	-13.77
UCS_Block A	1.98	2.26	-12.56
WASCO PIPE SDN BHD (COATING)	0.35	0.77	-54.84
WEIDA MARKETING SDN. BHD.	2.03	2.40	-15.42

Low-performing Inverters

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	1.604	1.880	14.68
BJC FOOD (MALAYSIA) SDN. BHD.	60KTL-M0(COM1-3)	NE=50476042	1.440	1.880	23.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	1.295	2.214	41.51

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	1.280	2.214	42.19
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	1.286	2.214	41.92
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	1.282	2.214	42.10
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	1.275	2.214	42.41
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	1.287	2.214	41.87
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	1.285	2.214	41.96
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	1.288	2.214	41.82
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	1.289	2.214	41.78
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	1.282	2.214	42.10
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	1.625	2.034	20.11
SJK (C) TSHING NIAN	INV-TA2530374153	NE=77389280	0.000	2.592	100.00
SUCCESS ELECTRONIC LOT 5	TERA INVERTER 3	NE=73355202	0.832	1.035	19.61
SUCCESS ELECTRONIC LOT 7	TERA INVERTER 5	NE=73651978	1.851	2.068	10.49

Low-performing Strings

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV11 input current(A)	266.610	388.120	31.31
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV13 input current(A)	266.000	388.120	31.46
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV15 input current(A)	278.560	388.120	28.23
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV17 input current(A)	207.380	388.120	46.57
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV18 input current(A)	-1.470	388.120	100.38

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV19 input current(A)	237.030	388.120	38.93
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV20 input current(A)	-1.790	388.120	100.46
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV7 input current(A)	264.130	388.120	31.95
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV9 input current(A)	300.330	388.120	22.62
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV11 input current(A)	1.880	383.060	99.51
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV13 input current(A)	2.340	383.060	99.39
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV15 input current(A)	1.220	383.060	99.68
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV17 input current(A)	2.730	383.060	99.29
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV19 input current(A)	2.270	383.060	99.41
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV3 input current(A)	2.430	383.060	99.37
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV5 input current(A)	1.460	383.060	99.62
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV7 input current(A)	1.560	383.060	99.59
BP PLASTICS BP9	INVERTER 1 (AREA C)	NE=60208482	PV9 input current(A)	2.150	383.060	99.44
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV input current(A) 6	6.000	390.600	98.46
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV11 input current(A)	1.010	390.600	99.74
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV13 input current(A)	1.940	390.600	99.50

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV15 input current(A)	1.380	390.600	99.65
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV17 input current(A)	4.890	390.600	98.75
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV3 input current(A)	2.150	390.600	99.45
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV5 input current(A)	2.110	390.600	99.46
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV7 input current(A)	1.380	390.600	99.65
BP PLASTICS BP9	INVERTER 2 (AREA C)	NE=60208484	PV9 input current(A)	1.940	390.600	99.50
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV input current(A) 4	4.000	393.890	98.98
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV11 input current(A)	1.440	393.890	99.63
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV13 input current(A)	1.950	393.890	99.50
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV15 input current(A)	1.350	393.890	99.66
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV17 input current(A)	2.730	393.890	99.31
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV19 input current(A)	2.290	393.890	99.42
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV3 input current(A)	2.450	393.890	99.38
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV5 input current(A)	1.480	393.890	99.62
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV7 input current(A)	2.100	393.890	99.47
BP PLASTICS BP9	INVERTER 3 (AREA C)	NE=60208483	PV9 input current(A)	1.970	393.890	99.50

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV input current(A) 2	4.000	233.920	98.29
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV10 input current(A)	-1.140	233.920	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV14 input current(A)	-1.040	233.920	100.44
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV16 input current(A)	-1.060	233.920	100.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV19 input current(A)	103.870	233.920	55.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV20 input current(A)	-1.800	233.920	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV input current(A) 2	2.000	243.150	99.18
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV16 input current(A)	-1.120	243.150	100.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV18 input current(A)	-1.320	243.150	100.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV2 input current(A)	189.480	243.150	22.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV20 input current(A)	-1.640	243.150	100.67
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV4 input current(A)	188.820	243.150	22.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV input current(A) 2	4.000	216.910	98.16
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV input current(A) 3	3.000	216.910	98.62
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV10 input current(A)	-1.320	216.910	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV12 input current(A)	-1.130	216.910	100.52

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV14 input current(A)	-1.060	216.910	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV16 input current(A)	-1.450	216.910	100.67
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV20 input current(A)	-1.790	216.910	100.83
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV6 input current(A)	-1.530	216.910	100.71
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV input current(A) 2	6.000	219.410	97.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV18 input current(A)	-1.110	219.410	100.51
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV input current(A) 2	2.000	233.620	99.14
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV input current(A) 3	3.000	233.620	98.72
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV12 input current(A)	-1.530	233.620	100.65
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV20 input current(A)	-1.090	233.620	100.47
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV9 input current(A)	182.190	233.620	22.01
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV input current(A) 2	2.000	226.910	99.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV10 input current(A)	-1.010	226.910	100.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV12 input current(A)	-1.550	226.910	100.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV14 input current(A)	-1.050	226.910	100.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV16 input current(A)	-1.140	226.910	100.50

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV18 input current(A)	-1.260	226.910	100.56
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV20 input current(A)	-1.720	226.910	100.76
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV6 input current(A)	-1.330	226.910	100.59
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV8 input current(A)	-1.740	226.910	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 1	2.000	235.090	99.15
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 2	2.000	235.090	99.15
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV10 input current(A)	-1.800	235.090	100.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV12 input current(A)	-1.470	235.090	100.63
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV14 input current(A)	-1.240	235.090	100.53
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV16 input current(A)	-1.380	235.090	100.59
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV18 input current(A)	-1.080	235.090	100.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV20 input current(A)	-2.130	235.090	100.91
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV6 input current(A)	-1.280	235.090	100.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV8 input current(A)	-1.930	235.090	100.82
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV10 input current(A)	-1.140	236.580	100.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV12 input current(A)	-1.260	236.580	100.53

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV16 input current(A)	-1.780	236.580	100.75
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV18 input current(A)	-1.980	236.580	100.84
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV20 input current(A)	-2.000	236.580	100.85
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV6 input current(A)	-1.660	236.580	100.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV8 input current(A)	-1.150	236.580	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV9 input current(A)	176.650	236.580	25.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV input current(A) 2	6.000	228.740	97.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV12 input current(A)	-1.120	228.740	100.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV20 input current(A)	-1.570	228.740	100.69
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV8 input current(A)	-1.400	228.740	100.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV9 input current(A)	157.220	228.740	31.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV input current(A) 2	2.000	227.990	99.12
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV input current(A) 3	3.000	227.990	98.68
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV input current(A) 4	4.000	311.680	98.72
IOI MALL PUCHONG (OLD WING)	Inverter 1 - TERA	NE=57818394	PV4 input current(A)	233.160	311.680	25.19
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV12 input current(A)	-1.200	318.810	100.38
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV14 input current(A)	-1.010	318.810	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 10 - TERA	NE=57818392	PV16 input current(A)	-1.850	318.810	100.58

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV10 input current(A)	-1.140	314.300	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV12 input current(A)	-1.480	314.300	100.47
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV14 input current(A)	-1.010	314.300	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV16 input current(A)	-4.670	314.300	101.49
IOI MALL PUCHONG (OLD WING)	Inverter 11 - TERA	NE=57818399	PV8 input current(A)	-1.060	314.300	100.34
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV10 input current(A)	-1.540	319.300	100.48
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV14 input current(A)	-1.080	319.300	100.34
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV16 input current(A)	-5.140	319.300	101.61
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV6 input current(A)	-2.550	319.300	100.80
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV8 input current(A)	-1.480	319.300	100.46
IOI MALL PUCHONG (OLD WING)	Inverter 12 - TERA	NE=57818390	PV9 input current(A)	252.220	319.300	21.01
IOI MALL PUCHONG (OLD WING)	Inverter 18 - TERA	NE=57818401	PV2 input current(A)	192.510	296.770	35.13
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV12 input current(A)	-1.020	322.100	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 2 - TERA	NE=57818389	PV8 input current(A)	-1.700	322.100	100.53
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV10 input current(A)	-1.020	319.590	100.32
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV12 input current(A)	-1.390	319.590	100.43
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV16 input current(A)	-1.490	319.590	100.47
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV18 input current(A)	-1.080	319.590	100.34
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV20 input current(A)	-1.670	319.590	100.52
IOI MALL PUCHONG (OLD WING)	Inverter 3 R1 - TERA	NE=60013298	PV8 input current(A)	-1.880	319.590	100.59
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV input current(A) 4	4.000	314.370	98.73
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV input current(A) 7	7.000	314.370	97.77

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV10 input current(A)	-1.100	314.370	100.35
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV12 input current(A)	-1.610	314.370	100.51
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV14 input current(A)	-1.650	314.370	100.52
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV16 input current(A)	-5.530	314.370	101.76
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV4 input current(A)	235.610	314.370	25.05
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV6 input current(A)	-1.610	314.370	100.51
IOI MALL PUCHONG (OLD WING)	Inverter 4 - TERA	NE=57818393	PV8 input current(A)	-2.070	314.370	100.66
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV12 input current(A)	-1.150	315.610	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV16 input current(A)	-1.040	315.610	100.33
IOI MALL PUCHONG (OLD WING)	Inverter 5 - TERA	NE=57818395	PV8 input current(A)	-1.370	315.610	100.43
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV10 input current(A)	-1.110	320.370	100.35
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV12 input current(A)	-1.950	320.370	100.61
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV14 input current(A)	-1.140	320.370	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV16 input current(A)	-4.950	320.370	101.55
IOI MALL PUCHONG (OLD WING)	Inverter 6 - TERA	NE=57818396	PV20 input current(A)	-1.160	320.370	100.36
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV input current(A) 4	4.000	316.750	98.74
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV12 input current(A)	241.470	316.750	23.77
IOI MALL PUCHONG (OLD WING)	Inverter 8 - TERA	NE=57818397	PV15 input current(A)	252.270	316.750	20.36
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV input current(A) 2	2.000	313.240	99.36
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV12 input current(A)	-2.300	313.240	100.73
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV16 input current(A)	-2.000	313.240	100.64
IOI MALL PUCHONG (OLD WING)	Inverter 9 - TERA	NE=57818400	PV18 input current(A)	-1.560	313.240	100.50
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV input current(A) 4	4.000	441.090	99.09
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV11 input current(A)	1.560	441.090	99.65
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV13 input current(A)	1.330	441.090	99.70

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV15 input current(A)	2.100	441.090	99.52
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV17 input current(A)	1.450	441.090	99.67
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV19 input current(A)	1.320	441.090	99.70
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV3 input current(A)	1.590	441.090	99.64
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV5 input current(A)	1.370	441.090	99.69
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV7 input current(A)	1.450	441.090	99.67
KIARA BAY	Inverter 1 - TERA	NE=55735156	PV9 input current(A)	1.350	441.090	99.69
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV input current(A) 2	2.000	379.560	99.47
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV11 input current(A)	2.580	379.560	99.32
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV13 input current(A)	1.960	379.560	99.48
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV15 input current(A)	2.450	379.560	99.35
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV17 input current(A)	2.200	379.560	99.42
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV19 input current(A)	1.970	379.560	99.48
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV5 input current(A)	1.840	379.560	99.52
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV7 input current(A)	1.980	379.560	99.48
KIARA BAY	Inverter 10 - TERA	NE=55735154	PV9 input current(A)	1.930	379.560	99.49
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV input current(A) 2	2.000	379.260	99.47
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV11 input current(A)	2.290	379.260	99.40
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV13 input current(A)	2.310	379.260	99.39
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV15 input current(A)	2.430	379.260	99.36
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV17 input current(A)	2.190	379.260	99.42
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV19 input current(A)	2.010	379.260	99.47
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV3 input current(A)	2.240	379.260	99.41
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV5 input current(A)	2.320	379.260	99.39
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV7 input current(A)	2.000	379.260	99.47

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 11 - TERA	NE=55735153	PV9 input current(A)	2.020	379.260	99.47
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV input current(A) 3	6.000	447.140	98.66
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV2 input current(A)	-5.550	447.140	101.24
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV4 input current(A)	-3.030	447.140	100.68
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV6 input current(A)	-2.380	447.140	100.53
KIARA BAY	Inverter 4 - TERA	NE=55735161	PV8 input current(A)	-2.220	447.140	100.50
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV11 input current(A)	1.930	428.620	99.55
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV13 input current(A)	2.620	428.620	99.39
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV15 input current(A)	1.730	428.620	99.60
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV17 input current(A)	1.870	428.620	99.56
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV3 input current(A)	1.600	428.620	99.63
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV5 input current(A)	1.970	428.620	99.54
KIARA BAY	Inverter 5 - TERA	NE=55735155	PV7 input current(A)	2.430	428.620	99.43
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV input current(A) 3	3.000	400.500	99.25
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV4 input current(A)	-1.750	400.500	100.44
KIARA BAY	Inverter 6 - TERA	NE=55735160	PV8 input current(A)	-1.500	400.500	100.37
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV input current(A) 4	4.000	389.430	98.97
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV10 input current(A)	306.900	389.430	21.19
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV11 input current(A)	1.660	389.430	99.57
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV13 input current(A)	2.260	389.430	99.42
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV15 input current(A)	2.250	389.430	99.42
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV17 input current(A)	2.500	389.430	99.36
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV19 input current(A)	2.280	389.430	99.41
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV5 input current(A)	1.760	389.430	99.55
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV7 input current(A)	2.150	389.430	99.45

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KIARA BAY	Inverter 7 - TERA	NE=55735157	PV9 input current(A)	2.880	389.430	99.26
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV input current(A) 2	2.000	374.140	99.47
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV11 input current(A)	2.130	374.140	99.43
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV13 input current(A)	2.740	374.140	99.27
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV15 input current(A)	2.390	374.140	99.36
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV17 input current(A)	5.710	374.140	98.47
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV19 input current(A)	2.800	374.140	99.25
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV3 input current(A)	2.910	374.140	99.22
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV5 input current(A)	2.550	374.140	99.32
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV7 input current(A)	2.610	374.140	99.30
KIARA BAY	Inverter 8 - TERA	NE=55735158	PV9 input current(A)	2.520	374.140	99.33
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV4 input current(A)	-1.500	370.700	100.40
KIARA BAY	Inverter 9 - TERA	NE=55735159	PV8 input current(A)	-1.040	370.700	100.28
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV2 input current(A)	256.460	417.020	38.50
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV3 input current(A)	307.900	417.020	26.17
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	NE=51163027	PV5 input current(A)	314.630	417.020	24.55
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV1 input current(A)	210.500	366.150	42.51
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV3 input current(A)	187.250	366.150	48.86

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
BIMB Bdr Penawar - 1st Floor	Dongle- INV1	BT24C0060244	Network Connection Error	Major	15-04-2026 18:07

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
BJC FOOD (MALAYSIA) SDN. BHD.	60KTL-M0(COM1-3)	ES2180084797	Low Insulation Resistance	Major	16-05-2026 07:40
BOILERMECH LOT 873	Logger-102516002824	102516002824	Network Connection Error	Major	13-05-2026 12:52
BP PLASTICS BP9	Logger-102556511876	102556511876	Network Connection Error	Major	10-05-2026 16:38
C0172_ATRIA SOUTH	Logger-102256528212	102256528212	Network Connection Error	Major	08-05-2026 01:02
C0176_GETHA	Logger-102256528260	102256528260	Network Connection Error	Major	28-04-2026 21:09
Fibertex Phase 2	Inverter 2 L3 Old	6T2379019735	Upgrade Failed or Version Mismatch	Minor	18-07-2025 15:24
IOI Mall Puchong (Old Wing)	Inverter 21 R1-TERA	6T2599057796	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 3 R1 - TERA	BN2521059950	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 2 - TERA	BN2461066770	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 4 - TERA	6T2479017517	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 1 - TERA	BN2461065466	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 5 - TERA	BN2461066760	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
LIAN FOO POULTRY FARM SDN BHD	Dongle-BT2541519026	BT2541519026	Network Connection Error	Major	30-04-2026 18:40
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	Grid Loss	Major	30-04-2026 17:55
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	Grid Loss	Major	30-04-2026 17:54
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	Grid Loss	Major	30-04-2026 17:54
Lian Teck Seng Lot 11	Dongle-BT24C0060275	BT24C0060275	Network Connection Error	Major	29-01-2026 15:54
MARINE GOLD SDN BHD	Dongle-TA2340293153	TA2340293153	Network Connection Error	Major	26-03-2026 15:55

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
MARINE GOLD SDN BHD	Dongle-TA2340293476	TA2340293476	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340291437	TA2340291437	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-HV2310776105	HV2310776105	Network Connection Error	Major	26-03-2026 14:56
MARINE GOLD SDN BHD	Dongle-HV2310776109	HV2310776109	Network Connection Error	Major	26-03-2026 14:55
MARINE GOLD SDN BHD	Dongle-HV2310773587	HV2310773587	Network Connection Error	Major	26-03-2026 14:54
MENARA PKNS PJ	Logger-102466288020	102466288020	Network Connection Error	Major	10-05-2026 01:00
MAIAW FRESH	VASOLAR INV 1	NS2331625509	Grid Loss	Major	15-05-2026 13:06
PKT 12 WAVES	Inverter 4	ES2470045168	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 5	6T2459004824	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 3	6T2449041406	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 7	6T2449033633	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 8	6T2459004809	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 6	ES2470045204	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 10	6T2449041556	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 1	6T2459004867	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 2	6T2459004831	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 9	6T2449032075	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT THE SHIP	Inverter_7	6T2379019759	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_3	6T2379019623	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_1	6T2379018298	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_5	6T2379019768	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_4	6T2379019776	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_2 R1	BN2531021024	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_6	6T2379019622	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
Pengerang Independent Terminal	Dongle-LAB	TA23B0087782	Network Connection Error	Major	20-04-2026 13:52

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
Pleasure Latex Phase 2	Logger-102347282208	102347282208	Network Connection Error	Major	19-02-2026 03:00
QL FARM SDN BHD	Logger-102466853213	102466853213	Network Connection Error	Major	24-04-2026 10:56
QL FARM SDN BHD	Inverter 2	ES2580051643	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter 1	ES2580051653	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter3	ES2490076207	Grid Loss	Major	24-04-2026 10:07
REDANG LAGOON RESORT	Dongle-2102312EHS10N9115979	2102312EHS10N9115979	Network Connection Error	Major	30-01-2026 19:29
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	Grid Loss	Major	30-01-2026 07:23
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	Upgrade Failed or Version Mismatch	Minor	19-11-2025 21:35
SJK (C) TSHING NIAN	INV-TA2530374153	TA2530374153	Grid Loss	Major	16-05-2026 06:59
THP MEDICAL	VASOLAR INV 3	6T2279009018	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 2	6T2279008977	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 1	6T2279009011	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
VINDA PHASE 4 (MSB 3-2)	MASTER LOG HT P4	102595350697	Southbound Device Communication Abnormal	Minor	29-04-2026 15:30

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
AFI BRAKE MANUFACTURING SDN BHD	INV 4 - GROUND FLOOR	HV22B0337098	70.9
AFI BRAKE MANUFACTURING SDN BHD	INV 6 - SECOND FLOOR	HV22A0405534	70.9
AFI BRAKE MANUFACTURING SDN BHD	INV 7 - THIRD FLOOR	HV22B0337096	70.3
Fungiculture	Inverter 2 (M3)	HV22B0337400	70.1
SWEE CHEONG WATCH SDN BHD (Meter 1)	INV-TA2470383341	TA2470383341	70.5