

FusionSolar Troubleshooting Report

Date: 18-05-2026
Generated At: 18-05-2026 08:30:11
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	2
Total low-performing inverters	16
Total low-performing strings	177
Total alarms	74
Total high-temperature inverters	81

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
MAJOR ENGINEERING Lot 10	1.73	3.51	-50.71
MAJOR ENGINEERING Lot 8	0.67	3.51	-80.91

Low-performing Inverters

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	1.604	1.880	14.68
BJC FOOD (MALAYSIA) SDN. BHD.	60KTL-M0(COM1-3)	NE=50476042	1.440	1.880	23.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	1.295	2.214	41.51
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	1.280	2.214	42.19
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	1.286	2.214	41.92
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	1.282	2.214	42.10

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	1.275	2.214	42.41
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	1.287	2.214	41.87
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	1.285	2.214	41.96
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	1.288	2.214	41.82
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	1.289	2.214	41.78
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	1.282	2.214	42.10
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	1.625	2.034	20.11
SJK (C) TSHING NIAN	INV-TA2530374153	NE=77389280	0.000	2.592	100.00
SUCCESS ELECTRONIC LOT 5	TERA INVERTER 3	NE=73355202	0.832	1.035	19.61
SUCCESS ELECTRONIC LOT 7	TERA INVERTER 5	NE=73651978	1.851	2.068	10.49

Low-performing Strings

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV11 input current(A)	570.200	874.770	34.82
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV13 input current(A)	586.860	874.770	32.91
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV15 input current(A)	593.660	874.770	32.14
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV17 input current(A)	437.500	874.770	49.99
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV18 input current(A)	-1.480	874.770	100.17
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV19 input current(A)	491.270	874.770	43.84
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV20 input current(A)	-2.490	874.770	100.28

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV7 input current(A)	539.600	874.770	38.32
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV9 input current(A)	661.440	874.770	24.39
BJC FOOD (MALAYSIA) SDN. BHD.	60KTL-M0(COM1-3)	NE=50476042	PV input current(A) 5	5.000	811.670	99.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV1 input current(A)	116.050	178.360	34.93
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV10 input current(A)	-7.770	178.360	104.36
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV11 input current(A)	124.860	178.360	30.00
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV12 input current(A)	-4.120	178.360	102.31
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV13 input current(A)	116.100	178.360	34.91
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV14 input current(A)	-6.660	178.360	103.73
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV16 input current(A)	-2.370	178.360	101.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV18 input current(A)	-1.250	178.360	100.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV19 input current(A)	27.130	178.360	84.79
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV2 input current(A)	100.540	178.360	43.63
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV20 input current(A)	-7.470	178.360	104.19
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV3 input current(A)	120.750	178.360	32.30
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV4 input current(A)	111.990	178.360	37.21
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV5 input current(A)	111.600	178.360	37.43

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV6 input current(A)	-1.800	178.360	101.01
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV7 input current(A)	123.270	178.360	30.89
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV8 input current(A)	-4.610	178.360	102.58
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-1)	NE=50412148	PV9 input current(A)	115.830	178.360	35.06
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV input current(A) 1	2.000	215.040	99.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV1 input current(A)	165.800	215.040	22.90
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV10 input current(A)	-6.880	215.040	103.20
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV11 input current(A)	80.130	215.040	62.74
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV12 input current(A)	-7.400	215.040	103.44
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV13 input current(A)	84.710	215.040	60.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV14 input current(A)	-11.730	215.040	105.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV16 input current(A)	-2.990	215.040	101.39
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV17 input current(A)	141.460	215.040	34.22
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV18 input current(A)	-10.920	215.040	105.08
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV19 input current(A)	138.400	215.040	35.64
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV2 input current(A)	65.610	215.040	69.49

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV20 input current(A)	-6.140	215.040	102.86
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV3 input current(A)	166.680	215.040	22.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV4 input current(A)	63.190	215.040	70.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV5 input current(A)	76.120	215.040	64.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV6 input current(A)	-9.890	215.040	104.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV7 input current(A)	92.300	215.040	57.08
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-10)	NE=50412130	PV8 input current(A)	-6.610	215.040	103.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV1 input current(A)	107.030	149.120	28.23
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV10 input current(A)	-8.660	149.120	105.81
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV12 input current(A)	-9.630	149.120	106.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV13 input current(A)	84.490	149.120	43.34
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV14 input current(A)	-9.940	149.120	106.67
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV16 input current(A)	-3.130	149.120	102.10
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV18 input current(A)	-2.090	149.120	101.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV19 input current(A)	107.290	149.120	28.05
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV20 input current(A)	-8.880	149.120	105.95

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV6 input current(A)	-10.540	149.120	107.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV8 input current(A)	-7.240	149.120	104.86
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-2)	NE=50412133	PV9 input current(A)	115.900	149.120	22.28
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV input current(A) 1	2.000	146.240	98.63
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV10 input current(A)	-13.020	146.240	108.90
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV11 input current(A)	114.450	146.240	21.74
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV12 input current(A)	-9.090	146.240	106.22
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV14 input current(A)	-8.190	146.240	105.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV15 input current(A)	65.840	146.240	54.98
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV16 input current(A)	-9.760	146.240	106.67
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV18 input current(A)	-3.620	146.240	102.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV2 input current(A)	113.410	146.240	22.45
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV20 input current(A)	-3.200	146.240	102.19
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV6 input current(A)	-3.650	146.240	102.50
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV8 input current(A)	-9.450	146.240	106.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-3)	NE=50412147	PV9 input current(A)	63.780	146.240	56.39

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV input current(A) 1	4.000	196.120	97.96
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV input current(A) 2	2.000	196.120	98.98
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV1 input current(A)	117.980	196.120	39.84
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV10 input current(A)	-9.790	196.120	104.99
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV11 input current(A)	96.820	196.120	50.63
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV12 input current(A)	-10.900	196.120	105.56
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV13 input current(A)	71.380	196.120	63.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV14 input current(A)	-12.180	196.120	106.21
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV15 input current(A)	65.490	196.120	66.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV16 input current(A)	-8.400	196.120	104.28
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV17 input current(A)	121.060	196.120	38.27
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV18 input current(A)	-2.940	196.120	101.50
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV19 input current(A)	76.200	196.120	61.15
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV20 input current(A)	-3.430	196.120	101.75
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV3 input current(A)	121.880	196.120	37.85
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV6 input current(A)	-2.410	196.120	101.23

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV8 input current(A)	-8.740	196.120	104.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-4)	NE=50412150	PV9 input current(A)	59.090	196.120	69.87
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV input current(A) 1	3.000	180.080	98.33
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV1 input current(A)	111.330	180.080	38.18
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV10 input current(A)	-9.300	180.080	105.16
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV11 input current(A)	93.810	180.080	47.91
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV12 input current(A)	-9.360	180.080	105.20
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV13 input current(A)	87.480	180.080	51.42
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV14 input current(A)	-9.180	180.080	105.10
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV16 input current(A)	-3.770	180.080	102.09
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV18 input current(A)	-3.060	180.080	101.70
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV2 input current(A)	75.280	180.080	58.20
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV20 input current(A)	-3.720	180.080	102.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV3 input current(A)	124.250	180.080	31.00
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV4 input current(A)	100.740	180.080	44.06
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV5 input current(A)	97.050	180.080	46.11

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV6 input current(A)	-7.880	180.080	104.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV7 input current(A)	118.450	180.080	34.22
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV8 input current(A)	-9.850	180.080	105.47
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-5)	NE=50412131	PV9 input current(A)	108.860	180.080	39.55
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV input current(A) 1	3.000	173.960	98.28
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV1 input current(A)	87.350	173.960	49.79
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV10 input current(A)	-11.100	173.960	106.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV11 input current(A)	127.550	173.960	26.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV12 input current(A)	-10.740	173.960	106.17
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV13 input current(A)	120.860	173.960	30.52
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV14 input current(A)	-8.840	173.960	105.08
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV15 input current(A)	133.680	173.960	23.15
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV16 input current(A)	-7.660	173.960	104.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV17 input current(A)	135.560	173.960	22.07
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV18 input current(A)	-8.440	173.960	104.85
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV2 input current(A)	96.370	173.960	44.60

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV20 input current(A)	-4.510	173.960	102.59
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV3 input current(A)	106.440	173.960	38.81
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV4 input current(A)	96.500	173.960	44.53
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV5 input current(A)	123.570	173.960	28.97
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV6 input current(A)	-4.180	173.960	102.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV7 input current(A)	121.220	173.960	30.32
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV8 input current(A)	-12.070	173.960	106.94
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-6)	NE=50412146	PV9 input current(A)	133.500	173.960	23.26
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV10 input current(A)	-9.070	190.310	104.77
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV11 input current(A)	121.330	190.310	36.25
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV12 input current(A)	-2.560	190.310	101.35
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV13 input current(A)	118.110	190.310	37.94
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV14 input current(A)	-2.660	190.310	101.40
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV16 input current(A)	-1.680	190.310	100.88
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV17 input current(A)	88.210	190.310	53.65
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV18 input current(A)	-3.900	190.310	102.05

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV19 input current(A)	87.060	190.310	54.25
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV2 input current(A)	96.890	190.310	49.09
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV20 input current(A)	-3.530	190.310	101.85
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV4 input current(A)	115.400	190.310	39.36
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV5 input current(A)	109.240	190.310	42.60
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV6 input current(A)	-2.840	190.310	101.49
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV7 input current(A)	125.790	190.310	33.90
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV8 input current(A)	-2.990	190.310	101.57
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-7)	NE=50412143	PV9 input current(A)	57.490	190.310	69.79
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV input current(A) 1	3.000	148.670	97.98
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV1 input current(A)	91.160	148.670	38.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV10 input current(A)	-5.780	148.670	103.89
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV12 input current(A)	-7.590	148.670	105.11
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV14 input current(A)	-8.240	148.670	105.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV16 input current(A)	-5.980	148.670	104.02
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV18 input current(A)	-6.220	148.670	104.18

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV2 input current(A)	87.880	148.670	40.89
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV20 input current(A)	-7.910	148.670	105.32
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV3 input current(A)	91.310	148.670	38.58
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV4 input current(A)	78.110	148.670	47.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV6 input current(A)	-5.750	148.670	103.87
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV8 input current(A)	-9.000	148.670	106.05
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-8)	NE=50412144	PV9 input current(A)	106.600	148.670	28.30
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV1 input current(A)	32.890	174.830	81.19
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV10 input current(A)	-7.660	174.830	104.38
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV11 input current(A)	42.090	174.830	75.93
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV12 input current(A)	-8.890	174.830	105.08
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV14 input current(A)	-6.120	174.830	103.50
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV16 input current(A)	-9.740	174.830	105.57
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV18 input current(A)	-7.800	174.830	104.46
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV2 input current(A)	32.370	174.830	81.48
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV20 input current(A)	-9.390	174.830	105.37

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV3 input current(A)	101.040	174.830	42.21
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV4 input current(A)	85.760	174.830	50.95
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV6 input current(A)	-3.850	174.830	102.20
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-9)	NE=50412145	PV8 input current(A)	-6.780	174.830	103.88
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV input current(A) 1	3.000	646.570	99.54
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV1 input current(A)	354.290	646.570	45.20
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV3 input current(A)	341.540	646.570	47.18
SUCCESS ELECTRONIC LOT 5	TERA INVERTER 3	NE=73355202	PV input current(A) 1	4.000	138.570	97.11
SUCCESS ELECTRONIC LOT 5	TERA INVERTER 3	NE=73355202	PV3 input current(A)	107.470	138.570	22.44

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
BIMB Bdr Penawar - 1st Floor	Dongle- INV1	BT24C0060244	Network Connection Error	Major	15-04-2026 18:07
BOILERMECH LOT 873	Logger-102516002824	102516002824	Network Connection Error	Major	13-05-2026 12:52
BP PLASTICS BP9	Logger-102556511876	102556511876	Network Connection Error	Major	10-05-2026 16:38
C0172_ATRIA SOUTH	Logger-102256528212	102256528212	Network Connection Error	Major	08-05-2026 01:02
C0176_GETHA	Logger-102256528260	102256528260	Network Connection Error	Major	28-04-2026 21:09
Fibertex Phase 2	Inverter 2 L3 Old	6T2379019735	Upgrade Failed or Version Mismatch	Minor	18-07-2025 15:24
GLASS PLASTIC PACKAGING	Dongle - (No.23)	TA24C0272100	Network Connection Error	Major	17-05-2026 07:25
GLASS PLASTIC PACKAGING	Dongle - (No.6)	TA24C0272130	Network Connection Error	Major	17-05-2026 07:24
GLASS PLASTIC PACKAGING	Dongle - (No.23A)	TA24C0271931	Network Connection Error	Major	17-05-2026 07:24

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
GUH METER 1	VASOLAR_INV_1	6T2379018351	Abnormal External Fan	Major	17-05-2026 10:22
IOI Mall Puchong (Old Wing)	Inverter 21 R1-TERA	6T2599057796	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 3 R1 - TERA	BN2521059950	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 2 - TERA	BN2461066770	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 4 - TERA	6T2479017517	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 1 - TERA	BN2461065466	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 5 - TERA	BN2461066760	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
LIAN FOO POULTRY FARM SDN BHD	Dongle-BT2541519026	BT2541519026	Network Connection Error	Major	30-04-2026 18:40
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	Grid Loss	Major	30-04-2026 17:55
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	Grid Loss	Major	30-04-2026 17:54
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	Grid Loss	Major	30-04-2026 17:54
Lian Teck Seng Lot 11	Dongle-BT24C0060275	BT24C0060275	Network Connection Error	Major	29-01-2026 15:54
MARINE GOLD SDN BHD	Dongle-TA2340293153	TA2340293153	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340293476	TA2340293476	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340291437	TA2340291437	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-HV2310776105	HV2310776105	Network Connection Error	Major	26-03-2026 14:56
MARINE GOLD SDN BHD	Dongle-HV2310776109	HV2310776109	Network Connection Error	Major	26-03-2026 14:55
MARINE GOLD SDN BHD	Dongle-HV2310773587	HV2310773587	Network Connection Error	Major	26-03-2026 14:54

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
MENARA PKNS PJ	Logger-102466288020	102466288020	Network Connection Error	Major	10-05-2026 01:00
MAIAW FRESH	VASOLAR INV 1	NS2331625509	Grid Loss	Major	15-05-2026 13:06
Maxtwo Engineering (Factory)	Dongle-TA2510349523	TA2510349523	Network Connection Error	Major	17-05-2026 10:02
PKT 12 WAVES	Inverter 4	ES2470045168	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 5	6T2459004824	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 3	6T2449041406	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 7	6T2449033633	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 8	6T2459004809	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 6	ES2470045204	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 10	6T2449041556	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 1	6T2459004867	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 9	6T2449032075	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 2	6T2459004831	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT THE SHIP	Inverter_7	6T2379019759	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_3	6T2379019623	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_1	6T2379018298	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_5	6T2379019768	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_4	6T2379019776	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_6	6T2379019622	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_2 R1	BN2531021024	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
Pengerang Independent Terminal	Dongle-LAB	TA23B0087782	Network Connection Error	Major	20-04-2026 13:52
Pleasure Latex Phase 2	Logger-102347282208	102347282208	Network Connection Error	Major	19-02-2026 03:00
QL FARM SDN BHD	Logger-102466853213	102466853213	Network Connection Error	Major	24-04-2026 10:56
QL FARM SDN BHD	Inverter 2	ES2580051643	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter 1	ES2580051653	Grid Loss	Major	24-04-2026 10:07

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
QL FARM SDN BHD	Inverter3	ES2490076207	Grid Loss	Major	24-04-2026 10:07
REDANG LAGOON RESORT	Dongle-2102312EHS10N9115979	2102312EHS10N9115979	Network Connection Error	Major	30-01-2026 19:29
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	Grid Loss	Major	30-01-2026 07:23
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	Upgrade Failed or Version Mismatch	Minor	19-11-2025 21:35
SJK (C) TSHING NIAN	INV-TA2530374153	TA2530374153	Grid Loss	Major	17-05-2026 06:56
SJK ■ C ■ PIN HWA 1	Dongle-BT2530773381	BT2530773381	Network Connection Error	Major	16-05-2026 21:04
SWH INDUSTRIES (PLOT 132113)	Dongle-BT2590184507	BT2590184507	Network Connection Error	Major	16-05-2026 16:48
THP MEDICAL	VASOLAR INV 3	6T2279009018	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 2	6T2279008977	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 1	6T2279009011	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
Toa Paint Kepong Warehouse	Dongle-TA2340293160	TA2340293160	Network Connection Error	Major	16-05-2026 15:40
VINDA PHASE 4 (MSB 3-2)	MASTER LOG HT P4	102595350697	Southbound Device Communication Abnormal	Minor	29-04-2026 15:30
WASCO PIPE SDN BHD (MILL)	Inverter 1	GR2569103020	Grid Loss	Major	17-05-2026 09:55
WASCO PIPE SDN BHD (MILL)	Inverter 2	GR2569101664	Grid Loss	Major	17-05-2026 09:55
WASCO PIPE SDN BHD (MILL)	Inverter 4	GR2569101626	Grid Loss	Major	17-05-2026 09:55

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
AMEBA MGMT	INV-HV2290878023	HV2290878023	71.8
AMT PC DISTRIBUTORS SDN. BHD.	INV-6T22B9024620	6T22B9024620	74.8
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-13)	ES2550064305	70.8
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-14)	ES2550064253	72.7
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-15)	ES2550064258	73.0
ATS AIR SOLUTION	INV-HV22A0242778	HV22A0242778	73.2

Plant Name	Inverter Name	Inverter SN	Temperature
BREMFIELD SDN BHD	INV 1	ES2320221246	78.4
BREMFIELD SDN BHD	INV 3	6T22A9048280	73.4
BREMFIELD SDN BHD	INV 4	HV22B0435140	71.2
BUNCHO (M) SDN BHD	INV-6T2519005159	6T2519005159	73.2
C0102_QL batang kali	150K-MG0(COM3-2)	GR2479026710	75.2
C0102_QL batang kali	150K-MG0(COM3-3)	GR2479026770	75.7
C0102_QL batang kali	50KTL-M3(COM3-4)	6T24C9048091	70.1
C0149_VERTEX MISSION	HV21B0210137	HV21B0210137	74.5
CHAN KAH WHYE	INV-NS249G082061	NS249G082061	80.1
CIC CONTRACT SDN BHD	INV-HV22A0242777	HV22A0242777	77.7
Durasafe Sdn. Bhd.	INV 1-6T2479002464	6T2479002464	70.1
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 1	6T2569054829	74.6
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 2	ES2580087345	83.0
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 3	6T2569054834	73.0
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 4	ES2580087312	82.3
Farm Fresh Taiping (Factory)	50KTL-M3(COM1-12)	6T22A9038815	71.9
Fungiculture	Inverter 2 (M3)	HV22B0337400	71.3
Fungiculture	Inverter 2 (M4)	HV22B0004571	70.5
GLASS PLASTIC PACKAGING	INV 3 - (Lot 65999)	6T2489010635	70.9
GLASS PLASTIC PACKAGING	INV 4 - (Lot 65999)	6T2489010593	73.7
IOI City Mall Inc. Feeder 1	Inverter 2.12 R1	6T2599029683	70.5
IOI Mall Puchong (New Wing)	Inverter 15 - TERA	ES2330107601	73.7
IOI Mall Puchong (New Wing)	Inverter 16 - TERA	6T2449030262	76.0
IOI Mall Puchong (New Wing)	Inverter 17 - TERA	6T2479017623	70.2
IOI Mall Puchong (New Wing) Phase 2	Inverter 9	GR2569094300	71.8

Plant Name	Inverter Name	Inverter SN	Temperature
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	70.9
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	71.3
IOI Mall Puchong (Old Wing)	Inverter 20 - TERA	6T24C9047414	70.9
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	72.8
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	73.2
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	73.9
Jiann Lih safety product	40KTL-M3(COM1-16)	ES2290059727	71.4
KOSSAN PAINT SDN BHD	Inv 1 (Production)	ES2580051607	76.5
KUASA BAKTI (PETRON SETIA ALAM)	INV-6T2489035314	6T2489035314	73.4
Kamma Klang Enterprise	Inverter 2	HV22A0153968	76.5
Kiara Bay	Inverter 2 - TERA	ES2330110574	72.3
Kiara Bay	Inverter 3 - TERA	6T2449022934	78.2
Kiara Bay	Inverter 4 - TERA	6T2449023252	77.6
Kiara Bay	Inverter 6 - TERA	ES2350101155	73.1
Kiara Bay	Inverter 9 - TERA	ES2350101147	70.9
Komplex PKNS Bangi	40KTL-M3(COM1-13)	ES22A0040484	72.1
Marbach Asia Pacific Lot17	INV-6T2489012207	6T2489012207	75.4
Marbach Asia Pacific lot 15	INV-6T2489012205	6T2489012205	75.1
Multi Choice (M) Sdn Bhd	TERA INV 3	ES2560208616	80.4
New Age 160	INV 1	6T2469012777	72.4
New Age 160	Inverter 2 R1	6T23B9005979	76.6
New Age 160	Inverter 3-36ktl m3	6T2489036764	71.4
P.A Food Sdn Bhd 2ATKT	INV-ES2420001275	ES2420001275	75.1
P.A Food Sdn Bhd Lot 10	INV-6T2449029469	6T2449029469	70.9
P.A Food Sdn Bhd Lot 12	INV-6T2449029471	6T2449029471	72.3

Plant Name	Inverter Name	Inverter SN	Temperature
QL PAJAM PHASE 2	INV 4	6T2549059627	71.2
RS POLY INDUSTRY	VASOLAR INV 1	ES2420000999	73.9
RS POLY INDUSTRY	VASOLAR INV 2	ES2420001084	72.4
SCENT PUR MANUFACTURING SDN BHD NO.35	INV-TA2470078151	TA2470078151	73.0
SCENT PUR MANUFACTURING SDN BHD NO.37	INV-NS245G038275	NS245G038275	83.3
SJK (C) WU TECK	INV 1	6T25B9000135	76.4
SP Logistics Sdn Bhd	INV-6T23B9005457	6T23B9005457	76.8
SWEE CHEONG WATCH SDN BHD (Meter 1)	INV-TA2470383341	TA2470383341	73.6
San Soon Seng Food Industries Sdn Bhd	Inv 02 (Racking WH)	6T2549057201	71.1
Succesfuel Sdn. Bhd.	INVERTER 1 R1	6T24C9072224	76.0
THOR SPECIALTIES	INV-ES25C0123936	ES25C0123936	74.0
TOMEI	INV-(12-1)	HV2330348462	74.4
TOMEI	INV-(16-1)	HV2330348376	77.1
TOMEI	INV-(4-1)	HV2330348450	72.1
TOMEI	INV-(4-2)	HV2330348386	73.4
TOMEI	INV-(6-1)	HV2330348465	71.6
TOMEI	INV-(8)	HV2330348453	71.5
TOMEI	INV-(8-2)	HV2330348466	70.6
TOMEI	INV-(8-3)	HV2330348451	70.1
Teong Huat Medical	INV-6T2599029908	6T2599029908	77.5
VINDA PHASE 4 (MSB 3-2)	Inverter13 Phase4 R1	ES2580050563	71.6
VINDA PHASE 4 (MSB 3-2)	Phase4 Inverter 8 R1	6T2489038090	70.0
VISKO INDUSTRIES SDN BHD	VASOLAR_INV_8	ES2180084993	70.6
WCS UNIT 6	INVERTER UNIT 6	HV2290931617	73.5
WCS UNIT 7	INVERTER UNIT 7	HV22A0404241	71.4