

FusionSolar Troubleshooting Report

Date: 19-05-2026
Generated At: 19-05-2026 22:30:09
Prepared By: TERA SPMS

Executive Summary

Metric	Value
Total low-performing plants	3
Total low-performing inverters	36
Total low-performing strings	257
Total alarms	64
Total high-temperature inverters	141

Low-performing Plants

Plant Name	Plant PSH	City Average PSH	Deviation
Kossan Rubber Industries Berhad	0.00	2.04	-100.00
MAJOR ENGINEERING Lot 10	3.16	3.86	-18.08
MAJOR ENGINEERING Lot 8	1.16	3.86	-69.93

Low-performing Inverters

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	3.089	3.546	12.89
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-11)	NE=50412015	1.670	2.910	42.61
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-12)	NE=50412007	1.668	2.910	42.68
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-15)	NE=50412011	1.672	2.910	42.54
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-16)	NE=50412009	1.673	2.910	42.51

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-17)	NE=50412012	1.805	2.910	37.97
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-18)	NE=50412014	1.781	2.910	38.80
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-19)	NE=50411994	1.776	2.910	38.97
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-20)	NE=50412016	1.780	2.910	38.83
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	3.105	4.288	27.59
PKT 12 WAVES	Inverter 1	NE=56003099	3.387	4.246	20.23
PKT 12 WAVES	Inverter 10	NE=56003102	3.311	4.246	22.02
PKT 12 WAVES	Inverter 2	NE=56003098	3.357	4.246	20.94
PKT 12 WAVES	Inverter 3	NE=56003101	3.371	4.246	20.61
PKT 12 WAVES	Inverter 4	NE=56003104	3.409	4.246	19.71
PKT 12 WAVES	Inverter 5	NE=56003103	3.208	4.246	24.45
PKT 12 WAVES	Inverter 6	NE=56003095	3.238	4.246	23.74
PKT 12 WAVES	Inverter 7	NE=56003100	3.225	4.246	24.05
PKT 12 WAVES	Inverter 8	NE=56003096	3.237	4.246	23.76
PKT 12 WAVES	Inverter 9	NE=56003097	3.229	4.246	23.95
QL FOODS	INVERTER_5 R1	NE=54942978	0.001	4.849	99.98
QL FOODS	INVERTER_1	NE=53678484	0.001	4.849	99.98
QL FOODS	INVERTER_10	NE=53679611	0.001	4.849	99.98
QL FOODS	INVERTER_12	NE=53679581	0.001	4.849	99.98
QL FOODS	INVERTER_13	NE=53679495	0.000	4.849	100.00
QL FOODS	INVERTER_14	NE=53679493	0.001	4.849	99.98
QL FOODS	INVERTER_15	NE=53679053	0.001	4.849	99.98
QL FOODS	INVERTER_2	NE=53678485	0.001	4.849	99.98
QL FOODS	INVERTER_3	NE=53678487	0.000	4.849	100.00

Plant Name	Inverter	SN	Inverter PSH	Benchmark PSH	Deviation
QL FOODS	INVERTER_4	NE=53678481	0.000	4.849	100.00
QL FOODS	INVERTER_6	NE=53678483	0.001	4.849	99.98
QL FOODS	INVERTER_7	NE=53676713	0.001	4.849	99.98
QL FOODS	INVERTER_8	NE=53678803	0.002	4.849	99.96
QL FOODS	INVERTER_9	NE=53679667	0.000	4.849	100.00
SAWIPAC SDN BHD	INV-6T2519015310	NE=62552646	2.435	3.734	34.79
SJK (C) TSHING NIAN	INV-TA2530374153	NE=77389280	1.261	5.382	76.57

Low-performing Strings

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV11 input current(A)	606.920	967.200	37.25
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV13 input current(A)	642.600	967.200	33.56
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV15 input current(A)	656.780	967.200	32.09
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV17 input current(A)	479.480	967.200	50.43
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV18 input current(A)	-2.290	967.200	100.24
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV19 input current(A)	547.120	967.200	43.43
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV20 input current(A)	-1.290	967.200	100.13
BJC FOOD (MALAYSIA) SDN. BHD.	100KTL-M1(COM1-1)	NE=50476040	PV7 input current(A)	602.940	967.200	37.66
DSG MALAYSIA SDN. BHD	100KTL-M1(COM1-11)	NE=50412015	PV16 input current(A)	1.210	627.730	99.81
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV1 input current(A)	408.170	807.540	49.46

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
KWANG HUA PERSENDIRIAN METER 2-3-4-5-6	Block C - Inverter 7 - Meter 2	NE=51163025	PV3 input current(A)	382.470	807.540	52.64
PKT 12 WAVES	Inverter 1	NE=56003099	PV1 input current(A)	450.300	719.300	37.40
PKT 12 WAVES	Inverter 1	NE=56003099	PV10 input current(A)	-2.110	719.300	100.29
PKT 12 WAVES	Inverter 1	NE=56003099	PV12 input current(A)	-1.510	719.300	100.21
PKT 12 WAVES	Inverter 1	NE=56003099	PV14 input current(A)	-1.370	719.300	100.19
PKT 12 WAVES	Inverter 1	NE=56003099	PV16 input current(A)	-47.070	719.300	106.54
PKT 12 WAVES	Inverter 1	NE=56003099	PV2 input current(A)	418.010	719.300	41.89
PKT 12 WAVES	Inverter 1	NE=56003099	PV4 input current(A)	-1.250	719.300	100.17
PKT 12 WAVES	Inverter 1	NE=56003099	PV6 input current(A)	-2.360	719.300	100.33
PKT 12 WAVES	Inverter 10	NE=56003102	PV10 input current(A)	-1.340	736.190	100.18
PKT 12 WAVES	Inverter 10	NE=56003102	PV11 input current(A)	481.910	736.190	34.54
PKT 12 WAVES	Inverter 10	NE=56003102	PV12 input current(A)	441.110	736.190	40.08
PKT 12 WAVES	Inverter 10	NE=56003102	PV15 input current(A)	465.520	736.190	36.77
PKT 12 WAVES	Inverter 10	NE=56003102	PV16 input current(A)	468.840	736.190	36.32
PKT 12 WAVES	Inverter 10	NE=56003102	PV17 input current(A)	1.520	736.190	99.79
PKT 12 WAVES	Inverter 10	NE=56003102	PV19 input current(A)	439.300	736.190	40.33
PKT 12 WAVES	Inverter 10	NE=56003102	PV20 input current(A)	489.900	736.190	33.45
PKT 12 WAVES	Inverter 10	NE=56003102	PV6 input current(A)	-16.180	736.190	102.20
PKT 12 WAVES	Inverter 10	NE=56003102	PV8 input current(A)	-1.600	736.190	100.22
PKT 12 WAVES	Inverter 2	NE=56003098	PV1 input current(A)	471.570	698.480	32.49
PKT 12 WAVES	Inverter 2	NE=56003098	PV12 input current(A)	-1.350	698.480	100.19
PKT 12 WAVES	Inverter 2	NE=56003098	PV14 input current(A)	-1.050	698.480	100.15
PKT 12 WAVES	Inverter 2	NE=56003098	PV16 input current(A)	-1.270	698.480	100.18
PKT 12 WAVES	Inverter 2	NE=56003098	PV2 input current(A)	396.710	698.480	43.20

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
PKT 12 WAVES	Inverter 2	NE=56003098	PV4 input current(A)	-1.440	698.480	100.21
PKT 12 WAVES	Inverter 2	NE=56003098	PV6 input current(A)	-6.420	698.480	100.92
PKT 12 WAVES	Inverter 3	NE=56003101	PV1 input current(A)	420.740	696.840	39.62
PKT 12 WAVES	Inverter 3	NE=56003101	PV12 input current(A)	-1.010	696.840	100.14
PKT 12 WAVES	Inverter 3	NE=56003101	PV16 input current(A)	-15.470	696.840	102.22
PKT 12 WAVES	Inverter 3	NE=56003101	PV2 input current(A)	439.750	696.840	36.89
PKT 12 WAVES	Inverter 3	NE=56003101	PV6 input current(A)	-1.270	696.840	100.18
PKT 12 WAVES	Inverter 4	NE=56003104	PV10 input current(A)	467.720	736.270	36.47
PKT 12 WAVES	Inverter 4	NE=56003104	PV11 input current(A)	488.120	736.270	33.70
PKT 12 WAVES	Inverter 4	NE=56003104	PV12 input current(A)	459.630	736.270	37.57
PKT 12 WAVES	Inverter 4	NE=56003104	PV14 input current(A)	-1.140	736.270	100.15
PKT 12 WAVES	Inverter 4	NE=56003104	PV16 input current(A)	-1.050	736.270	100.14
PKT 12 WAVES	Inverter 4	NE=56003104	PV4 input current(A)	-1.060	736.270	100.14
PKT 12 WAVES	Inverter 4	NE=56003104	PV7 input current(A)	488.920	736.270	33.60
PKT 12 WAVES	Inverter 4	NE=56003104	PV8 input current(A)	447.100	736.270	39.27
PKT 12 WAVES	Inverter 4	NE=56003104	PV9 input current(A)	463.610	736.270	37.03
PKT 12 WAVES	Inverter 5	NE=56003103	PV1 input current(A)	433.260	686.580	36.90
PKT 12 WAVES	Inverter 5	NE=56003103	PV10 input current(A)	-1.680	686.580	100.24
PKT 12 WAVES	Inverter 5	NE=56003103	PV12 input current(A)	-1.720	686.580	100.25
PKT 12 WAVES	Inverter 5	NE=56003103	PV16 input current(A)	-1.260	686.580	100.18
PKT 12 WAVES	Inverter 5	NE=56003103	PV18 input current(A)	-1.010	686.580	100.15
PKT 12 WAVES	Inverter 5	NE=56003103	PV2 input current(A)	450.810	686.580	34.34
PKT 12 WAVES	Inverter 5	NE=56003103	PV20 input current(A)	-1.270	686.580	100.18
PKT 12 WAVES	Inverter 5	NE=56003103	PV6 input current(A)	-1.260	686.580	100.18
PKT 12 WAVES	Inverter 5	NE=56003103	PV8 input current(A)	-3.380	686.580	100.49

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
PKT 12 WAVES	Inverter 6	NE=56003095	PV1 input current(A)	463.210	680.630	31.94
PKT 12 WAVES	Inverter 6	NE=56003095	PV14 input current(A)	-1.060	680.630	100.16
PKT 12 WAVES	Inverter 6	NE=56003095	PV16 input current(A)	-8.950	680.630	101.31
PKT 12 WAVES	Inverter 6	NE=56003095	PV2 input current(A)	385.460	680.630	43.37
PKT 12 WAVES	Inverter 6	NE=56003095	PV8 input current(A)	-1.040	680.630	100.15
PKT 12 WAVES	Inverter 7	NE=56003100	PV1 input current(A)	452.040	681.530	33.67
PKT 12 WAVES	Inverter 7	NE=56003100	PV12 input current(A)	-1.400	681.530	100.21
PKT 12 WAVES	Inverter 7	NE=56003100	PV14 input current(A)	-1.010	681.530	100.15
PKT 12 WAVES	Inverter 7	NE=56003100	PV16 input current(A)	-1.040	681.530	100.15
PKT 12 WAVES	Inverter 7	NE=56003100	PV2 input current(A)	422.570	681.530	38.00
PKT 12 WAVES	Inverter 7	NE=56003100	PV6 input current(A)	-1.140	681.530	100.17
PKT 12 WAVES	Inverter 7	NE=56003100	PV8 input current(A)	-1.180	681.530	100.17
PKT 12 WAVES	Inverter 8	NE=56003096	PV10 input current(A)	-1.870	677.260	100.28
PKT 12 WAVES	Inverter 8	NE=56003096	PV12 input current(A)	-2.920	677.260	100.43
PKT 12 WAVES	Inverter 8	NE=56003096	PV14 input current(A)	-1.370	677.260	100.20
PKT 12 WAVES	Inverter 8	NE=56003096	PV16 input current(A)	-1.160	677.260	100.17
PKT 12 WAVES	Inverter 8	NE=56003096	PV19 input current(A)	456.110	677.260	32.65
PKT 12 WAVES	Inverter 8	NE=56003096	PV20 input current(A)	405.800	677.260	40.08
PKT 12 WAVES	Inverter 8	NE=56003096	PV6 input current(A)	-15.330	677.260	102.26
PKT 12 WAVES	Inverter 9	NE=56003097	PV1 input current(A)	421.510	753.660	44.07
PKT 12 WAVES	Inverter 9	NE=56003097	PV12 input current(A)	-1.540	753.660	100.20
PKT 12 WAVES	Inverter 9	NE=56003097	PV16 input current(A)	-49.040	753.660	106.51
PKT 12 WAVES	Inverter 9	NE=56003097	PV2 input current(A)	499.990	753.660	33.66
PKT 12 WAVES	Inverter 9	NE=56003097	PV20 input current(A)	-1.160	753.660	100.15
PKT 12 WAVES	Inverter 9	NE=56003097	PV3 input current(A)	437.430	753.660	41.96

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
PKT 12 WAVES	Inverter 9	NE=56003097	PV4 input current(A)	497.270	753.660	34.02
PKT 12 WAVES	Inverter 9	NE=56003097	PV8 input current(A)	-1.260	753.660	100.17
QL FOODS	INVERTER_5 R1	NE=54942978	PV10 input current(A)	-10.600	28.600	137.06
QL FOODS	INVERTER_5 R1	NE=54942978	PV12 input current(A)	-21.180	28.600	174.06
QL FOODS	INVERTER_5 R1	NE=54942978	PV13 input current(A)	7.590	28.600	73.46
QL FOODS	INVERTER_5 R1	NE=54942978	PV14 input current(A)	-4.620	28.600	116.15
QL FOODS	INVERTER_5 R1	NE=54942978	PV15 input current(A)	16.060	28.600	43.85
QL FOODS	INVERTER_5 R1	NE=54942978	PV16 input current(A)	-13.530	28.600	147.31
QL FOODS	INVERTER_5 R1	NE=54942978	PV17 input current(A)	12.810	28.600	55.21
QL FOODS	INVERTER_5 R1	NE=54942978	PV18 input current(A)	-8.760	28.600	130.63
QL FOODS	INVERTER_5 R1	NE=54942978	PV19 input current(A)	18.030	28.600	36.96
QL FOODS	INVERTER_5 R1	NE=54942978	PV2 input current(A)	-24.390	28.600	185.28
QL FOODS	INVERTER_5 R1	NE=54942978	PV20 input current(A)	-15.410	28.600	153.88
QL FOODS	INVERTER_5 R1	NE=54942978	PV3 input current(A)	13.850	28.600	51.57
QL FOODS	INVERTER_5 R1	NE=54942978	PV4 input current(A)	-12.110	28.600	142.34
QL FOODS	INVERTER_5 R1	NE=54942978	PV5 input current(A)	14.050	28.600	50.87
QL FOODS	INVERTER_5 R1	NE=54942978	PV6 input current(A)	-11.770	28.600	141.15
QL FOODS	INVERTER_5 R1	NE=54942978	PV7 input current(A)	17.230	28.600	39.76
QL FOODS	INVERTER_5 R1	NE=54942978	PV8 input current(A)	-14.840	28.600	151.89
QL FOODS	INVERTER_5 R1	NE=54942978	PV9 input current(A)	17.880	28.600	37.48
QL FOODS	INVERTER_1	NE=53678484	PV10 input current(A)	-13.420	41.460	132.37
QL FOODS	INVERTER_1	NE=53678484	PV11 input current(A)	12.130	41.460	70.74
QL FOODS	INVERTER_1	NE=53678484	PV12 input current(A)	-11.580	41.460	127.93
QL FOODS	INVERTER_1	NE=53678484	PV13 input current(A)	14.110	41.460	65.97
QL FOODS	INVERTER_1	NE=53678484	PV14 input current(A)	-12.600	41.460	130.39

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
QL FOODS	INVERTER_1	NE=53678484	PV15 input current(A)	17.280	41.460	58.32
QL FOODS	INVERTER_1	NE=53678484	PV16 input current(A)	-16.600	41.460	140.04
QL FOODS	INVERTER_1	NE=53678484	PV17 input current(A)	11.840	41.460	71.44
QL FOODS	INVERTER_1	NE=53678484	PV18 input current(A)	-11.370	41.460	127.42
QL FOODS	INVERTER_1	NE=53678484	PV19 input current(A)	13.800	41.460	66.71
QL FOODS	INVERTER_1	NE=53678484	PV2 input current(A)	-34.850	41.460	184.06
QL FOODS	INVERTER_1	NE=53678484	PV20 input current(A)	-13.830	41.460	133.36
QL FOODS	INVERTER_1	NE=53678484	PV3 input current(A)	14.020	41.460	66.18
QL FOODS	INVERTER_1	NE=53678484	PV4 input current(A)	-13.620	41.460	132.85
QL FOODS	INVERTER_1	NE=53678484	PV5 input current(A)	13.220	41.460	68.11
QL FOODS	INVERTER_1	NE=53678484	PV6 input current(A)	-11.390	41.460	127.47
QL FOODS	INVERTER_1	NE=53678484	PV7 input current(A)	17.020	41.460	58.95
QL FOODS	INVERTER_1	NE=53678484	PV8 input current(A)	-13.240	41.460	131.93
QL FOODS	INVERTER_1	NE=53678484	PV9 input current(A)	15.160	41.460	63.43
QL FOODS	INVERTER_10	NE=53679611	PV2 input current(A)	-7.200	15.840	145.45
QL FOODS	INVERTER_10	NE=53679611	PV3 input current(A)	3.200	15.840	79.80
QL FOODS	INVERTER_10	NE=53679611	PV5 input current(A)	1.670	15.840	89.46
QL FOODS	INVERTER_10	NE=53679611	PV6 input current(A)	1.300	15.840	91.79
QL FOODS	INVERTER_10	NE=53679611	PV7 input current(A)	9.950	15.840	37.18
QL FOODS	INVERTER_10	NE=53679611	PV8 input current(A)	2.100	15.840	86.74
QL FOODS	INVERTER_12	NE=53679581	PV10 input current(A)	-10.360	64.890	115.97
QL FOODS	INVERTER_12	NE=53679581	PV11 input current(A)	17.320	64.890	73.31
QL FOODS	INVERTER_12	NE=53679581	PV12 input current(A)	-10.750	64.890	116.57
QL FOODS	INVERTER_12	NE=53679581	PV13 input current(A)	12.680	64.890	80.46
QL FOODS	INVERTER_12	NE=53679581	PV14 input current(A)	-11.780	64.890	118.15

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
QL FOODS	INVERTER_12	NE=53679581	PV15 input current(A)	14.470	64.890	77.70
QL FOODS	INVERTER_12	NE=53679581	PV16 input current(A)	-20.500	64.890	131.59
QL FOODS	INVERTER_12	NE=53679581	PV17 input current(A)	13.870	64.890	78.63
QL FOODS	INVERTER_12	NE=53679581	PV18 input current(A)	-11.510	64.890	117.74
QL FOODS	INVERTER_12	NE=53679581	PV19 input current(A)	14.090	64.890	78.29
QL FOODS	INVERTER_12	NE=53679581	PV2 input current(A)	-49.160	64.890	175.76
QL FOODS	INVERTER_12	NE=53679581	PV20 input current(A)	-17.970	64.890	127.69
QL FOODS	INVERTER_12	NE=53679581	PV3 input current(A)	15.780	64.890	75.68
QL FOODS	INVERTER_12	NE=53679581	PV4 input current(A)	-20.380	64.890	131.41
QL FOODS	INVERTER_12	NE=53679581	PV5 input current(A)	18.660	64.890	71.24
QL FOODS	INVERTER_12	NE=53679581	PV6 input current(A)	-14.190	64.890	121.87
QL FOODS	INVERTER_12	NE=53679581	PV7 input current(A)	15.610	64.890	75.94
QL FOODS	INVERTER_12	NE=53679581	PV8 input current(A)	-20.830	64.890	132.10
QL FOODS	INVERTER_12	NE=53679581	PV9 input current(A)	15.860	64.890	75.56
QL FOODS	INVERTER_13	NE=53679495	PV1 input current(A)	11.570	37.040	68.76
QL FOODS	INVERTER_13	NE=53679495	PV10 input current(A)	-17.890	37.040	148.30
QL FOODS	INVERTER_13	NE=53679495	PV11 input current(A)	13.510	37.040	63.53
QL FOODS	INVERTER_13	NE=53679495	PV12 input current(A)	-15.590	37.040	142.09
QL FOODS	INVERTER_13	NE=53679495	PV13 input current(A)	14.730	37.040	60.23
QL FOODS	INVERTER_13	NE=53679495	PV14 input current(A)	-14.970	37.040	140.42
QL FOODS	INVERTER_13	NE=53679495	PV15 input current(A)	16.330	37.040	55.91
QL FOODS	INVERTER_13	NE=53679495	PV16 input current(A)	-16.860	37.040	145.52
QL FOODS	INVERTER_13	NE=53679495	PV17 input current(A)	15.540	37.040	58.05
QL FOODS	INVERTER_13	NE=53679495	PV18 input current(A)	-18.600	37.040	150.22
QL FOODS	INVERTER_13	NE=53679495	PV19 input current(A)	12.780	37.040	65.50

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
QL FOODS	INVERTER_13	NE=53679495	PV2 input current(A)	-10.870	37.040	129.35
QL FOODS	INVERTER_13	NE=53679495	PV20 input current(A)	-10.470	37.040	128.27
QL FOODS	INVERTER_13	NE=53679495	PV3 input current(A)	22.610	37.040	38.96
QL FOODS	INVERTER_13	NE=53679495	PV4 input current(A)	-19.280	37.040	152.05
QL FOODS	INVERTER_13	NE=53679495	PV5 input current(A)	-33.030	37.040	189.17
QL FOODS	INVERTER_13	NE=53679495	PV7 input current(A)	15.380	37.040	58.48
QL FOODS	INVERTER_13	NE=53679495	PV8 input current(A)	-14.110	37.040	138.09
QL FOODS	INVERTER_13	NE=53679495	PV9 input current(A)	21.970	37.040	40.69
QL FOODS	INVERTER_14	NE=53679493	PV10 input current(A)	-14.680	57.540	125.51
QL FOODS	INVERTER_14	NE=53679493	PV11 input current(A)	16.590	57.540	71.17
QL FOODS	INVERTER_14	NE=53679493	PV12 input current(A)	-16.420	57.540	128.54
QL FOODS	INVERTER_14	NE=53679493	PV13 input current(A)	15.740	57.540	72.65
QL FOODS	INVERTER_14	NE=53679493	PV14 input current(A)	-14.850	57.540	125.81
QL FOODS	INVERTER_14	NE=53679493	PV15 input current(A)	15.510	57.540	73.04
QL FOODS	INVERTER_14	NE=53679493	PV16 input current(A)	-15.490	57.540	126.92
QL FOODS	INVERTER_14	NE=53679493	PV17 input current(A)	14.130	57.540	75.44
QL FOODS	INVERTER_14	NE=53679493	PV18 input current(A)	-13.880	57.540	124.12
QL FOODS	INVERTER_14	NE=53679493	PV19 input current(A)	16.190	57.540	71.86
QL FOODS	INVERTER_14	NE=53679493	PV2 input current(A)	-49.300	57.540	185.68
QL FOODS	INVERTER_14	NE=53679493	PV20 input current(A)	-19.180	57.540	133.33
QL FOODS	INVERTER_14	NE=53679493	PV3 input current(A)	14.340	57.540	75.08
QL FOODS	INVERTER_14	NE=53679493	PV4 input current(A)	-15.830	57.540	127.51
QL FOODS	INVERTER_14	NE=53679493	PV5 input current(A)	24.200	57.540	57.94
QL FOODS	INVERTER_14	NE=53679493	PV6 input current(A)	-13.110	57.540	122.78
QL FOODS	INVERTER_14	NE=53679493	PV7 input current(A)	19.260	57.540	66.53

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
QL FOODS	INVERTER_14	NE=53679493	PV8 input current(A)	-20.630	57.540	135.85
QL FOODS	INVERTER_14	NE=53679493	PV9 input current(A)	16.780	57.540	70.84
QL FOODS	INVERTER_15	NE=53679053	PV2 input current(A)	-10.010	14.300	170.00
QL FOODS	INVERTER_15	NE=53679053	PV3 input current(A)	2.820	14.300	80.28
QL FOODS	INVERTER_15	NE=53679053	PV4 input current(A)	8.580	14.300	40.00
QL FOODS	INVERTER_15	NE=53679053	PV5 input current(A)	5.690	14.300	60.21
QL FOODS	INVERTER_15	NE=53679053	PV6 input current(A)	-8.580	14.300	160.00
QL FOODS	INVERTER_15	NE=53679053	PV8 input current(A)	-10.010	14.300	170.00
QL FOODS	INVERTER_2	NE=53678485	PV10 input current(A)	-19.050	21.940	186.83
QL FOODS	INVERTER_2	NE=53678485	PV11 input current(A)	14.200	21.940	35.28
QL FOODS	INVERTER_2	NE=53678485	PV12 input current(A)	-15.610	21.940	171.15
QL FOODS	INVERTER_2	NE=53678485	PV13 input current(A)	10.950	21.940	50.09
QL FOODS	INVERTER_2	NE=53678485	PV14 input current(A)	-10.530	21.940	147.99
QL FOODS	INVERTER_2	NE=53678485	PV15 input current(A)	13.540	21.940	38.29
QL FOODS	INVERTER_2	NE=53678485	PV16 input current(A)	-14.610	21.940	166.59
QL FOODS	INVERTER_2	NE=53678485	PV17 input current(A)	11.840	21.940	46.03
QL FOODS	INVERTER_2	NE=53678485	PV18 input current(A)	-11.380	21.940	151.87
QL FOODS	INVERTER_2	NE=53678485	PV19 input current(A)	11.620	21.940	47.04
QL FOODS	INVERTER_2	NE=53678485	PV2 input current(A)	-22.910	21.940	204.42
QL FOODS	INVERTER_2	NE=53678485	PV20 input current(A)	-13.290	21.940	160.57
QL FOODS	INVERTER_2	NE=53678485	PV3 input current(A)	13.380	21.940	39.02
QL FOODS	INVERTER_2	NE=53678485	PV4 input current(A)	-14.600	21.940	166.55
QL FOODS	INVERTER_2	NE=53678485	PV5 input current(A)	12.410	21.940	43.44
QL FOODS	INVERTER_2	NE=53678485	PV6 input current(A)	-12.790	21.940	158.30
QL FOODS	INVERTER_2	NE=53678485	PV7 input current(A)	14.490	21.940	33.96

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
QL FOODS	INVERTER_2	NE=53678485	PV8 input current(A)	-18.620	21.940	184.87
QL FOODS	INVERTER_2	NE=53678485	PV9 input current(A)	13.780	21.940	37.19
QL FOODS	INVERTER_3	NE=53678487	PV10 input current(A)	-14.120	21.230	166.51
QL FOODS	INVERTER_3	NE=53678487	PV11 input current(A)	14.850	21.230	30.05
QL FOODS	INVERTER_3	NE=53678487	PV12 input current(A)	-15.810	21.230	174.47
QL FOODS	INVERTER_3	NE=53678487	PV14 input current(A)	-14.580	21.230	168.68
QL FOODS	INVERTER_3	NE=53678487	PV16 input current(A)	-18.240	21.230	185.92
QL FOODS	INVERTER_3	NE=53678487	PV18 input current(A)	-17.500	21.230	182.43
QL FOODS	INVERTER_3	NE=53678487	PV2 input current(A)	-19.030	21.230	189.64
QL FOODS	INVERTER_3	NE=53678487	PV20 input current(A)	-19.250	21.230	190.67
QL FOODS	INVERTER_3	NE=53678487	PV4 input current(A)	-19.140	21.230	190.16
QL FOODS	INVERTER_3	NE=53678487	PV6 input current(A)	-19.890	21.230	193.69
QL FOODS	INVERTER_3	NE=53678487	PV7 input current(A)	1.850	21.230	91.29
QL FOODS	INVERTER_3	NE=53678487	PV8 input current(A)	-3.570	21.230	116.82
QL FOODS	INVERTER_4	NE=53678481	PV2 input current(A)	-71.050	81.690	186.98
QL FOODS	INVERTER_4	NE=53678481	PV9 input current(A)	7.660	81.690	90.62
QL FOODS	INVERTER_6	NE=53678483	PV10 input current(A)	-14.150	21.000	167.38
QL FOODS	INVERTER_6	NE=53678483	PV12 input current(A)	-14.230	21.000	167.76
QL FOODS	INVERTER_6	NE=53678483	PV14 input current(A)	-17.190	21.000	181.86
QL FOODS	INVERTER_6	NE=53678483	PV15 input current(A)	14.210	21.000	32.33
QL FOODS	INVERTER_6	NE=53678483	PV16 input current(A)	-14.880	21.000	170.86
QL FOODS	INVERTER_6	NE=53678483	PV18 input current(A)	-15.150	21.000	172.14
QL FOODS	INVERTER_6	NE=53678483	PV2 input current(A)	-13.750	21.000	165.48
QL FOODS	INVERTER_6	NE=53678483	PV20 input current(A)	-16.000	21.000	176.19
QL FOODS	INVERTER_6	NE=53678483	PV4 input current(A)	-18.560	21.000	188.38

Plant Name	Inverter	SN	String	Total Current	Benchmark	Deviation
QL FOODS	INVERTER_6	NE=53678483	PV6 input current(A)	-19.120	21.000	191.05
QL FOODS	INVERTER_6	NE=53678483	PV8 input current(A)	-15.840	21.000	175.43
QL FOODS	INVERTER_7	NE=53676713	PV2 input current(A)	-65.290	68.550	195.24
QL FOODS	INVERTER_7	NE=53676713	PV5 input current(A)	-33.600	68.550	149.02
QL FOODS	INVERTER_7	NE=53676713	PV6 input current(A)	30.080	68.550	56.12
QL FOODS	INVERTER_9	NE=53679667	PV1 input current(A)	11.750	43.550	73.02
QL FOODS	INVERTER_9	NE=53679667	PV10 input current(A)	-11.190	43.550	125.69
QL FOODS	INVERTER_9	NE=53679667	PV11 input current(A)	9.510	43.550	78.16
QL FOODS	INVERTER_9	NE=53679667	PV12 input current(A)	-11.160	43.550	125.63
QL FOODS	INVERTER_9	NE=53679667	PV13 input current(A)	10.520	43.550	75.84
QL FOODS	INVERTER_9	NE=53679667	PV14 input current(A)	-11.570	43.550	126.57
QL FOODS	INVERTER_9	NE=53679667	PV15 input current(A)	10.170	43.550	76.65
QL FOODS	INVERTER_9	NE=53679667	PV16 input current(A)	-17.590	43.550	140.39
QL FOODS	INVERTER_9	NE=53679667	PV17 input current(A)	10.300	43.550	76.35
QL FOODS	INVERTER_9	NE=53679667	PV18 input current(A)	-13.300	43.550	130.54
QL FOODS	INVERTER_9	NE=53679667	PV2 input current(A)	-8.730	43.550	120.05
QL FOODS	INVERTER_9	NE=53679667	PV20 input current(A)	-47.490	43.550	209.05
QL FOODS	INVERTER_9	NE=53679667	PV3 input current(A)	11.190	43.550	74.31
QL FOODS	INVERTER_9	NE=53679667	PV4 input current(A)	-20.190	43.550	146.36
QL FOODS	INVERTER_9	NE=53679667	PV6 input current(A)	-31.300	43.550	171.87
QL FOODS	INVERTER_9	NE=53679667	PV7 input current(A)	8.520	43.550	80.44
QL FOODS	INVERTER_9	NE=53679667	PV8 input current(A)	-14.910	43.550	134.24
QL FOODS	INVERTER_9	NE=53679667	PV9 input current(A)	9.730	43.550	77.66

Active Alarms

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
BOILERMECH LOT 873	Logger-102516002824	102516002824	Network Connection Error	Major	19-05-2026 06:35
C0172_ATRIA SOUTH	Logger-102256528212	102256528212	Network Connection Error	Major	18-05-2026 12:57
C0176_GETHA	Logger-102256528260	102256528260	Network Connection Error	Major	28-04-2026 21:09
Fibertex Phase 2	Inverter 2 L3 Old	6T2379019735	Upgrade Failed or Version Mismatch	Minor	18-07-2025 15:24
IOI Mall Puchong (New Wing) Phase 2	Inverter 3	GR2569071111	String Loss	Warning	18-05-2026 16:09
IOI Mall Puchong (New Wing) Phase 2	Inverter 4	GR2569071069	String Loss	Warning	17-05-2026 13:39
IOI Mall Puchong (Old Wing)	Inverter 21 R1-TERA	6T2599057796	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 3 R1 - TERA	BN2521059950	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 12 - TERA	BN2461066801	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 2 - TERA	BN2461066770	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 7 - TERA	6T2479017524	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 10 - TERA	6T2469039407	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 4 - TERA	6T2479017517	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 1 - TERA	BN2461065466	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 5 - TERA	BN2461066760	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 6 - TERA	BN2461066754	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 11 - TERA	BN2461066739	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 8 - TERA	BN2461065428	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
IOI Mall Puchong (Old Wing)	Inverter 9 - TERA	6T2479017523	Upgrade Failed or Version Mismatch	Minor	18-04-2026 00:46
LIAN FOO POULTRY FARM SDN BHD	Dongle-BT2541519026	BT2541519026	Network Connection Error	Major	30-04-2026 18:40
LIAN FOO POULTRY FARM SDN BHD	INV-ES2550000030	ES2550000030	Grid Loss	Major	30-04-2026 17:55
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125116	ES25C0125116	Grid Loss	Major	30-04-2026 17:54
LIAN FOO POULTRY FARM SDN BHD	INV-ES25C0125117	ES25C0125117	Grid Loss	Major	30-04-2026 17:54
Lian Teck Seng Lot 11	Dongle-BT24C0060275	BT24C0060275	Network Connection Error	Major	29-01-2026 15:54
MARINE GOLD SDN BHD	Dongle-TA2340293153	TA2340293153	Network Connection Error	Major	26-03-2026 15:55

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
MARINE GOLD SDN BHD	Dongle-TA2340293476	TA2340293476	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-TA2340291437	TA2340291437	Network Connection Error	Major	26-03-2026 15:55
MARINE GOLD SDN BHD	Dongle-HV2310776105	HV2310776105	Network Connection Error	Major	26-03-2026 14:56
MARINE GOLD SDN BHD	Dongle-HV2310776109	HV2310776109	Network Connection Error	Major	26-03-2026 14:55
MARINE GOLD SDN BHD	Dongle-HV2310773587	HV2310773587	Network Connection Error	Major	26-03-2026 14:54
MENARA PKNS PJ	Logger-102466288020	102466288020	Network Connection Error	Major	10-05-2026 01:00
MAIAW FRESH	VASOLAR INV 1	NS2331625509	Grid Loss	Major	15-05-2026 13:06
PKT 12 WAVES	Inverter 4	ES2470045168	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 5	6T2459004824	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 3	6T2449041406	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 7	6T2449033633	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 8	6T2459004809	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 6	ES2470045204	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT 12 WAVES	Inverter 10	6T2449041556	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 1	6T2459004867	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 9	6T2449032075	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT 12 WAVES	Inverter 2	6T2459004831	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:30
PKT THE SHIP	Inverter_7	6T2379019759	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_3	6T2379019623	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_1	6T2379018298	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_5	6T2379019768	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_4	6T2379019776	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_6	6T2379019622	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
PKT THE SHIP	Inverter_2 R1	BN2531021024	Upgrade Failed or Version Mismatch	Minor	15-05-2026 20:32
Pengerang Independent Terminal	Dongle-LAB	TA23B0087782	Network Connection Error	Major	20-04-2026 13:52

Plant Name	Device Name	Device SN	Alarm Name	Severity	Occurrence Time
Pleasure Latex Phase 2	Logger-102347282208	102347282208	Network Connection Error	Major	19-02-2026 03:00
QL FARM SDN BHD	Logger-102466853213	102466853213	Network Connection Error	Major	24-04-2026 10:56
QL FARM SDN BHD	Inverter 2	ES2580051643	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter 1	ES2580051653	Grid Loss	Major	24-04-2026 10:07
QL FARM SDN BHD	Inverter3	ES2490076207	Grid Loss	Major	24-04-2026 10:07
REDANG LAGOON RESORT	Dongle-2102312EHS10N9115979	2102312EHS10N9115979	Network Connection Error	Major	30-01-2026 19:29
REDANG LAGOON RESORT	INV-ES22A0089681	ES22A0089681	Grid Loss	Major	30-01-2026 07:23
SIME KANSAI PAINT SDN BHD	INV-ES2550146111	ES2550146111	Upgrade Failed or Version Mismatch	Minor	19-11-2025 21:35
THP MEDICAL	VASOLAR INV 3	6T2279009018	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 2	6T2279008977	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
THP MEDICAL	VASOLAR INV 1	6T2279009011	Upgrade Failed or Version Mismatch	Minor	15-02-2026 20:22
Toa Paint Kepong Warehouse	Dongle-TA2340293160	TA2340293160	Network Connection Error	Major	18-05-2026 22:45
VINDA PHASE 4 (MSB 3-2)	Inverter7 Phase4 R1	ES2580051502	AC Overcurrent	Major	19-05-2026 08:49
VINDA PHASE 4 (MSB 3-2)	Inverter7 Phase4 R1	ES2580051502	The PV string is short-circuited to the ground.	Major	19-05-2026 08:49

High-temperature Inverters

Plant Name	Inverter Name	Inverter SN	Temperature
AFI BRAKE MANUFACTURING SDN BHD	INV 4 - GROUND FLOOR	HV22B0337098	76.8
AFI BRAKE MANUFACTURING SDN BHD	INV 5 - FIRST FLOOR	HV22B0337097	80.6
AFI BRAKE MANUFACTURING SDN BHD	INV 6 - SECOND FLOOR	HV22A0405534	76.4
AFI BRAKE MANUFACTURING SDN BHD	INV 7 - THIRD FLOOR	HV22B0337096	76.5
AMT PC DISTRIBUTORS SDN. BHD.	INV-6T22B9024620	6T22B9024620	72.7
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-12)	ES2550064320	74.5
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-13)	ES2550064305	74.8

Plant Name	Inverter Name	Inverter SN	Temperature
ASIA WIRE STEEL MESH MANUFACTURERS SDN BHD	Inverter(COM3-15)	ES2550064258	77.4
ATS AIR SOLUTION	INV-HV22A0242778	HV22A0242778	75.9
Advance Vi Tech Lot 1629	INVERTER 2 - TERA	ES2330108240	71.3
Advance Vi Tech Lot 1629	INVERTER 3 - TERA	6T24B9059721	70.0
Apex Uniparts	VASOLAR_INV_1	ES2420001215	77.4
BP PLASTICS BP9	INVERTER 9 (AREA A)	ES24A0149486	75.3
BP PLASTICS HQ	Inverter_2	ES2440060550	73.5
BP PLASTICS HQ	Inverter_6	6T2499021622	77.3
BP PLASTICS HQ	Inverter_8	6T2499021624	73.4
BREMFIELD SDN BHD	INV 1	ES2320221246	73.4
C0102_QL batang kali	150K-MG0(COM3-2)	GR2479026710	75.0
C0149_VERTEX MISSION	HV21B0210137	HV21B0210137	80.0
CHAN KAH WHYE	INV-NS249G082061	NS249G082061	80.5
Dong Sing Food Link Sdn Bhd	Inverter(COM2-1)	ES2570023845	79.0
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 1	6T2569054829	74.2
FDP AND MTB INDUSTRIES SDN BHD	TERA FDP INV 2	ES2580087345	81.3
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 3	6T2569054834	73.0
FDP AND MTB INDUSTRIES SDN BHD	TERA MTB INV 4	ES2580087312	81.0
FOX ONE LOT 14	INV 1	ES2540189953	70.9
FOX ONE LOT 8	TERA INVERTER 2	6T25B9000067	72.3
FOX ONE MARKETING SDN BHD	TERA INV 1	6T2499021789	71.5
Farm Fresh Taiping (Factory)	50KTL-M3(COM1-12)	6T22A9038815	75.4
Fibertex Phase 2	Inv. CarPark Roof A	ES2420001055	74.6
Fibertex Phase 2	Inverter 1 L3	6T23A9016283	77.1
Fibertex Phase 2	Inverter 3 L3	6T2379019737	70.6

Plant Name	Inverter Name	Inverter SN	Temperature
Fibertex Phase 2	Inverter 4 L3	6T2379019613	72.7
Fibertex Phase 2	Inverter 8 L3	6T2379019736	73.6
Fibertex Phase 2	Inverter 9 L3	6T2379019637	72.9
Fibertex Phase 2	Roof 2C Bridge R1	6T2469046697	71.4
Fungiculture	Inverter 1 (M1)	ES22B0022924	71.2
Fungiculture	Inverter 1 (M2)	HV22A0578274	71.0
Fungiculture	Inverter 1 (M3)	ES22B0022997	70.9
Fungiculture	Inverter 2 (M3)	HV22B0337400	77.1
Fungiculture	Inverter 2 (M4)	HV22B0004571	74.3
Fungiculture	Inveter 2 (M1)	HV22B0337398	74.7
GLASS PLASTIC PACKAGING	INV 2 - (No.23)	6T2489010546	80.7
GLASS PLASTIC PACKAGING	INV 3 - (Lot 65999)	6T2489010635	76.8
GLASS PLASTIC PACKAGING	INV 4 - (Lot 65999)	6T2489010593	79.1
Hoon Yuen Furniture	Inverter 1	ES22B0024091	73.2
IOI City Mall Inc. Feeder 1	Inverter 2.1 - TERA	6T22C9011475	70.7
IOI City Mall Inc. Feeder 1	Inverter 2.12 R1	6T2599029683	71.7
IOI City Mall Inc. Feeder 1	Inverter 2.2 - TERA	6T22B9036192	71.4
IOI City Mall Inc. Feeder 1	Inverter 2.5 - TERA	6T22C9011507	71.9
IOI City Mall Inc. Feeder 1	Inverter 2.6 - TERA	6T22C9011480	72.7
IOI Knowledge Vision Sdn Bhd	Tera Inverter 1	NS2481218152	70.0
IOI Knowledge Vision Sdn Bhd	Tera Inverter 2	6T2519015499	70.8
IOI Mall Puchong (New Wing)	Inverter 16 - TERA	6T2449030262	73.8
Jebsen And Jessen Malaysia Sdn Bhd (MHE)	Inverter 2 - Tera	6T2489031215	72.0
Jiann Lih safety product	40KTL-M3(COM1-16)	ES2290059727	70.0
KB AIS SDN. BHD.	Inverter-1	6T21C9025324	74.8

Plant Name	Inverter Name	Inverter SN	Temperature
KISWIRE CORD SDN BHD	VASOLAR_INV_10	6T2269040723	71.8
KISWIRE CORD SDN BHD	VASOLAR_INV_12	HV22A0243263	72.3
KOSSAN PAINT SDN BHD	Inv 1 (Production)	ES2580051607	75.1
KOSSAN PAINT SDN BHD	Inv 2 (Production)	HV2610027701	70.3
Kamma Klang Enterprise	Inverter 1	ES22A0088766	71.8
Kamma Klang Enterprise	Inverter 2	HV22A0153968	85.0
Kiara Bay	Inverter 2 - TERA	ES2330110574	71.5
Kiara Bay	Inverter 3 - TERA	6T2449022934	78.9
Kiara Bay	Inverter 4 - TERA	6T2449023252	79.6
Kiara Bay	Inverter 6 - TERA	ES2350101155	75.0
Kiara Bay	Inverter 8 - TERA	ES2470045868	70.1
Kiara Bay	Inverter 9 - TERA	ES2350101147	74.3
Komplex PKNS Bangi	40KTL-M3(COM1-13)	ES22A0040484	80.4
Komplex PKNS Bangi	50KTL-M3(COM1-14)	6T22A9024868	70.1
Kwang Hua Persendirian meter 2-3-4-5-6	Block B2-Inverter 6 - Meter 6	6T21C9025214	71.9
LAM SOON EDIBLE OILS	INV-2	6T2449022953	73.2
Marbach Asia Pacific Lot17	INV-6T2489012207	6T2489012207	76.6
Marbach Asia Pacific lot 15	INV-6T2489012205	6T2489012205	73.2
Mitsui Copper Foil P3	Inverter 3 (AREA A)	6T24A9009773	76.8
Mitsui Copper Foil P3	Inverter 4 (AREA A)	6T24A9013004	73.8
Multi Choice (M) Sdn Bhd	TERA INV 2	GR2489029048	70.2
Multi Choice (M) Sdn Bhd	TERA INV 3	ES2560208616	81.1
New Age 160	INV 1	6T2469012777	75.3
New Age 160	Inverter 2 R1	6T23B9005979	80.5
New Age 160	Inverter 3-36ktl m3	6T2489036764	79.4

Plant Name	Inverter Name	Inverter SN	Temperature
P.A Food Sdn Bhd 2ATKT	INV-ES2420001275	ES2420001275	85.1
P.A Food Sdn Bhd Lot 10	INV-6T2449029469	6T2449029469	79.1
P.A Food Sdn Bhd Lot 12	INV-6T2449029471	6T2449029471	82.4
P.A. Food Warehouse No. 9	INV-HV2290797189	HV2290797189	73.8
PKT 8 WAVES	Inverter_2	6T2439012020	70.6
Pengerang Independent Terminal	VASOLAR INV 3 CP 1	ES2340146417	71.3
Pengerang Independent Terminal	VASOLAR INV 4 CP 2	6T23A9016705	73.3
Pengerang Independent Terminal	VASOLAR INV7 MC	ES2340146422	79.0
QL ENDAU DEEP SEA FISHING	Inverter 1 (COM1-12)	GR2479028683	77.4
QL ENDAU DEEP SEA FISHING	Inverter 2 (COM3-13)	6T2519005200	78.0
QL ENDAU DEEP SEA FISHING	Inverter 3 (COM3-14)	GR2479020699	74.7
QL ENDAU DEEP SEA FISHING	Inverter 4 (COM3-15)	GR2479020734	75.7
QL ENDAU DEEP SEA FISHING	Inverter 5 (COM3-16)	GR2479028681	76.8
QL ENDAU MARINE	TERA - INV 1	6T2449018663	74.6
QL ENDAU MARINE	TERA - INV 2	6T24C9071297	76.3
QL ENDAU MARINE	TERA - INV 4	GR2479026771	75.8
QL FOODS	TERA INV2_HOSTEL	6T2599013072	74.6
QL Maxincome	Inverter 1	6T2449023173	72.9
QL Maxincome	Inverter 2	6T2489021016	71.0
QL PAJAM PHASE 2	INV 3	6T2549059593	70.9
QL PAJAM PHASE 2	INV 5	6T2559006722	77.1
QI Lot 14	INV-ES24A0149129	ES24A0149129	75.5
QI Lot 16	INV-ES24A0149130	ES24A0149130	73.3
ROYAL KLANG CLUB	Inverter 1	6T2559006760	75.5
RS POLY INDUSTRY	VASOLAR INV 1	ES2420000999	76.1

Plant Name	Inverter Name	Inverter SN	Temperature
RS POLY INDUSTRY	VASOLAR INV 2	ES2420001084	74.2
SABAH CHINESE HIGH SCHOOL (TAK YUEN BUILDING)	50KTL-M3(COM1-2)	ES22A0076308	73.2
SCENT PUR MANUFACTURING SDN BHD NO.35	INV-TA2470078151	TA2470078151	72.4
SCENT PUR MANUFACTURING SDN BHD NO.37	INV-NS245G038275	NS245G038275	82.6
SJK (C) WU TECK	INV 1	6T25B9000135	85.9
SJK ■ C ■ PIN HWA 1	INVERTER-2	ES2560208642	77.8
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-2)	ES2190081056	71.0
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-3)	ES2190075764	70.4
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-4)	ES2190080965	73.2
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-5)	ES2190075672	73.9
SM Chung Chung Hua (PSDN) Klang	60KTL-M0(COM1-6)	ES2190081021	72.2
SP Logistics Sdn Bhd	INV-6T23B9005457	6T23B9005457	77.2
SWEE CHEONG WATCH SDN BHD (Meter 1)	INV-TA2470383341	TA2470383341	75.6
SWEE CHEONG WATCH SDN BHD (Meter 2)	INV-TA2470383489	TA2470383489	71.5
San Soon Seng Food Industries Sdn Bhd	Inv 02 (Racking WH)	6T2549057201	74.9
San Soon Seng Food Industries Sdn Bhd	Inv 06 (GP 2)	ES2480078460	71.0
Succesfuel Sdn. Bhd.	INVERTER 1 R1	6T24C9072224	81.8
THOR SPECIALTIES	INV-ES25C0123936	ES25C0123936	72.9
TOMEI	INV-(12-1)	HV2330348462	84.4
TOMEI	INV-(16-1)	HV2330348376	85.3
TOMEI	INV-(4-1)	HV2330348450	81.0
TOMEI	INV-(4-2)	HV2330348386	82.9
TOMEI	INV-(4-3)	HV2330348461	77.5
TOMEI	INV-(6-1)	HV2330348465	79.7
TOMEI	INV-(8)	HV2330348453	82.0

Plant Name	Inverter Name	Inverter SN	Temperature
TOMEI	INV-(8-2)	HV2330348466	80.1
TOMEI	INV-(8-3)	HV2330348451	79.8
Tembikar Wei Khing	Inverter 8 - TERA	6T2469033043	70.6
Teong Huat Medical	INV-6T2599029908	6T2599029908	73.2
VINDA PHASE 4 (MSB 3-2)	Inverter11 - Phase 4	GR2479020739	71.9
VINDA PHASE 4 (MSB 3-2)	Inverter13 Phase4 R1	ES2580050563	70.5
VISKO INDUSTRIES SDN BHD	VASOLAR_INV_8	ES2180084993	72.0
WASCO PIPE SDN BHD (MILL)	Inverter 4	GR2569101626	70.8
WCS UNIT 6	INVERTER UNIT 6	HV2290931617	72.3