

Improving the Efficiency Of Chilled Water Plants

By Gil Avery, P.E.
Fellow ASHRAE

For the past 30 or more years most central chilled water plants have used primary-secondary pumping arrangements as shown in *Figure 1*. The primary system includes all equipment to the plant side of Points A and B and the secondary system includes all equipment to the load side of these points. The majority of these systems have the chillers staged from flow. As the flow in the secondary starts to exceed the flow in the primary, an additional primary pump and chiller is staged on. As the flow in the secondary decreases, so that one less chiller can handle the reduced flow, a pump and chiller is staged off. This method of control assumes that the load is proportional to flow and that the ΔT between the chilled water supply and return is constant and at the design condition.

These assumptions are generally wrong. Systems rarely operate at design ΔT because of coils that are dirty, inadequate coil control valves, thermostats that are set wrong, excessive temperature drops in the supply and return mains, etc. Therefore, flow is not a reliable indication of load. As a result, the vast majority of central chilled water plants operate inefficiently with lower than design ΔT s and with more partially loaded chillers on-line than would be necessary if the chillers were properly staged.

The Way It's Been Done

The typical primary/secondary system shown in *Figure 1* is fully loaded at the outdoor design conditions of 95°F (35°C) dry bulb and 78°F (25.5°C) wet bulb. The system is operating as designed with 6,000 gpm (379 L/s) of 45°F (7°C) supply water and 57°F (13.8°C) return water (2 gpm/ton [0.03 mL/J]). Each of the three 1,000 ton (3517 kW) chillers and companion pumps are handling 2,000 gpm (126 L/s). The fourth standby pump is off.

In *Figure 2* the load is only 600 tons (2110 kW). The ΔT is 6°F (3.3°C) (4 gpm/ton [0.07 mL/J]), which is typical of many systems designed to operate at a higher ΔT . Two pumps and chillers are on-line, with each chiller inefficiently loaded to 300 tons (1055 kW); 4,000 gpm (252 L/s) is circulated in the primary, 1,600 gpm (101 L/s) through the bypass and 2,400 gpm (151 L/s) (600 tons \times 4 gpm/ton [2110 kW \times 0.07 mL/J]) in the secondary. If the system were properly staged and piped, one chiller could easily handle the 600 ton (2110 kW) load.

In *Figure 3* the load has increased to 1,500 tons (5275 kW); 6,000 gpm (379 L/s) is circulating in the primary and secondary systems with no flow in the bypass. Three inefficiently loaded chillers and three pumps are on-line. Two chillers could handle the load.

To satisfy the 1,600 ton (5627 kW) load in *Figure 4*, 6,400 gpm (404 L/s) (1,600 \times 4 gpm/ton [5627 \times 0.07 mL/J]) is required. The flow in the secondary now exceeds the primary flow of 6,000 gpm (379 L/s),

and return water through the bypass starts to mix with the supply water. This raises the supply water temperature and the air-handling unit control valves start to open, thus increasing both the secondary and bypass flow. Temperature control in the conditioned spaces is lost, even though only about half of the central plant capacity is used. When chillers are staged from flow and are controlled at the design leaving chilled water temperature, the approximate maximum system capacity is:

$$\frac{(\text{Operating } \Delta T) \times (\text{Design Capacity})}{\text{Design } \Delta T}$$

Very often facilities with operating conditions such as these will add an additional chiller and pump even though the existing plant would have sufficient capacity if the chillers were piped and staged properly. Adding more equipment is not the solution. The secondary pump and piping is not designed for the additional flow.

The capacity of a chiller, using hydrocarbon-based refrigerant, increases from 0.5% to 1.5% for every degree decrease in entering condenser water temperature. However, the increase in chiller capacity at a lower kW/ton cannot be used when chillers are staged from flow. Whenever the flow exceeds the design flow of the chiller in the typical primary/secondary system, the next machine is staged on even though the operating machine(s) are not fully loaded. The maximum capacity of any machine never goes above the 100% capacity abscissa line in *Figure 5*. Most chillers are rated at 85°F (29°C) entering condenser water temperature, a condition that may exist less than 2% of the year. At other times whenever the outdoor wet bulb and

About the Author

Gil Avery, P.E., is a principal in The Kele Companies in Memphis, Tenn.




Figure 1: A typical primary/secondary chiller system fully loaded at the outdoor design conditions of 95°F (35°C) dry bulb and 78°F (25.5°C) wet bulb.




Figure 2: A typical primary/secondary chiller system with a load of only 600 tons (2110 kW).




Figure 3: A typical primary/secondary chiller system with the load having increased to 1,500 tons (5275 kW).




Figure 4: A typical primary/secondary chiller system with a 1,600 ton (5627 kW) load.

entering condenser water temperature is less than design, the chiller capacity will increase and the kW/ton will decrease. This higher efficiency and lower kW/ton operating range is in the shaded area above the 100% capacity abscissa line in Figure 5. A high-efficiency chiller may operate at 0.55 kW/ton with 85°F (29°C) condenser water and at 0.34 kW/ton with 55°F (12.7°C) condenser water. Most 1,000 ton (3517 kW) chillers may therefore produce more than 1,100 tons (3869 kW) when the entering condenser water temperature is 65°F–70°F (18°C–21°C).

The majority of primary/secondary chilled water plants operate similar to those depicted in Figures 2 and 3, with too many chillers on-line for efficient operation. Minimizing the number of chillers on-line reduces the plant kW/ton since the unneeded pumps and auxiliary devices are also off-line.

Improving The Efficiency

Although the remedy is relatively simple and inexpensive, operators are hesitant to change, thinking, “That was the way the system was designed to operate.” Initially everything possible must be done to correct the issues contributing to the low ΔT . Then change the way the chillers are staged on and off and install a check valve in the bypass line at Point C as shown in Figure 4 to prevent return water from mixing with supply water. The check valve and bypass line should be sized to handle the minimum flow of the largest chiller. A non-slammng check valve with a manual opening device is generally used. A temperature sensor in the secondary supply water, set low enough to satisfy the load requiring the coldest water, will stage the chillers on. They are staged off by another sensor in the secondary




Figure 5: Percent of rated capacity vs. outdoor wet-bulb temperature.




Figure 6: A single pump primary-secondary chilled water system.




Figure 7: Multi-plexed sources and loads.

return water and by measuring the load ($\text{flow} \times \Delta T$). When the load decreases below the capacity of an on-line chiller, that chiller and pump is staged off. The sensors in the supply and return lines must be matched sensors with an accuracy of $\pm 0.10^\circ\text{F}$ (0.5°C). These changes generally have been shown to reduce the kW/ton by 10 to 20%.

Most chillers will operate satisfactorily with evaporator tube water velocities between 3 and 12 fps (0.9 and 3.6 m/s). Under certain conditions (e.g., startup), the flow in the secondary will exceed the primary design flow and the primary and secondary pumps will then be in series. There will be a slight increase in the flow through the chillers under these conditions but since the flow varies as the square of the head, the actual increase will rarely exceed 10% above design. An increase in flow even this great would require an increase in pump head of over 20% a condition unlikely to occur with the usual centrifugal pumps that are chosen with flat pump curves.

Single Pump Primary/Secondary System

For new construction, the central plant can be designed us-

ing a single pump, as shown in Figure 6. Conventional primary pumps are usually large, low-speed, low-head pumps that require an excessive amount of floor space. Their elimination can materially reduce the initial cost of the system.

The differential pressure sensor "DP-1" controls bypass valve "V-4" to maintain a minimum differential (minimum flow) across the chiller evaporators. When a chiller is staged on and the differential pressure decreases, the processor will modulate valve "V-4" open. When the coil valves or bypass valve "V-4" opens, the differential pressure at sensor "DP-2" will decrease and the processor will ramp up the speed of pump "P-1" through the drive "VFD" to maintain a constant differential across the ends of the supply and return mains. Flow at sensor "FS-1" and temperature at sensors "T-1" and "T-2" are used by the processor to stage the chillers on and off using the sequence described previously. Valves "V-1," "V-2," and "V-3" are closed when their respective chiller is off. Similar controls have been applied for many years to constant flow systems that were converted to variable flow and only one pump was available. Although flow sensor "FS-1" is shown, the differential pres-




Figure 8: Tertiary pumping system.

sure measured by "DP-1" across the chiller evaporators can be used to calculate the flow.

The accuracy of this method of calculating flow increases in proportion to the number of chillers in the central plant. Each evaporator circuit acts as an orifice. As long as the system is closed to the atmosphere, there will not be a significant change in pressure drop through the evaporator tubes as the system ages. On plants with three or more chillers, the accuracy approaches that of most flow sensors.

The bypass valve "V-4" and bypass line should be sized to handle the minimum flow of the largest chiller. The drop across the bypass and valve must be less than the minimum operating differential (setting of "DP-2"). Valve "V-4" must be coupled to an actuator that can close off against the full head of the secondary system. Correctly sized industrial metal-seated butterfly or ball valves are a good choice if they are selected to withstand the system dynamic forces.


Decentralized Systems

Outlying buildings on campuses and institutional complexes may have chilled water sources that can be connected to the chilled water system through the supply and return manifold as shown in Figure 7. Building A houses the chilled water or ice storage facility. Building B has an existing chiller and load. Buildings C and E have a load and source respectively. Building D houses the central chiller plant. All sources pump out of the return manifold through the cooling source and into the supply manifold. All loads are pumped out of the supply manifold through the load and into the return manifold. Two position valves "V-1" are used to isolate inactive loads and sources. Multiplexing all of the chilled water sources and loads in this manner has many advantages. Any source or combination of sources can serve any load or combination of loads any place on the manifold. Loads and sources can be matched to provide the most efficient operation. Manifold piping is smaller and less expensive than conventional loop piping. Chiller redundancy is maximized. A detailed method of controlling loads and sources is found in (Avery 1987).

Tertiary Pumping Systems

Tertiary loads on central systems are generally piped in the customary fashion as shown in Figure 8. Temperature sensor "T-1" controls valve "V-1" to maintain the design supply chilled water temperature. Differential pressure sensor "DP-1" con-

PUT YOUR BIG AIR HANDLER UP ON A PEDESTAL.



The Pedestal™ Plenum Curb

The Pedestal™ Plenum Curb from Conn-Fab is designed to meet your tightest specs and toughest applications — no matter how large the air handler.

Constructed of minimum 14 ga. galvanized steel, fully reinforced and insulated, the Pedestal is built for years of trouble-free, code-compliant service. There's simply no better built curb for large air handling units.



Conn-Fab Catwalk offers easy, trouble-free access

An ideal companion for the Pedestal, the Conn-Fab Catwalk is cantilevered from the curb itself, so it never touches the roof or the air handler. Easily installed, it complies with all OSHA specs.

For more information about our innovative Pedestal Curbs, Adapter Curbs or Catwalks, please contact Conn-Fab Sales directly.

Circle No. 13 on Reader Service Card or visit www.pub-serv.com/rs/ashrae

CONN-FAB

Conn-Fab Sales, Incorporated • P.O. Box 388
Uncasville, CT 06382-0388
Phone (860) 848-9266 • Fax (860) 848-0503

controls the speed of the building pump through the variable frequency drive "VFD." This method of piping and control does not take advantage of the differential pressure that is available between the supply and return mains. The pressure is wasted across valve "V-1." A preferred method of piping the tertiary system is shown in *Figure 9*. The differential pressure sensor "DP-1" controls valve "V-1" in sequence with the speed of the pump through the variable frequency drive "VFD." As the load in the building increases, valve "V-1" modulates open. On a continued drop in differential pressure, pump "P-1" will start and ramp up to the speed required to maintain the design differential pressure at "DP-1." The cycle reverses on a rise in differential pressure. Using the pressure between the supply and return mains reduces the building pumping energy.

Summary

The use of the typical primary/secondary paradigm shown in *Figure 1* may be costing building owners millions of dollars in additional operating costs because of the inefficient nature of these systems. There are better ways of designing chilled water systems. It's time to get our heads out of the 1950s and start using what we've learned since then.

Bibliography

Avery, G. 1987. "Microprocessor control for large chilled water




Figure 9: Tertiary booster pumping system.

distribution systems." *Heating/Piping/Air Conditioning Engineering*.

Avery, G. 1993. "Designing and commissioning variable flow hydronic systems." *ASHRAE Journal* 35(7):45-49.

Avery, G. 1998. "Controlling chillers in variable flow systems." *ASHRAE Journal* 40(2):42-45.

Avery, G. 2000. "Selecting valves and piping coils." *ASHRAE Journal* 42(4):23-27. ●

ELECTRONIC FLOWHOOD DIRECT DIGITAL READOUT 25-2500 CFM



AUTOMATICALLY CORRECTS FOR AIR DENSITY & BACKPRESSURE
CHOICE OF METERS - AIR FLOW ONLY, OR AIR FLOW, VELOCITY, PRESSURE & TEMPERATURE
OPTIONS INCLUDE: MEMORY, AVERAGE & SUM TO 100 READINGS, SEQUENTIAL RECALL, AUTO-READ
REPAIR POLICY - TWO WEEK TURNAROUND OR LESS
CUSTOM TOPS MADE TO ORDER

Shortridge Instruments, Inc.

7855 East Redfield Road • Scottsdale, Arizona 85260
(480) 991-6744 FAX (480) 443-1267

Circle No. 25 on Reader Service Card or visit www.pub-serv.com/rs/ashrae

Our complete library of Magic Aire® HVAC Product Catalogs, Specifications, Submittals and Performance Programs
now available online at

magicaire.com

Instant access to the information and tools you need to make your job easier, faster and more productive!

Magic Aire®

AIR HANDLERS • COILS • ROOFTOPS • UNIT VENTILATORS
501 Galveston Street • Wichita Falls, Texas 76301
(940) 397-2100 • FAX (940) 397-2166

Circle No. 23 on Reader Service Card or visit www.pub-serv.com/rs/ashrae