

Document no. : 6207378.01COC

Ratings of the Grid-connected PV Inverter:

Valutazioni dell'inverter fotovoltaico collegato alla rete:

Operating temperature range: - 25°C to + 60°C

Protective class: I

Ingress protection rating: IP65

Power factor range (adjustable): 0.8 leading...0.8 lagging

T3-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 3000VA, max apparent power 3300 VA, rated 4.3 A, max 4.8 A

T4-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 4000VA, max apparent power 4400 VA, rated 5.8 A, max 6.4 A

T5-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 5000VA, max apparent power 5500 VA, rated 7.2 A, max 8.0 A

T6-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 6000VA, max apparent power 6600 VA, rated 8.7 A, max 9.6 A

T8-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 8000VA, max apparent power 8800 VA, rated 11.6 A, max 12.8 A

T8(Dual)-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 8000VA, max apparent power 8800 VA, rated 11.6 A, max 12.8 A

T10-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 10000VA, max apparent power 11000 VA, rated 14.5 A, max 15.9 A

T10(Dual)-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 10000VA, max apparent power 11000 VA, rated 14.5 A, max 15.9 A

T12-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 14 A /14 A, Isc PV: 18.2 A/18.2 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 12000VA, max apparent power 13200 VA, rated 17.4 A, max 19.1 A

T12(Dual)-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 12000VA, max apparent power 13200 VA, rated 17.4 A, max 19.1 A

T15-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 15000VA, max apparent power 16500 VA, rated 21.7 A, max 23.9 A

T17-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Annex



Document no. : 6207378.01COC

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 17000VA, max apparent power 18700 VA, rated 24.6 A, max 27.1 A

T20-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 20000VA, max apparent power 22000 VA, rated 29.0 A, max 31.9 A

T23-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 23000VA, max apparent power 25300 VA, rated 33.3 A, max 36.7 A

T25-G3:

PV input: Max. 1100 Vdc, MPPT voltage range: 140-1000 Vdc, max 28 A /28 A, Isc PV: 36.4 A/36.4 A

Output: 3/N/PE, 230/400 Vac, 50/60 Hz, rated apparent power 25000VA, max apparent power 27500 VA, rated 36.2 A, max 39.9 A

Type of generating unit:

Tipologia di apparato:

Static Conversion Device <i>Dipositivo di conversione statica</i>	Interface Protection <i>Protezione di interfaccia</i>	Interface Protection Device <i>Dispositivo di interfaccia</i>	Rotating Generator Device <i>Dispositivo di generazione rotante</i>
Yes/Sì	Yes/Sì	Yes/Sì	No/No

REMARK: the device is capable to limit the Idc to 0.5% of the nominal current

NOTA: Il dispositivo è in grado di limitare la Idc allo 0.5% della corrente nominale

Hardware version: V1.2

Versione hardware: V1.2

Firmware release (SW): V1.00

Revisione firmware (SW): V1.00

Testing Laboratory:

Laboratorio prove:

Testing Laboratory for CEI 0-21:2022-03+V1:2022-11+V2:2024-01

DEKRA Testing and Certification (Suzhou) Co., Ltd.

No. 99, Hongye Road, Suzhou Industrial Park Suzhou, 215006, P.R. China

Accreditation Number: L5313 (CNAS-ILAC)

--- End ---



CERTIFICATE OF CONFORMITY

CERTIFICATO DI CONFORMITÀ

Issued to: FOXESS CO., LTD.
Rilasciato a: Room A203, Building C, No. 205, Binhai Six Road, New Airport Industry Area,
Longwan District, Wenzhou City, Zhejiang Province, P.R. China

For the product: Grid-connected PV Inverter
Tipo prodotto:

Trade name:
Marchio:



Type/Model: T3-G3, T4-G3, T5-G3, T6-G3, T8-G3, T8(Dual)-G3, T10-G3, T10(Dual)-G3, T12-G3,
Riferimento modello: T12(Dual)-G3, T15-G3, T17-G3, T20-G3, T23-G3, T25-G3

Ratings: See Annex
Dati di targa:

Manufactured by: FOXESS CO., LTD.
Costruttore: Room A203, Building C, No. 205, Binhai Six Road, New Airport Industry Area,
Longwan District, Wenzhou City, Zhejiang Province, P.R. China

Requirements: CEI 0-21:2022-03+V1:2022-11+V2:2024-01
Requisiti: *Regola tecnica di riferimento per la connessione di Utenti attivi e passivi alle reti BT delle imprese distributrici di energia elettrica*

The tested models are suitable for installation in systems with a total power greater than 11.08 kW.

I modelli testati sono adatti per l'installazione in sistemi con potenza di uscita maggiore di 11.08 kW.

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6207378.50

Il presente certificato è rilasciato a causa di un esame da parte di DEKRA, i cui risultati sono riportati in un file riservato n. 6207378.50

The examination has been carried out on one single specimen of the product. The certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

L'esame è stato effettuato su un unico esemplare del prodotto. Questo attestato di conformità è rilasciato sulla base dei risultati di prova riferiti nel rapporto sopra menzionato. La valutazione non include una verifica della produzione di serie né del luogo di produzione.

This Test Certificate expires at the latest on 2029-11-22 or expires upon withdrawal of one of the above mentioned standards.

Il presente certificato di prova scade al più tardi il 2029-11-22 o scade al momento del ritiro di uno dei suddetti standard.

Shanghai, 22 November 2024

Certificate Number: 6207378.01COC

DEKRA Testing and Certification (Shanghai) Ltd.


Cliff Lin
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



DEKRA Testing and Certification (Shanghai) Ltd.

No.250, Jiangchangsang Road, Jing'an District, Shanghai, 200436 People's Republic of China

T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com

ESA-CER-F021 v4.1