



- NOTES
1. CUSTOMER TO SIZE AND PROVIDE THE FOLLOWING CABLES:
    - MV FEEDER CABLES
    - AC CABLES FROM AUXILIARY DISTRIBUTION BOARD TO CONTAINERS
    - DC CABLES FROM MAIN DC DISCONNECT TO INVERTERS
  2. THE PROJECT SLD IS FOR ILLUSTRATION PURPOSES ONLY. NUMBER OF PCS-BESS CONTAINER BLOCKS PER FEEDER AND NUMBER OF FEEDERS WILL CHANGE FOR EACH PROJECT.

0	17SEPT'24	INITIAL DESIGN	ND	HD	HA
REV	DATE	DESCRIPTION	DWN	CHK'D	APP'D
PROJECT					
TITLE					
ELECTRICAL TYPICAL BATTERY BLOCK SLD					
EXPORT ADMINISTRATION REGULATIONS WARNING THIS DOCUMENT CONTAINS TECHNICAL DATA WHICH IF EXPORTED FROM THE UNITED STATES MUST BE EXPORTED IN ACCORDANCE WITH THE EXPORT ADMINISTRATION REGULATIONS, DIVERSION CONTRARY TO U.S. LAW IS PROHIBITED.					
CONFIDENTIAL & PROPRIETARY THIS DOCUMENT CONTAINS COMPANY CONFIDENTIAL AND PROPRIETARY INFORMATION OF PREVALON. NEITHER THIS DOCUMENT, NOR ANY INFORMATION OBTAINED THEREFROM IS TO BE REPRODUCED, TRANSMITTED, OR DISCLOSED TO ANY THIRD-PARTY WITHOUT FIRST RECEIVING THE EXPRESS WRITTEN AUTHORIZATION OF PREVALON.					
©PREVALON, INC. ALL RIGHTS RESERVED					
SECURITY LEVEL	EXPORT CLASSIFICATION	REASON FOR CONTROL			
SL2	EAR99	NLR			
STATUS		RELEASE DATE			
<b>NOT FOR CONSTRUCTION</b>		17SEPT'24			
SIZE		SCALE			
ANSI D		AS SHOWN			
DRAWING NUMBER					REVISION
XDM-000000-100s1					0