



- NOTES**
- BUYER TO SIZE AND PROVIDE FOLLOWING CABLES:
 - MV FEEDER CABLES
 - AC CABLES FROM AUXILIARY AC PANEL TO THE ENCLOSURES
 - DC CABLES FROM MAIN DC DISCONNECT OF THE ENCLOSURE TO THE DC INPUT OF THE INVERTER
 - EQUIPMENT RATING SHOWN ARE NAMEPLATE VALUES.
 - THIS DOCUMENT ONLY SHOWS EQUIPMENT IN PREVALON'S SCOPE AT BOL.
 - FINAL SITE LEVEL SLD IN BUYER'S SCOPE, AS REQUIRED, SITE LEVEL SLD TO ALSO INCLUDE EQUIPMENT OUTSIDE OF PREVALON'S SCOPE INCLUDING BUT NOT LIMITED TO AUX TRANSFORMERS AND AC PANELS, AUGMENTATION EQUIPMENT REQUIRED OVER THE LIFE OF PROJECT, MV SWITCHGEAR, SUBSTATION YARD ETC.

NOT FOR CONSTRUCTION

100.00 MW / 400.00 MWh

Pilot Project, Lake Mary


PREVALON
A Mitsubishi Power Americas and EES Joint Venture

PROJECT SINGLE LINE DIAGRAM

EXPORT ADMINISTRATION REGULATIONS WARNING
THIS DOCUMENT CONTAINS TECHNICAL DATA WHICH IF EXPORTED FROM THE UNITED STATES MUST BE EXPORTED IN ACCORDANCE WITH THE EXPORT ADMINISTRATION REGULATIONS. DIVERSION CONTRARY TO U.S. LAW IS PROHIBITED.

CONFIDENTIAL & PROPRIETARY
THIS DOCUMENT CONTAINS COMPANY CONFIDENTIAL AND PROPRIETARY INFORMATION OF PREVALON NEITHER THIS DOCUMENT, NOR ANY INFORMATION OBTAINED THEREFROM IS TO BE REPRODUCED, TRANSMITTED, OR DISCLOSED TO ANY THIRD-PARTY WITHOUT FIRST RECEIVING THE EXPRESS WRITTEN AUTHORIZATION OF PREVALON.
© PREVALON, INC. ALL RIGHTS RESERVED

SECURITY LEVEL - SL2	EXPORT CLASSIFICATION - EAR99
REASON FOR CONTROL - NLR	DRAWING RELEASE DATE: 2024-08-05