



COMPANY	Wayfair
STREET	1600 Donaldson Hwy
CITY, STATE, ZIP	Erlanger, KY 41018
PHONE	(937) 726-4903

DATE	8/29/2024
EMAIL	bharter@linklogistics.com
CONTRACT NO.	36396439
INSPECTED BY	Mike Burroughs, Jesus Izquierdo

SYS. NO.	TYPE OF SYSTEM	VALVE LOCATION	VALVE MODEL	PRESS BEFORE	FLOW PRESS	PRESS AFTER	WATER FLOW TIME	Comments	
1	Wet	Warehouse	6" Victaulic Firelock	174	167	173			+
2	Wet	Warehouse	6" Victaulic Firelock	173	162	172			+
3	Wet	Warehouse	6" Victaulic Firelock	172	166	172			+
4	Wet	Warehouse	6" Victaulic Firelock	183	150	181			+
5	Wet	Warehouse	6" Victaulic Firelock	174	161	173			+
6	Wet	Warehouse	6" Victaulic Firelock	176	164	176			+
7	Wet	Warehouse	6" Victaulic Firelock	170	164	169			+
8	Wet	Warehouse	6" Victaulic Firelock	168	161	167			+
9	Wet	Warehouse	6" Victaulic Firelock	174	166	172			+
10	Wet	Warehouse	6" Victaulic Firelock	171	163	168			+
11	Wet	Warehouse	6" Victaulic Firelock	178	162	174			+
12	Wet	Warehouse	6" Victaulic Firelock	174	160	172			+
13	Wet	Warehouse	6" Victaulic Firelock	181	172	178			+
14	Wet	Warehouse	6" Victaulic Firelock	183	168	177			+
15	Wet	Warehouse	6" Victaulic Firelock	178	167	175			+
16	Wet	Warehouse	6" Victaulic Firelock	179	164	176			+
17	Wet	Warehouse	6" Victaulic Firelock	180	163	178			+
18	Wet	Warehouse	6" Victaulic Firelock	177	158	174			+
19	Wet	Warehouse	6" Victaulic Firelock	181	167	179			+
20	Wet	Warehouse	6" Victaulic Firelock	172	162	174			+
21	Wet	Warehouse	6" Victaulic Firelock	176	166	175			+
22	Wet	Warehouse	6" Victaulic Firelock	174	161	172			+
23	Wet	Warehouse	6" Victaulic Firelock	175	169	175			+
24	Wet	Warehouse	6" Victaulic Firelock	177	165	176			+
25	Wet	Warehouse	6" Victaulic Firelock	172	159	170			+
2A	Wet	Ware	6" straight pipe	171	166	171			