

- D. Information for approval should also include stainless steel reinforcement and joint sealant for spiral wound pipe liners.
- E. Patch repair installations are to be completed as per International Standards and subject to ADM approval.

29.1.4.2 Method Statements

- A. The Contractor shall submit method statements to the Engineer for approval 4 weeks in advance of commencing the site activity in accordance with Section 01300 of the specification. These shall comprise but not necessarily be limited to:
- B. Sewage bypass pumping and/or diversion plan which shall include an emergency response plan to be followed in the event of a failure of the bypass pumping and/or diversion plan.
- C. Detailed construction plan including:
 - i. Equipment set-up and locations of proposed access points.
 - ii. Anticipated cut off periods for services.
 - iii. Procedures for verification of active service connections.
 - iv. Procedures for notifying affected residences and businesses.
 - v. Procedures for complying with traffic control.
 - vi. Procedures to be adopted to obtain permits to work from the ADM Operation and Maintenance Section.
 - vii. Safety procedures in particular working with scaffolding, entering confined spaces and operations with hot media.
 - viii. Storm Water system cleaning procedures.
 - ix. Liner installation procedures.
 - x. Procedures for sealing annular space between liner pipe and host pipe where applicable.
 - xi. Methods of sealing any annular space between liner pipe and host pipe at manholes.
 - xii. Procedures for manhole rehabilitation.
 - xiii. Procedure for any required modifications either temporary or permanent to existing manholes such as widening of access opening, removal of cover slabs, removal of intermediate landings and ladders, and removal of manhole benching etc.