

Provisions for Public Spaces

Facility/Building

Space/Floor

Sheet Number

YES

N/A

NON

Observations

Furniture and signals are aligned and don't invade the accessible path				
If there is a cycling paths it's between urban furniture and curb				
Pedestrian crossings are preceded by tactile warnings				
For pedestrian streets, areas between buildings are level				
Shaded zones are provided at least every 50 m				
Street names are displayed at any crossing				
There are information signs about the nearest public transport, public toilets and interest points				
There information panels every two crossings				
There are toilets at least every 400 m				
Traffic signals have sound signals				
When required, pick-up and drop-off areas are provided				