

working width for the type of plant using the roadway. This width should not exceed 10m.

- b. Crossings should be restricted to the smallest possible number and should be fenced to give a clear indication of the roadway.
- c. Goalposts should be erected on both sides of the overhead line to act as both gateways and height limit.
- d. Height and position of such goalposts will depend on the voltage of the overhead line and ADWEA should be contacted to advice on clearance required.

### **18.1.9 Setting up Site**

A. Setting up site shall be undertaken in accordance with the following particular requirements:

#### **1. Site Security**

- a. At all sites where it is reasonably practicable to do so, a fence should be erected enclosing all construction activities. In this case:
  - i. The fence should not be less than 2m high and not be capable of being easily climbed.
  - ii. Should be close boarded or covered with mesh of a size not exceeding 30mm.
  - iii. All support posts must be securely anchored and fencing properly maintained.
  - iv. Site access opening should be fitted with gates, which should be manned during working hours, and locked off during nonworking hours.
  - v. Suitable warning notices should be fixed to the fence.

#### **2. Electrical Installation**

- a. The Contractor shall prior to the connection of power ensure the following:
  - i. Contact certified and trained staff from the relevant authority to carry out an initial inspection of electrical mains and sub mains distribution boards.
  - ii. Ensure installation is checked by ADWEA or their associated group companies.