

## Entrances, Counter and reception areas

Facility/Building .....

Space/Floor .....

Sheet Number .....

YES

N/A

NON

Observations

<b>Gradients of entrances <math>\leq 5\%</math></b>				
<b>When several paths, both accessible and inaccessible marked</b>				
<b>If accessible door not the main door, it is marked with directional sign</b>				
<b>Identification and exact address</b>				
<b>In public use buildings, reception desk near the entrance</b>				
<b>Dimensions doors <math>\geq 900</math> mm width x 2100 mm height</b>				
<b>Automatic door</b>				
<b>Doormats levelled with <math>\pm 2</math> mm</b>				
<b>Access controls barriers with at least one barrier with width <math>\geq 900</math> mm</b>				

## Counters and reception areas

<b>Reception areas with seating places and interaction spaces</b>				
<b>Front desks with accessible interaction space</b>				
<b>Low counter height between 750 - 790 mm and high counter height between 950 - 1250 mm</b>				
<b>Under the desk a space of 680 mm height and 480 mm deep</b>				