TABLE 1507.3.7 CLAY AND CONCRETE TILE ATTACHMENT[a,b,c]

<table>
<tr><th colspan="5">GENERAL-CLAY OR CONCRETE ROOF TILE</th></tr>
<tr><th>Maximum basic wind speed (mph)</th><th>Mean roof height (feet)</th><th>Roof slope up to < 3:12</th><th colspan="2">Roof slope 3:12 and over</th></tr>
<tr><td>85</td><td>0-60</td><td rowspan="2">One fastener per tile. Flat tile without vertical laps, two fasteners per tile.</td><td colspan="2" rowspan="2">Two fasteners per tile. Only one fastener on slopes of 7:12 and less for tiles with installed weight exceeding 7.5 lbs./sq. ft. having a width no greater than 16 inches.</td></tr>
<tr><td>100</td><td>0-40</td></tr>
<tr><td>100</td><td>> 40-60</td><td colspan="3">The head of all tiles shall be nailed. The nose of all eave tiles shall be fastened with approved clips. All rake tiles shall be nailed with two nails. The nose of all ridge, hip and rake tiles shall be set in a bead of roofer's mastic.</td></tr>
<tr><td>110</td><td>0-60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><td>120</td><td>0-60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><td>130</td><td>0-60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><td>All</td><td>> 60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><th colspan="5">INTERLOCKING CLAY OR CONCRETE ROOF TILE WITH PROJECTING ANCHOR LUGS[d,e]
(Installations on spaced/solid sheathing with battens or spaced sheathing)</th></tr>
<tr><th>Maximum basic wind speed (mph)</th><th>Mean roof height (feet)</th><th>Roof slope up to < 5:12</th><th>Roof slope 5:12 < 12:12</th><th>Roof slope 12:12 and over</th></tr>
<tr><td>85</td><td>0-60</td><td rowspan="2">Fasteners are not required. Tiles with installed weight less than 9 lbs./sq. ft. require a minimum of one fastener per tile.</td><td rowspan="2">One fastener per tile every other row. All perimeter tiles require one fastener. Tiles with installed weight less than 9 lbs./sq. ft. require a minimum of one fastener per tile.</td><td rowspan="2">One fastener required for every tile. Tiles with installed weight less than 9 lbs./sq. ft. require a minimum of one fastener per tile.</td></tr>
<tr><td>100</td><td>0-40</td></tr>
<tr><td>100</td><td>> 40-60</td><td colspan="3">The head of all tiles shall be nailed. The nose of all eave tiles shall be fastened with approved clips. All rake tiles shall be nailed with two nails The nose of all ridge, hip and rake tiles shall be set in a bead of roofer's mastic.</td></tr>
<tr><td>110</td><td>0-60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><td>120</td><td>0-60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><td>130</td><td>0-60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><td>All</td><td>> 60</td><td colspan="3">The fastening system shall resist the wind forces in Section 1609.5.3.</td></tr>
<tr><th colspan="5">INTERLOCKING CLAY OR CONCRETE ROOF TILE WITH PROJECTING ANCHOR LUGS</th></tr>
</table>