




PLAN  
(ITEM 3 & SURROUND OMITTED)  
SCALE 1 : 20



SECTION 'A-A'  
SCALE 1 : 20



SECTION 'C-C'  
(ITEM 3 & CONCRETE SURROUND OMITTED)  
SCALE 1 : 20



SECTION 'B-B'  
SCALE 1 : 20

ITEM	DESCRIPTION	DRG No.	No. OFF
1	BOLTS, FOUNDATION, INDENTED No. 2	EP 1022	4
2	CABLE BEARERS WALL TYPE No. 2	EP 1010	2
3	FRAME & COVER CARRIAGE WAY TYPE No. 4	EP 1095	1
4	REINFORCEMENT BAR 10 DIA. x 660		8
5	REINFORCEMENT BAR 10 DIA. x 845		14
6	REINFORCEMENT BAR 10 DIA. x 1115		8
7	REINFORCEMENT BAR 10 DIA. x 150		16
8	REINFORCEMENT BAR 10 DIA. x 710		2
9	REINFORCEMENT BAR 10 DIA. x 1165		2
10	BRACKET CABLE BEARER No. 3	EP 1110	2
11	PIN LOCKING CABLE BEARER	EP 1018	2

SCHEDULE

## NOTES:

- ALL DIMENSIONS ARE IN MILLIMETRES.
- DO NOT SCALE FROM THE DRAWING.
- FOR METHOD OF FIXING ITEM 3 SEE DRG. CN 1961z
- END DUCTS MUST BE IN LINE.
- REINFORCEMENT MAY BE REPOSITIONED SLIGHTLY TO CLEAR DUCTS WHEN NECESSARY.
- 50MM. MIN. COVER IN ALL REINFORCEMENT EXCEPT CONCRETE SURROUND REINFORCEMENT WHICH HAS 25MM MINIMUM COVER.
- ITEM 7 SPACED AT 230MM PITCH IN SIDE WALLS & 230MM PITCH IN END WALLS.
- EXACT LOCATION OF WATER BAR TO SUIT KICKER DETAIL.
- FURNITURE ITEMS 9a & 9b ARE NOT SHOWN ON DRAWING.

## NOTES FOR PROTECTION OF UNDERGROUND CONCRETE

IT IS MANDATORY TO PROTECT ALL UNDERGROUND CONCRETE STRUCTURES WHICH INCLUDES THE FOLLOWING WITH ONE LAYER OF SELF ADHESIVE MEMBRANE BITUTHENE 1000 X Hc OR PREMISEAL 100 WITH PROTECTION BOARD 'SERVPAK' 3mm OR 'APOC' 3mm THICK OR EQUAL APPROVED.

- OUTER SURFACE OF WALLS OF ALL JOINT BOXES AND MANHOLES.
- BOTTOM SURFACE OF BASES OF ALL JOINT BOXES/MANHOLES
- OUTER SURROUNDING SURFACES OF ALL CABINET/KIOSK BASES INCLUDING BOTTOM.
- OUTER SURFACES OF SHAFTS AND UPPER SURFACE OF ROOF OF ALL MANHOLES.

OR

-ANY OTHER CONCRETE STRUCTURE WHICH ARE IN CONTACT WITH EARTH AROUND.

\* FOR REFERENCE ONLY

ITEMS 10 & 11 INCLUDED IN SCHEDULE

H	DWG. QUALITY IMPROVED.	VA	24-4-08
G	ITEMS 9a & 9b INCLUDED IN SCH & NOTE 9 ADDED	MKT23-2-04	CHALL
F	REVISED	MKT18-10-01	
E	PREPARED IN CAD.	MKT28-10-97	
	AMENDMENTS	DRN	DATE
		APPD	

ETISALAT	الاتصالات
EMIRATES TELECOMMUNICATIONS CORPORATION	
HEAD OFFICE-ABU DHABI	

JOINT BOX JRC 4	SCALE AS SHOWN
	SHEET: 1 OF 1

DRAWN	DATE	CHD.	APPD.	DRAWING NO.	REV.
THOMAS	26-10-1997			CN 1815z	H
T:\ACAD\FILES\JO\CH-DIAGRAM\CN 1815z					