

PLUMBING FIXTURES AND FIXTURE FITTINGS

Table 4-2 continued

Type of Building or Occupancy ²	Water Closets ^{14, 18} (Fixtures per Person)	Urinals ^{5, 10} (Fixtures per Person)	Lavatories (Fixtures per Person)	Bathtubs or Showers (Fixtures per Person)	Abolition Stand, Pedestal or Sink (Fixtures per Person)	Drinking Fountains ^{3, 13, 17} (Fixtures per Person)
Office or public buildings	Male Female 1: 1-100 3: 1-50 2: 101-200 4: 51-100 3: 201-400 8: 101-200 11: 201-400 Over 400, add 1 fixture for each additional 500 males and 1 for each additional 150 females.	Male 1: 1-100 2: 101-200 3: 201-400 4: 401-600 Over 600, add 1 fixture for each additional 300 males.	Male Female 1: 1-200 1: 1-200 2: 201-400 2: 201-400 3: 401-750 3: 401-750 Over 750, add 1 fixture for each additional 500 persons.		1: 1-10 2: 11-40 3: 41-80 Over 80, add 1 fixture for each additional 50 persons.	1 per 150 ¹²
Office or public buildings – for employee use	Male Female 1: 1-15 1: 1-15 2: 16-35 3: 16-35 3: 36-55 4: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Male 0: 1-9 1: 10-50 Add 1 fixture for each additional 50 males.	Male Female 1 per 40 1 per 40		1: 1-10 2: 11-40 Over 40, add 1 fixture for each additional 50 persons.	
Penal institutions – for employee use	Male Female 1: 1-15 1: 1-15 2: 16-35 3: 16-35 3: 36-55 4: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Male 0: 1-9 1: 10-50 Add 1 fixture for each additional 50 males.	Male Female 1 per 40 1 per 40		1: 1-10 2: 11-40 Over 40, add 1 fixture for each additional 50 persons.	1 per 150 ¹²
Penal institutions – for prison use Cell Exercise room	1 per cell 1 per exercise room	Male 1 per exercise room	1 per cell 1 per exercise room		1 per cell 2 per exercise room	1 per cell block floor 1 per exercise room
Public or professional offices ¹⁵	Same as Office or Public Buildings for employee use ¹⁵	Same as Office or Public Buildings for employee use ¹⁵	Same as Office or Public Buildings for employee use ¹⁵		Same as Office or Public Buildings for employee use ¹⁵	Same as Office or Public Buildings for employee use ¹⁵
Restaurants, pubs, and lounges ^{11, 15}	Male Female 1: 1-50 1: 1-50 2: 51-150 2: 51-150 3: 151-300 4: 151-300 Over 300, add 1 fixture for each additional 200 persons.	Male 1: 1-150 Over 150, add 1 fixture for each additional 150 males.	Male Female 1: 1-150 1: 1-150 2: 151-200 2: 151-200 3: 201-400 3: 201-400 Over 400, add 1 fixture for each additional 400 persons.		1 per 40 customers	
Retail or wholesale stores	Male Female 1: 1-100 1: 1-25 2: 101-200 2: 26-100 3: 201-400 4: 101-200 6: 201-300 8: 301-400 Over 400, add 1 fixture for each additional 500 males and 1 for each 150 females.	Male 0: 0-25 1: 26-100 2: 101-200 3: 201-400 4: 401-600 Over 600, add 1 fixture for each additional 300 males.	1 per 2 water closets		1: 1-10 2: 11-40 3: 41-80 Over 80, add 1 fixture for each additional 50 persons.	0: 1-30 ¹⁷ 1: 31-150 Over 150, add 1 drink- ing fountain for each additional 150 persons.
Schools – for staff use All schools	Male Female 1: 1-15 1: 1-15 2: 16-35 2: 16-35 3: 36-55 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Male 1 per 50	Male Female 1 per 40 1 per 40		1: 1-10 2: 11-40 3: 41-80 Over 80, add 1 fixture for each additional 50 persons.	
Schools – for student use Nursery	Male Female 1: 1-20 1: 1-20 2: 21-50 2: 21-50 Over 50, add 1 fixture for each additional 50 persons.		Male Female 1: 1-25 1: 1-25 2: 26-50 2: 26-50 Over 50, add 1 fixture for each additional 50 persons.		1 per 20 students	1 per 150 ¹²
Elementary	Male Female 1 per 30 1 per 25	Male 1 per 75	Male Female 1 per 35 1 per 35		1 per 20 students	1 per 150 ¹²
Secondary	Male Female 1 per 40 1 per 30	Male 1 per 35	Male Female 1 per 40 1 per 40		1 per 20 students	1 per 150 ¹²
Others (colleges, univer- sities, adult centers, etc.)	Male Female 1 per 40 1 per 30	Male 1 per 35	Male Female 1 per 40 1 per 40		1 per 20 students	1 per 150 ¹²
Mosques	Male Female 1 per 15 1 per 10		Male Female 1 per 20 1 per 10		1 per 10 worshippers	1 per 150 ¹²
Worship places educational and activities unit	Male Female 1 per 150 1 per 75	Male 1 per 150	1 per 2 water closets			1 per 150 ¹²
Worship places principal assembly place	Male Female 1 per 150 1 per 75	Male 1 per 150	1 per 2 water closets			1 per 150 ¹²