

11 TELEPHONE & TELECOM INSTALLATION

11.1 Main Guideline for Structured Cabling System (SCS)

- 11.1.1 All the Structure Cabling Installations shall follow the Service Authority (DWC) Standards. Refer to Appendix ().
- 11.1.2 The detailed design along with the materials to be used shall be submitted to the service authority (DWC) for approval.
- 11.1.3 The consultant must apply prior to commencing any construction works for the No Objection Certificate (N.O.C) from the service authority (DWC). See Appendix ().
- 11.1.4 The connection to the outside service corridor should be as per the service authority (DWC) requirements and subject to its approval.
- 11.1.5 Adequate size telecom room should be allocated as per the service authority (DWC) requirements, with 24 hours access to the service authority (DWC).
- 11.1.6 Warranty period shall start after issuing of the completion/ Acceptance certificate. See Appendix ().
- 11.1.7 Developers shall make provisions for cable connectivity between the Energy Transfer Station (ETS) Rooms and Telecom room in each building to enable connectivity of ETS room equipment to DWC District Cooling Central plants.