

## COMPLIANCE DOCUMENTATION

**Table 401.02(1): Documents Required**

Project Stages	Submittal Documents
Design Permit Application	1. DM BLDG Al Sa'fat declaration.
Construction Completion Application	1. Completed construction IAQ planning checklists and evaluations of proposed measures. 2. Technical data sheet for temporary and final filter used for MERV requirement. 3. Proof of purchase / delivery notes for temporary and final filter.
After Completion	NA

## REFERENCES AND ADDITIONAL INFORMATION

American Society of Heating, Refrigerating and Air-Conditioning Engineers. (2017). ASHRAE standard 55: Thermal Environmental Conditions for Human Occupancy, [www.ashrae.org](http://www.ashrae.org).

Sheet Metal and Air Conditioning National Contractors Association. (2007). (SMACNA) IAQ Guidelines for Occupied Buildings under Construction, ANSI/SMACNA 008–2008, [www.smacna.org](http://www.smacna.org).

American Society of Heating, Refrigerating and Air-Conditioning Engineers. (2017). ASHRAE standard 55.2: Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size, [www.ashrae.org](http://www.ashrae.org).