Table 5.50 — Health care premises – Decontamination rooms

Ref. no.	Type of area, task or activity	$\bar{E}_m$ lx	UGR_L –	U_o –	R_a –	Specific requirements
5.50.1	Sterilisation rooms	300	22	0,60	80	
5.50.2	Disinfection rooms	300	22	0,60	80	

Table 5.51 — Health care premises – Autopsy rooms and mortuaries

Ref. no.	Type of area, task or activity	$\bar{E}_m$ lx	UGR_L –	U_o –	R_a –	Specific requirements
5.51.1	General lighting	500	19	0,60	90	
5.51.2	Autopsy table and dissecting table	5 000	-	-	90	Values higher than 5 000 lx may be required.

Table 5.52 — Transportation areas – Airports

Ref. no.	Type of area, task or activity	$\bar{E}_m$ lx	UGR_L –	U_o –	R_a –	Specific requirements
5.52.1	Arrival and departure halls, baggage claim areas	200	22	0,40	80	
5.52.2	Connecting areas	150	22	0,40	80	
5.52.3	Information desks, check-in desks	500	19	0,70	80	DSE-work, see 4.9.
5.52.4	Customs and passport control desks	500	19	0,70	80	Facial recognition has to be provided.