

C1- Civils Checklist	Maintenance Task	Maintenance Frequency			
		Daily	Weekly	Monthly	Annually
Pumping Station Security	Check doors and windows for damage. Prior to commencing.	X			
Overall Visual Inspection	Carry out general visual inspection, detection of any damage, cleaning & lubrication (if applicable) for main gate, walkways, ladders, fence/ boundary walls, handrails, glass, Structure (P.S, MCC-Rooms, chambers, toilets) , flap gate and etc. and Submit report of work performed along with colored pictures.			X	
General Repairs	Repair / replace any damaged items for main gate, walkways, ladders, fence /boundary walls, handrails, glass, structure (P.S, chambers , MCC-Rooms, toilets) , flap gate and etc. and submit report of work performed along with colored photographs.				X
Pump Wet Well	Remove sand and debris from wet well / trash rack and submit report for works performed along with colored photographs.			X	
Paintwork & Protective finishes	Apply approved coating material and system to all surfaces of main gate, curbstone, fence / boundary walls, handrails, structure (P.S, chambers , MCC-Rooms, toilets) , and etc. and submit report of work performed along with colored pictures.				2.5
Pipelines, Force Mains and Sewers	Flushing and clean of pipeline to remove any debris, sand, blockage several times to the satisfaction of the engineer and submit for the works performed along with colored photographs and evaluation of assets condition.				X
Stormwater Structure, Manholes, Chambers & sand Traps	De-silting and removal of any other debris of each structure starting from inlets using approved combination tanker.			X	
	Apply approved uniform epoxy coating of MH / Access Covers and Frames, Gratings, Inlets etc.				X
	Carry out necessary repairs of stormwater structures, ladder and replace the missing / broken access cover, etc. And submit report for works performed along with colored pictures.				X
Bar Screens	Check and clean the Bar Screens, and remove the accumulated grits.	X			
Stop Logs Sliding Channels	Clean and remove all deposits.			3	
Rubber Valve	Clean and check for any erosion or clogging.			X	
C2- Lifting Gear	Maintenance Task	Maintenance Frequency			
		Daily	Weekly	Monthly	Annually
Overall Visual Inspection	Carry out general visual inspection, detection of any damage. Cleaning &			X	