

less than 60 feet (18 288 mm) in width and is provided with an approved automatic sprinkler system throughout in accordance with Section 903.3.1.1.

## **SECTION C103 MIXED OCCUPANCIES**

**C103.1 Mixed occupancies.** Mixed occupancies shall be protected in accordance with Section 508.

## **SECTION C104 EXITS**

**C104.1 Exit facilities.** Exits shall be provided in accordance with Chapters 10 and 11.

### **Exceptions:**

1. The maximum travel distance from any point in the building to an approved exit shall not exceed 300 feet (91 440 mm).
2. One exit is required for each 15,000 square feet (1393.5 m<sup>2</sup>) of area or fraction thereof.