

## Level changes

Facility/Building .....		Sheet Number .....
Space/Floor .....		

YES      N/A      NON      Observations

Guardrails				
<b>Absence of unprotected level changes</b> - guardrails for heights $\geq 500$ mm				
<b>Height <math>\geq 1100</math> mm</b>				
<b>With sufficient strength and stiffness to withstand a force of 3 kN/m</b>				
<b>No climbable</b>				
<b>Openings <math>\leq 100</math> mm</b>				
<b>With a continuous base <math>\geq 100</math> mm</b>				
Ramps				
<b>Only when a change in level with gradients <math>\leq 5\%</math> are not possible</b>				
<b>Gradients slope <math>\leq 8\%</math></b>				
<b>Cross fall gradient <math>\geq 2\%</math></b>				
<b>Run length <math>\leq 10</math> meters</b>				
<b>Run width 1000 mm between handrails</b>				
<b>No curved ramps</b>				
<b>Landings at the beginning and end of every run - surface 1500 mm x 1500 mm</b>				
<b>Level landings or <math>\leq 2\%</math></b>				