# 6.0 HORIZONTAL **CIRCULATION**

### **6.1 HORIZONTAL CIRCULATION**

THIS SECTION DEALS WITH THE DESIGN **OF HORIZONTAL** CIRCULATION.

**PERFORMANCE** 

Horizontal circulation shall be

designed so that it provides logically

arranged, well lit, safe and easy to

negotiate routes, suitable for the

patterns of use within a building,

which allow all users to access

services and facilities provided

therein and exit the building in the

**OBJECTIVES** 

event of an emergency.

# The design of horizontal circulation

**6.1.1 MANDATORY** 

will satisfy the performance objectives if:

#### **CORRIDORS AND PASSAGEWAYS**

**PROVISIONS** 

- 1. Corridors and passageways have an unobstructed minimum width of 1800mm (excluding any projections into the space) along their length.
- 2. Within residential apartments the minimum corridor width relates to the clear width of door openings in accordance with Table 5.
- 3. In existing buildings where the unobstructed width of the corridor or passageway is greater than 1200mm but less than 1800mm passing places at least 1800mm long and with a width of at least 1800mm are provided at regular intervals along their length. See Figure 43.
- 4. Elements such as columns, radiators and fire hoses are recessed or protected by a guardrail and are easy to identify.
- 5. Internal circulation routes within new buildings are level.
- 6. Internal circulation routes within existing buildings with a gradient between 1:20 and 1:60 have a level rest area at least 1500mm long for every 500mm change in level and have a clearly differentiated surface.

- 7. Internal circulation routes within existing buildings with a gradient steeper than 1:20 are designed as an internal ramp in accordance with Section 5.2 and steps are provided in addition where the level change
- length between a level and a sloping section.
- 9. Where leaf-and-a-half doors are provided the wider leaf is located on the same side over the length of the corridor.
- 10. Outward opening doors are recessed so that when fully open they do not project into the circulation route.
- 11. Circulation routes in open plan areas comply with items 1 to 10.
- 12. Surfaces, finishes and lighting comply with Section 4.4 Surfaces and Section 8.3 -Internal Lighting.

## is greater than 300mm. 8. If guarding is provided where a corridor is divided along its