

- 3.3.14 All metering cabinets/compartments shall be provided with padlocking and wire-sealing facilities on their external door/cover which shall normally be of hinged type. Generally all apparatus, circuit breakers, isolators, bus bars, removable lid section of bus bar - trunking, etc., installed on the supply side of any DEWA's metering shall have provision for sealing by DEWA.
- 3.3.15 The metering section/compartment in all MDB/s and SMDB/s if and when incorporated within, shall completely be segregated from other sections/compartments.
- 3.3.16 For consumer premises with group of villas, space/provision shall be made for installing DEWA feeder pillars. Final location of such feeder pillars shall be finalized during estimation by considering cable route, cable route length, road crossing etc.