

1. Delivery, storage and handling shall at all times be performed in a manner to avoid product damage.
2. Only nylon slings shall be allowed for lifting products.
3. Products shall be stored off the ground on timber blocks of sufficient size and spacing to provide adequate support.
4. Products shall be stored at site in a temperature, humidity etc. environment as recommended by the manufacturer.
5. Products that are stored outside at site shall be stored under cover to prevent ultra violet deterioration and as recommended by the manufacturer.
6. The Contractor shall inspect all products upon delivery to site and report any damage to the Engineer.
7. Any products damaged during delivery, storage and handling shall be marked by the Contractor and set aside.
8. Proposals for repair of any damaged products shall be submitted in writing to the Engineer for approval.
9. Any damaged products deemed unsuitable for repair by the Engineer shall be removed from site and replaced.

26.3 Part 3 Material Specifications

26.3.1 General

- A. All materials, equipment and accessories shall be specified to support the system design and operating parameters. Whenever materials are required to comply with International Standards they shall be marked with acceptable certification trade mark. For specifications of pipes and fittings, refer to the relevant section(s).

26.3.2 Pipes and Fittings

- A. See relevant sections in the Specification.

26.3.3 Detectable Underground Warning Tape

- A. Marking tapes shall be installed above the pipelines. This shall be laminated polyethylene and aluminium foil, or similar, construction capable of detection by proprietary detection equipment at the surface without the need for connection