Components and Cla	dding – Method 1	h ≤ 60 ft.					
Figure 30.5-1 (cont'd)	Design Wind Pressures	Walls & Roofs					
Enclosed Buildings		Walls & Roots					

## Net Design Wind Pressure, $p_{net30}$ (psf) (Exposure B at h = 30 ft.)

	Zone	Effective	ective Pagin Wind Speed V (mph)																	
	Zone	wind area (sf)	110 115					Basic Wind Speed V (mpl							1	60	180		200	
	1	10	8.9	-21.8	9.7	-23.8	10.5	-25.9	12.4	-30.4	14.3	-35.3	16.5	-40.5	18.7	-46.1	23.7	-58.3	29.3	-72.0
Roof 0 to 7 degrees	1	20	8.3	-21.0	9.1	-23.2	9.9	-25.9	11.6	-29.6	13.4	-34.4	15.4	-39.4	17.6	<del>-4</del> 4.9	22.2	-56.8	27.4	-70.1
	1	50	7.6	-20.5	8.3	-22.4	9.0	-24.4	10.6	-28.6	12.3	-33.2	14.1	-38.1	16.0	43.3	20.3	-54.8	25.0	-67.7
	1	100	7.0	-19.9	7.7	-21.8	8.3	-23.7	9.8	-27.8	11.4	-32.3	13.0	-37.0	14.8	-42.1	18.8	-53.3	23.2	-65.9
	2	10	8.9	-36.5	9.7	-39.9	10.5	-43.5	12.4	-51.0	14.3	-59.2	16.5	-67.9	18.7	-77.3	23.7	-97.8	29.3	-120.7
	2	20	8.3	-32.6	9.1	-35.7	9.9	-38.8	11.6	-45.6	13.4	-52.9	15.4	-60.7	17.6	-69.0	22.2	-87.4	27.4	-107.9
	2	50	7.6	-27.5	8.3	-30.1	9.0	-32.7	10.6	-38.4	12.3	-44.5	14.1	-51.1	16.0	-58.2	20.3	-73.6	25.0	-90.9
	2	100	7.0	-23.6	7.7	-25.8	8.3	-28.1	9.8	-33.0	11.4	-38.2	13.0	-43.9	14.8	-50.0	18.8	-63.2	23.2	-78.1
	3	10	8.9	-55.0	9.7	-60.1	10.5	-65.4	12.4	-76.8	14.3	-89.0	16.5	-102.2	18.7	-116.3	23.7	-147.2	29.3	-181.7
	3	20	8.3	-45.5	9.1	-49.8	9.9	-54.2	11.6	-63.6	13.4	-73.8	15.4	-84.7	17.6	-96.3	22.2	-121.9	27.4	-150.5
	3	50	7.6	-33.1	8.3	-36.1	9.0	-39.3	10.6	-46.2	12.3	-53.5	14.1	-61.5	16.0	-69.9	20.3	-88.5	25.0	-109.3
1	3	100	7.0	-23.6	7.7	-25.8	8.3	-28.1	9.8	-33.0	11.4	-38.2	13.0	-43.9	14.8	-50.0	18.8	-63.2	23.2	-78.1
ses	1	10	12.5	-19.9	13.7	-21.8	14.9	-23.7	17.5	-27.8	20.3	-32.3	23.3	-37.0	26.5	-42.1	33.6	-53.3	41.5	-65.9
	1	20	11.4	-19.4	12.5	-21.2	13.6	-23.0	16.0	-27.0	18.5	-31.4	21.3	-36.0	24.2	-41.0	30.6	-51.9	37.8	-64.0
	1	50	10.0	-18.6	10.9	-20.4	11.9	-22.2	13.9	-26.0	16.1	-30.2	18.5	-34.6	21.1	-39.4	26.7	49.9	32.9	-61.6
) agr	1	100	8.9	-18.1	9.7	-19.8	10.5	-21.5	12.4	-25.2	14.3	-29.3	16.5	-33.6	18.7	-38.2	23.7	-48.4	29.3	-59.8
7 de	2	10	12.5	-34.7	13.7	-37.9	14.9	-41.3	17.5	-48.4	20.3	-56.2	23.3	-64.5	26.5	-73.4	33.6	-92.9	41.5	-114.6
Roof > 7 to 27 degrees	2	20	11.4	-31.9	12.5	-34.9	13.6	-38.0	16.0	-44.6	18.5	-51.7	21.3	-59.3	24.2	-67.5	30.6	-85.4	37.8	-105.5
7 t	2	50	10.0	-28.2	10.9	-30.9	11.9	-33.6	13.9	-39.4	16.1	-45.7	18.5	-52.5	21.1	-59.7	26.7	-75.6	32.9	-93.3
<b> </b> ∱	2	100	8.9	-25.5	9.7	-27.8	10.5	-30.3	12.4	-35.6	14.3	-41.2	16.5	-47.3	18.7	-53.9	23.7	-68.2	29.3	-84.2
Ro	3	10	12.5	-51.3	13.7	-56.0	14.9	-61.0	17.5	-71.6	20.3	-83.1	23.3	-95.4	26.5	-108.5	33.6	-137.3	41.5	-169.5
1	3	20	11.4	-47.9	12.5	-52.4	13.6	-57.1	16.0	-67.0	18.5	-77.7	21.3	-89.2	24.2	-101.4	30.6	-128.4	37.8	-158.5
	3	50	10.0	-43.5	10.9	-47.6	11.9	-51.8	13.9	-60.8	16.1	-70.5	18.5	-81.0	21.1	-92.1	26.7	-116.6	32.9	-143.9
	3	100	8.9	-40.2	9.7	-44.0	10.5	<b>-4</b> 7.9	12.4	-56.2	14.3	-65.1	16.5	-74.8	18.7	-85.1	23.7	-107.7	29.3	-132.9
	1	10	19.9	-21.8	21.8	-23.8	23.7	-25.9	27.8	-30.4	32.3	-35.3	37.0	-40.5	42.1	-46.1	53.3	-58.3	65.9	-72.0
l l	1	20	19.4	-20.7	21.2	-22.6	23.0	-24.6	27.0	-28.9	31.4	-33.5	36.0	-38.4	41.0	-43.7	51.9	-55.3	64.0	-68.3
Roof > 27 to 45 degrees	1	50	18.6	-19.2	20.4	-21.0	22.2	-22.8	26.0	-26.8	30.2	-31.1	34.6	-35.7	39.4	-40.6	49.9	-51.4	61.6	-63.4
egr	1	100	18.1	-18.1	19.8	-19.8	21.5	-21.5	25.2	-25.2	29.3	-29.3	33.6	-33.6	38.2	-38.2	48.4	-48.4	59.8	-59.8
5 d	2	10	19.9	-25.5	21.8	-27.8	23.7	-30.3	27.8	-35.6	32.3	-41.2	37.0	-47.3	42.1	-53.9	53.3	-68.2	65.9	-84.2
to 4	2	20	19.4	-24.3	21.2	-26.6	23.0	-29.0	27.0	-34.0	31.4	-39.4	36.0	-45.3	41.0	-51.5	51.9	-65.2	64.0	-80.5
27	2	50	18.6	-22.9	20.4	-25.0	22.2	-27.2	26.0	-32.0	30.2	-37.1	34.6	-42.5	39.4	-48.4	49.9	-61.3	61.6	-75.6
<u>^</u>	2	100	18.1	-21.8	19.8	-23.8	21.5	-25.9	25.2	-30.4	29.3	-35.3	33.6	-40.5	38.2	-46.1	48.4	-58.3	59.8	-72.0
%	3	10	19.9	-25.5	21.8	-27.8	23.7	-30.3	27.8	-35.6	32.3	-41.2	37.0	-47.3	42.1	-53.9	53.3	-68.2	65.9	-84.2
	3	20	19.4	-24.3	21.2	-26.6	23.0	-29.0	27.0	-34.0	31.4	-39.4	36.0	-45.3	41.0	-51.5	51.9	-65.2	64.0	-80.5
	3	50	18.6	-22.9	20.4	-25.0	22.2	-27.2	26.0	-32.0	30.2	-37.1	34.6	-42.5	39.4	-48.4	49.9	-61.3	61.6	-75.6
	3	100	18.1	-21.8	19.8	-23.8	21.5	-25.9	25.2	-30.4	29.3	-35.3	33.6	-40.5	38.2	-46.1	48.4	-58.3	59.8	-72.0
	4	10	21.8	-23.6	23.8	-25.8	25.9	-28.1	30.4	-33.0	35.3	-38.2	40.5	-43.9	46.1	-50.0	58.3	-63.2	72.0	-78.1
	4	20	20.8	-22.6	22.7	-24.7	24.7	-26.9	29.0	-31.6	33.7	-36.7	38.7	-42.1	44.0	-47.9	55.7	-60.6	68.7	-74.8
Wall	4	50	19.5	-21.3	21.3	-23.3	23.2	-25.4	27.2	-29.8	31.6	-34.6	36.2	-39.7	41.2	-45.1	52.2	-57.1	64.4	-70.5
	4	100	18.5	-20.4	20.2	-22.2	22.0	-24.2	25.9	-28.4	30.0	-33.0	34.4	-37.8	39.2	-43.1	49.6	-54.5	61.2	-67.3
	4	500	16.2	-18.1	17.7	-19.8	19.3	-21.5	22.7	-25.2	26.3	-29.3	30.2	-33.6	34.3	-38.2	43.5	-48.4	53.7	-59.8
	5	10	21.8	-29.1	23.8	-31.9	25.9	-34.7	30.4	-40.7	35.3	-47.2	40.5	-54.2	46.1	-61.7	58.3	-78.0	72.0	-96.3
	5	20	20.8	-27.2	22.7	-29.7	24.7	-32.4	29.0	-38.0	33.7	-44.0	38.7	-50.5	44.0	-57.5	55.7	-72.8	68.7	-89.9
	5	50	19.5	-24.6	21.3	-26.9	23.2	-29.3	27.2	-34.3	31.6	-39.8	36.2	-45.7	41.2	-52.0	52.2	-65.8	64.4	-81.3
	5	100	18.5	-22.6	20.2	-24.7	22.0	-26.9	25.9	-31.6	30.0	-36.7	34.4	-42.1	39.2	-47.9	49.6	-60.6	61.2	-74.8
	5	500	16.2	-18.1	17.7	-19.8	19.3	-21.5	22.7	-25.2	26.3	-29.3	30.2	-33.6	34.3	-38.2	43.5	-48.4	53.7	-59.8
					•	_														

Note: For effective areas between the those given above the load may be interpolated, otherwise use the load associated with the lower effective area.

Unit Conversions – 1.0 ft = 0.3048 m; 1.0 sf =  $0.0929 \text{ m}^2$ ; 1.0 psf =  $0.0479 \text{ kN/m}^2$ 

The final value, including all permitted reductions, used in the design shll not be less than that required by Section 30.2.2.